

This form is now available for electronic submittal using the Alabama Environmental Permitting and Compliance System or AEPACS.

[Note: The program encourages the use of an electronic form submittal rather than a paper form submittal.]

Please click the link below to submit this form electronically using AEPACS.

https://aepacs.adem.alabama.gov/nviro/ncore/external/home

Fac # OFINP Date

ADEM
3 YEAR OVERFILL PREVENTION EQUIPMENT INSPECTION REPORT

Site Name:				Owner:			
Address:				Address:			
City, County, Zip, State, Country:				City, State, Zip, Country:			
Facility I.D. #:				Phone #:/ Fax # Email:			
Inspector Name:				Inspector Phone #:			
Inspector Company:				Inspection Date:			
Site LatitudeLongitude Instructions							
 Submit a completed copy of this form within 30 days of performing test to: Groundwater Branch, PO Box 301463, Montgomery, AL 36130-1463, or fax to: (334) 270-5631, or email to: <u>USTcompliance@adem.alabama.gov</u>. If two or more types of overfill devices are present, only complete portion of form pertaining to the primary overfill device. Inspection must be performed in accordance with a nationally recognized code of practice (such as PEI RP-1200 or equivalent) or the manufacturer's instructions. Keep a copy of this inspection for 3 years. Questions on how to complete this form should be directed to the Groundwater Branch, 							
UST Compliance Section at (334) 270-5655.							
ADEM Unique Tank #							
Product Stored			21 . "				
Primary device being used in each tank to prevent overfill (Record only primary device inspection results.)	☐ Auto Shutoff☐ Alarm☐ Ball Float	☐ Auto Shutoff ☐ Alarm ☐ Ball Float		☐ Auto Shutoff ☐ Alarm ☐ Ball Float	☐ Auto Shutoff☐ Alarm☐ Ball Float	☐ Auto Shutoff☐ Alarm☐ Ball Float	
Was primary overfill device	□ yes	□ yes		□ yes	□ yes	□ yes	
removed for test?	□ no						
Automatic Shutoff Device Inspection							
Drop tube and float free of debris?	□ yes □ no	□ yes □ no		□ yes □ no	□ yes □ no	□ yes □ no	
Float moves freely and poppet	□ yes	□ yes		□ yes	□ yes	□ yes	
moves into path of flow?	□ no	□ no		□ no	□ no	□ no	
Bypass valve free of blockage?	□ yes	□ yes		□ yes	□ yes	□ yes	
(where applicable)	□ no □ n/a	□ no □ n/a		□ no □ n/a	□ no □ n/a	□ no □ n/a	
Flapper adjusted to shut off flow at	□ yes	□ yes		□ yes	□ yes	□ yes	
95% or less capacity?	□ no	□ no		□ no	□ no	□ no	
High Level Alarm Inspection (Outside Near Tanks, Not Inside at Tank Monitor)							
Overfill alarm activates in test	□ yes	□ yes		□ yes	□ yes	□ yes	
mode at console?	□ no	□ no		□ no	□ no	□ no	
Alarm can be heard and/or seen from where the tank is filled?	□ yes □ no	□ yes □ no		□ yes □ no	□ yes □ no	□ yes □ no	
	□ yes	□ yes		□ yes	□ yes	□ yes	
All associated floats move freely?	□ no	□ no		□ no	□ no	□ no	
Alarm activates at 90% or less capacity?	│ □ yes │ □ no	□ yes □ no		□ yes □ no	□ yes □ no	□ yes □ no	
Ball Float Valve Inspection							
- 1.	□ yes	□ yes		□ yes	□ yes	□ yes	
Ball float cage free of debris?	□no	□ no		□ no	□ no	□ no	
Ball moves freely in cage and is free of damage?	□ yes □ no	□ yes □ no		□ yes □ no	□ yes □ no	□ yes □ no	
Vent hole in pipe is open and near	□ yes	□ yes		□ yes	□ yes	□ yes	
the top of the tank?	□ no	□ no		□ no	□ no	□ no	
Ball float pipe is proper length to	□ yes	□ yes		□ yes	□ yes	□ yes	
activate at 90% or less capacity?	□ no	□ no		□ no	□ no	□ no	
Tank top fittings are vapor tight and free of leaks?	│ □ yes │ □ no	□ yes □ no		□ yes □ no	□ yes □ no	□ yes □ no	
		Shutoff Device or F					
Results of Inspection:	□ pass	□ pass	01.00 0.	□ pass	□ pass	□ pass	
("No" answer to any item indicates fail.)	☐ fail	☐ fail		□ fail	□ fail	□ fail	
Repairs Needed	Date of Repair	Description of any Repairs					
-1		Boothpaten of any repairs					
Site ContactLesseeConsultantOwner							
Name, Address, City, State, Zip, CountryPhone, Email							
Tester's Signature:							