



# NATIONAL POLLUTANT DISCHARGE ELIMINATION SYSTEM PERMIT

PERMITTEE: ALABAMA DEPARTMENT OF CONSERVATION AND NATURAL RESOURCES  
4403 MCLEAN DRIVE  
ROGERSVILLE, ALABAMA 35652

FACILITY LOCATION: JOE WHEELER STATE PARK SOUTH LAGOON (0.01 MGD)  
24921 ALABAMA HIGHWAY 101  
TOWN CREEK, ALABAMA  
LAWRENCE COUNTY

PERMIT NUMBER: AL0048488

RECEIVING WATERS: TENNESSEE RIVER

*In accordance with and subject to the provisions of the Federal Water Pollution Control Act, as amended, 33 U.S.C. §§1251-1378 (the "FWPCA"), the Alabama Water Pollution Control Act, as amended, Code of Alabama 1975, §§ 22-22-1 to 22-22-14 (the "AWPCA"), the Alabama Environmental Management Act, as amended, Code of Alabama 1975, §§22-22A-1 to 22-22A-15, and rules and regulations adopted thereunder, and subject further to the terms and conditions set forth in this permit, the Permittee is hereby authorized to discharge into the above-named receiving waters.*

ISSUANCE DATE:

EFFECTIVE DATE:

EXPIRATION DATE:

**Draft**

---

Alabama Department of Environmental Management

**MUNICIPAL SECTION  
NATIONAL POLLUTANT DISCHARGE ELIMINATION SYSTEM (NPDES)  
PERMIT**

**TABLE OF CONTENTS**

|                 |   |           |
|-----------------|---|-----------|
| <b>PART I</b>   | <b>DISCHARGE LIMITATIONS, CONDITIONS, AND REQUIREMENTS .....</b>            | <b>4</b>  |
| A.              | DISCHARGE LIMITATIONS AND MONITORING REQUIREMENTS .....                     | 4         |
| 1.              | Outfall 0011 Discharge Limits .....   | 4         |
| B.              | DISCHARGE MONITORING AND RECORD KEEPING REQUIREMENTS .....                  | 5         |
| 1.              | Representative Sampling .....   | 5         |
| 2.              | Measurement Frequency .....   | 5         |
| 3.              | Test Procedures .....   | 5         |
| 4.              | Recording of Results .....  | 6         |
| 5.              | Records Retention and Production .....                                      | 6         |
| 6.              | Reduction, Suspension or Termination of Monitoring and/or Reporting .....   | 6         |
| 7.              | Monitoring Equipment and Instrumentation .....                              | 6         |
| C.              | DISCHARGE REPORTING REQUIREMENTS .....                                      | 6         |
| 1.              | Reporting of Monitoring Requirements .....                                  | 6         |
| 2.              | Noncompliance Notification .....  | 9         |
| D.              | OTHER REPORTING AND NOTIFICATION REQUIREMENTS .....                         | 10        |
| 1.              | Anticipated Noncompliance .....   | 10        |
| 2.              | Termination of Discharge .....  | 10        |
| 3.              | Updating Information .....  | 10        |
| 4.              | Duty to Provide Information .....   | 10        |
| E.              | SCHEDULE OF COMPLIANCE .....  | 10        |
| 1.              | Compliance with discharge limits .....                                      | 10        |
| 2.              | Schedule .....  | 10        |
| <b>PART II</b>  | <b>OTHER REQUIREMENTS, RESPONSIBILITIES, AND DUTIES .....</b>               | <b>11</b> |
| A.              | OPERATIONAL AND MANAGEMENT REQUIREMENTS .....                               | 11        |
| 1.              | Facilities Operation and Maintenance .....                                  | 11        |
| 2.              | Best Management Practices .....   | 11        |
| 3.              | Certified Operator .....  | 11        |
| B.              | OTHER RESPONSIBILITIES .....  | 11        |
| 1.              | Duty to Mitigate Adverse Impacts .....                                      | 11        |
| 2.              | Right of Entry and Inspection .....   | 11        |
| C.              | BYPASS AND UPSET .....  | 11        |
| 1.              | Bypass .....  | 11        |
| 2.              | Upset .....   | 12        |
| D.              | DUTY TO COMPLY WITH PERMIT, RULES, AND STATUTES .....                       | 12        |
| 1.              | Duty to Comply .....  | 12        |
| 2.              | Removed Substances .....  | 13        |
| 3.              | Loss or Failure of Treatment Facilities .....                               | 13        |
| 4.              | Compliance With Statutes and Rules .....                                    | 13        |
| E.              | PERMIT TRANSFER, MODIFICATION, SUSPENSION, REVOCATION, AND REISSUANCE ..... | 13        |
| 1.              | Duty to Reapply or Notify of Intent to Cease Discharge .....                | 13        |
| 2.              | Change in Discharge .....   | 13        |
| 3.              | Transfer of Permit .....  | 14        |
| 4.              | Permit Modification and Revocation .....                                    | 14        |
| 5.              | Termination .....   | 15        |
| 6.              | Suspension .....  | 15        |
| 7.              | Stay .....  | 15        |
| F.              | COMPLIANCE WITH TOXIC POLLUTANT STANDARD OR PROHIBITION .....               | 15        |
| G.              | NOTICE TO DIRECTOR OF INDUSTRIAL USERS .....                                | 15        |
| H.              | PROHIBITIONS .....  | 16        |
| <b>PART III</b> | <b>ADDITIONAL REQUIREMENTS, CONDITIONS, AND LIMITATIONS .....</b>           | <b>17</b> |

|   |           |
|---|-----------|
| H. PROHIBITIONS.....  | 16        |
| <b>PART III ADDITIONAL REQUIREMENTS, CONDITIONS, AND LIMITATIONS.....</b> | <b>17</b> |
| A. CIVIL AND CRIMINAL LIABILITY.....                                      | 17        |
| 1. Tampering.....   | 17        |
| 2. False Statements.....  | 17        |
| 3. Permit Enforcement.....  | 17        |
| 4. Relief from Liability.....   | 17        |
| B. OIL AND HAZARDOUS SUBSTANCE LIABILITY.....                             | 17        |
| C. PROPERTY AND OTHER RIGHTS.....   | 18        |
| D. AVAILABILITY OF REPORTS.....   | 18        |
| E. EXPIRATION OF PERMITS FOR NEW OR INCREASED DISCHARGES.....             | 18        |
| F. COMPLIANCE WITH WATER QUALITY STANDARDS.....                           | 18        |
| G. GROUNDWATER.....   | 19        |
| H. DEFINITIONS.....   | 19        |
| I. SEVERABILITY.....  | 21        |
| <b>PART IV SPECIFIC REQUIREMENTS, CONDITIONS, AND LIMITATIONS.....</b>    | <b>22</b> |
| A. SLUDGE MANAGEMENT PRACTICES.....                                       | 22        |
| 1. Applicability.....   | 22        |
| 2. Submitting Information.....  | 22        |
| 3. Reopener or Modification.....  | 22        |
| B. EFFLUENT TOXICITY TESTING REOPENER.....                                | 22        |
| C. TOTAL RESIDUAL CHLORINE (TRC) REQUIREMENTS.....                        | 22        |
| D. PLANT CLASSIFICATION.....  | 23        |

**ATTACHMENT:**  
FORM 421

NON-COMPLIANCE NOTIFICATION FORM

## PART I DISCHARGE LIMITATIONS, CONDITIONS, AND REQUIREMENTS

### A. DISCHARGE LIMITATIONS AND MONITORING REQUIREMENTS

1. Outfall 0011 Discharge Limits

During the period beginning on the effective date of this permit and lasting through the expiration date of this permit, the Permittee is authorized to discharge from Outfall 0011, which is described more fully in the Permittee's application. Such discharge shall be limited and monitored by the Permittee as specified below:

| Parameter   | Discharge Limitations* |                   |                  |                |               |                  | Monitoring Requirements** |                     |                 |                           |              |
|---|------------------------|-------------------|------------------|----------------|---------------|------------------|---------------------------|---------------------|-----------------|---------------------------|--------------|
|   | Monthly Average        | Weekly Average    | Monthly Average  | Weekly Average | Daily Minimum | Daily Maximum    | Percent Removal           | (1) Sample Location | (2) Sample Type | (3) Measurement Frequency | (4) Seasonal |
| pH<br>00400 I 0 0                                       | *****                  | *****             | *****            | *****          | 6.0<br>S.U.   | 9.0<br>S.U.      | *****                     | E                   | GRAB            | G                         | *****        |
| Solids, Total Suspended<br>00530 I 0 0                  | 7.50<br>lbs/day        | 11.2<br>lbs/day   | 90.0<br>mg/l     | 135<br>mg/l    | *****         | *****            | *****                     | E                   | GRAB            | G                         | *****        |
| Solids, Total Suspended<br>00530 G 0 0                  | REPORT<br>lbs/day      | REPORT<br>lbs/day | REPORT<br>mg/l   | REPORT<br>mg/l | *****         | *****            | *****                     | I                   | GRAB            | G                         | *****        |
| Nitrogen, Ammonia Total (As N)<br>00610 I 0 0           | 1.66<br>lbs/day        | 2.50<br>lbs/day   | 20.0<br>mg/l     | 30.0<br>mg/l   | *****         | *****            | *****                     | E                   | GRAB            | G                         | *****        |
| Nitrogen, Kjeldahl Total (As N)<br>00625 I 0 0          | REPORT<br>lbs/day      | REPORT<br>lbs/day | REPORT<br>mg/l   | REPORT<br>mg/l | *****         | *****            | *****                     | E                   | GRAB            | G                         | S            |
| Nitrite Plus Nitrate Total I Det. (As N)<br>00630 I 0 0 | REPORT<br>lbs/day      | REPORT<br>lbs/day | REPORT<br>mg/l   | REPORT<br>mg/l | *****         | *****            | *****                     | E                   | GRAB            | G                         | S            |
| Phosphorus, Total (As P)<br>00665 I 0 0                 | REPORT<br>lbs/day      | REPORT<br>lbs/day | REPORT<br>mg/l   | REPORT<br>mg/l | *****         | *****            | *****                     | E                   | GRAB            | G                         | S            |
| Flow, In Conduit or Thru Treatment Plant<br>50050 I 0 0 | REPORT<br>MGD          | *****             | *****            | *****          | *****         | REPORT<br>MGD    | *****                     | E                   | INSTAN          | G                         | *****        |
| Chlorine, Total Residual See note (5)<br>50060 I 0 0    | *****                  | *****             | *****            | *****          | *****         | 1.0<br>mg/l      | *****                     | E                   | GRAB            | G                         | *****        |
| E. Coli<br>51040 I 0 0                                  | *****                  | *****             | 126<br>col/100mL | *****          | *****         | 235<br>col/100mL | *****                     | E                   | GRAB            | G                         | *****        |
| BOD, Carbonaceous 05 Day, 20C<br>80082 I 0 0            | 2.0<br>lbs/day         | 3.0<br>lbs/day    | 25.0<br>mg/l     | 37.5<br>mg/l   | *****         | *****            | *****                     | E                   | GRAB            | G                         | *****        |
| BOD, Carbonaceous 05 Day, 20C<br>80082 G 0 0            | REPORT<br>lbs/day      | REPORT<br>lbs/day | REPORT<br>mg/l   | REPORT<br>mg/l | *****         | *****            | *****                     | I                   | GRAB            | G                         | *****        |
| BOD, 5-Day Percent Removal<br>81010 K 0 0               | *****                  | *****             | *****            | *****          | *****         | *****            | 85.0%                     | K                   | CALCTD          | G                         | *****        |
| Solids, Suspended Percent Removal<br>81011 K 0 0        | *****                  | *****             | *****            | *****          | *****         | *****            | 65.0%                     | K                   | CALCTD          | G                         | *****        |

\* See Part II.C.1. (Bypass); Part II.C.2. (Upsset)

\*\* Monitoring Requirements

(1) Sample Location

I - Influent

E - Effluent

X - End Chlorine Contact Chamber

K - Percent Removal of the Monthly Avg. Influent Concentration

from the Monthly Avg. Effluent Concentration.

RS - Receiving Stream

(2) Sample Type:

CONTIN - Continuous

INSTAN - Instantaneous

COMP-8 - 8-Hour Composite

COMP24 - 24-Hour Composite

GRAB - Grab

CALCTD - Calculated

(3) Measurement Frequency: See also Part I.B.2.

A - 7 days per week

B - 5 days per week

C - 3 days per week

D - 2 days per week

E - 1 day per week

F - 2 days per month

G - 1 day per month

H - 1 day per quarter

J - Annual

Q - For Effluent Toxicity Testing, see Provision IV.B.

(4) Seasonal Limits:

S = Summer (April - October)

W = Winter (November - March)

ECS = E. coli Summer (June - September)

ECW = E. coli Winter (October - May)

(5) See Part IV.C. for Total Residual Chlorine (TRC). Monitoring for TRC is applicable if chlorine is utilized for disinfection purposes. If monitoring is not applicable during the monitoring period, enter "NODI=9" on the monthly DMR.

**B. DISCHARGE MONITORING AND RECORD KEEPING REQUIREMENTS**

## 1. Representative Sampling

Sample collection and measurement actions shall be representative of the volume and nature of the monitored discharge and shall be in accordance with the provisions of this permit. The effluent sampling point shall be at the nearest accessible location just prior to discharge and after final treatment, unless otherwise specified in the permit.

## 2. Measurement Frequency

Measurement frequency requirements found in Provision I.A. shall mean:

- a. Seven days per week shall mean daily.
- b. Five days per week shall mean any five days of discharge during a calendar weekly period of Sunday through Saturday.
- c. Three days per week shall mean any three days of discharge during a calendar week.
- d. Two days per week shall mean any two days of discharge during a calendar week.
- e. One day per week shall mean any day of discharge during a calendar week.
- f. Two days per month shall mean any two days of discharge during the month that are no less than seven days apart. However, if discharges occur only during one seven-day period in a month, then two days per month shall mean any two days of discharge during that seven day period.
- g. One day per month shall mean any day of discharge during the calendar month.
- h. Quarterly shall mean any day of discharge during each calendar quarter.
- i. The Permittee may increase the frequency of sampling, listed in Provisions I.B.2.a through I.B.2.h; however, all sampling results are to be reported to the Department.

## 3. Test Procedures

For the purpose of reporting and compliance, Permittees shall use one of the following procedures:

- a. For parameters with an EPA established Minimum Level (ML), report the measured value if the analytical result is at or above the ML and report "0" for values below the ML. Test procedures for the analysis of pollutants shall conform to 40 CFR Part 136 and guidelines published pursuant to Section 304(h) of the FWPCA, 33 U.S.C. Section 1314(h). If more than one method for analysis of a substance is approved for use, a method having a minimum level lower than the permit limit shall be used. If the minimum level of all methods is higher than the permit limit, the method having the lowest minimum level shall be used and a report of less than the minimum level shall be reported as zero and will constitute compliance, however should EPA approve a method with a lower minimum level during the term of this permit the Permittee shall use the newly approved method.
- b. For pollutants parameters without an established ML, an interim ML may be utilized. The interim ML shall be calculated as 3.18 times the Method Detection Level (MDL) calculated pursuant to 40 CFR Part 136, Appendix B.

Permittees may develop an effluent matrix-specific ML, where an effluent matrix prevents attainment of the established ML. However, a matrix specific ML shall be based upon proper laboratory method and technique. Matrix-specific MLs must be approved by the Department, and may be developed by the Permittee during permit issuance, reissuance, modification, or during compliance schedule.

In either case the measured value should be reported if the analytical result is at or above the ML and "0" reported for values below the ML.

- c. For parameters without an EPA established ML, interim ML, or matrix-specific ML, a report of less than the detection limit shall constitute compliance if the detection limit of all analytical methods is higher than the permit limit. For the purpose of calculating a monthly average, "0" shall be used for values reported less than the detection limit.

The Minimum Level utilized for procedures a and b above shall be reported on the Permittee's DMR. When an EPA approved test procedure for analysis of a pollutant does not exist, the Director shall approve the procedure to be used.

4. Recording of Results

For each measurement or sample taken pursuant to the requirements of this permit, the permittee shall record the following information:

- a. The facility name and location, point source number, date, time and exact place of sampling;
- b. The name(s) of person(s) who obtained the samples or measurements;
- c. The dates and times the analyses were performed;
- d. The name(s) of the person(s) who performed the analyses;
- e. The analytical techniques or methods used, including source of method and method number; and
- f. The results of all required analyses.

5. Records Retention and Production

- a. The permittee shall retain records of all monitoring information, including all calibration and maintenance records and all original strip chart recordings for continuous monitoring instrumentation, copies of all reports required by the permit, and records of all data used to complete the above reports or the application for this permit, for a period of at least three years from the date of the sample measurement, report or application. This period may be extended by request of the Director at any time. If litigation or other enforcement action, under the AWPCA and/or the FWPCA, is ongoing which involves any of the above records, the records shall be kept until the litigation is resolved. Upon the written request of the Director or his designee, the permittee shall provide the Director with a copy of any record required to be retained by this paragraph. Copies of these records should not be submitted unless requested.
- b. All records required to be kept for a period of three years shall be kept at the permitted facility or an alternate location approved by the Department in writing and shall be available for inspection.

6. Reduction, Suspension or Termination of Monitoring and/or Reporting

- a. The Director may, with respect to any point source identified in Provision I.A. of this permit, authorize the permittee to reduce, suspend or terminate the monitoring and/or reporting required by this permit upon the submission of a written request for such reduction, suspension or termination by the permittee, supported by sufficient data which demonstrates to the satisfaction of the Director that the discharge from such point source will continuously meet the discharge limitations specified in Provision I.A. of this permit.
- b. It remains the responsibility of the permittee to comply with the monitoring and reporting requirements of this permit until written authorization to reduce, suspend or terminate such monitoring and/or reporting is received by the permittee from the Director.

7. Monitoring Equipment and Instrumentation

All equipment and instrumentation used to determine compliance with the requirements of this permit shall be installed, maintained, and calibrated in accordance with the manufacturer's instructions or, in the absence of manufacturer's instructions, in accordance with accepted practices. At a minimum, flow measurement devices shall be calibrated at least once every 12 months.

**C. DISCHARGE REPORTING REQUIREMENTS**

1. Reporting of Monitoring Requirements

- a. The permittee shall conduct the required monitoring in accordance with the following schedule:

(1) **MONITORING REQUIRED MORE FREQUENTLY THAN MONTHLY AND MONTHLY** shall be conducted during the first full month following the effective date of coverage under this permit and every month thereafter.

- (2) **QUARTERLY MONITORING** shall be conducted at least once during each calendar quarter. Calendar quarters are the periods of January through March, April through June, July through September, and October through December. The permittee shall conduct the quarterly monitoring during the first complete calendar quarter following the effective date of this permit and is then required to monitor once during each quarter thereafter. Quarterly monitoring should be reported on the last DMR due for the quarter (i.e. March, June, September and December DMRs).
  - (3) **SEMIANNUAL MONITORING** shall be conducted at least once during the period of January through June and at least once during the period of July through December. The permittee shall conduct the semiannual monitoring during the first complete calendar semiannual period following the effective date of this permit and is then required to monitor once during each semiannual period thereafter. Semiannual monitoring may be done anytime during the semiannual period, unless restricted elsewhere in this permit, but it should be reported on the last DMR due for the month of the semiannual period (i.e. June and December DMRs).
  - (4) **ANNUAL MONITORING** shall be conducted at least once during the period of January through December. The permittee shall conduct the annual monitoring during the first complete calendar annual period following the effective date of this permit and is then required to monitor once during each annual period thereafter. Annual monitoring may be done anytime during the year, unless restricted elsewhere in this permit, but it should be reported on the December DMR.
- b. The permittee shall submit discharge monitoring reports (DMRs) on the forms approved by the Department and in accordance with the following schedule:
- (1) **REPORTS OF MORE FREQUENTLY THAN MONTHLY AND MONTHLY TESTING** shall be submitted on a monthly basis. The first report is due on the 28th day of the month following the month the permit becomes effective. The reports shall be submitted so that they are received by the Department no later than the 28th day of the month following the reporting period.
  - (2) **REPORTS OF QUARTERLY TESTING** shall be submitted on a quarterly basis. The first report is due on the 28th day of the month following the month the permit becomes effective. The reports shall be submitted so that they are received by the Department no later than the 28th day of the month following the reporting period.
  - (3) **REPORTS OF SEMIANNUAL TESTING** shall be submitted on a semiannual basis. The reports are due on the 28th day of JANUARY and the 28th day of JULY. The reports shall be submitted so that they are received by the Department no later than the 28th day of the month following the reporting period.
  - (4) **REPORTS OF ANNUAL TESTING** shall be submitted on an annual basis. Unless specified elsewhere in the permit, the first report is due on the 28th day of JANUARY. The reports shall be submitted so that they are received by the Department no later than the 28th day of the month following the reporting period.
- c. The Department is utilizing a web-based electronic environmental (E2) DMR reporting system for submittal of DMRs. **If the permittee is not already participating in the E2 DMR system, the permittee must apply for participation in the system within 180 days of coverage under this permit unless the facility submits in writing valid justification as to why they cannot participate and the Department approves in writing utilization of hard copy DMR submittals.** Once the permittee is enrolled in the E2 DMR system, the permittee must utilize the system for the submittal of DMRs unless otherwise allowed by this permit. To participate in the E2 DMR system, the Permittee Participation Package may be downloaded online at <https://e2.adem.alabama.gov/npdes>. If the E2 DMR system is down (i.e., electronic submittal of DMR data is unable to be completed due to technical problems originating with the Department's system: this could include entry/submittal issues with an entire set of DMRs or individual parameters), the permittee is not relieved of their obligation to submit DMR data to the Department by the required submittal date. However, if the E2 DMR system is down on the 28<sup>th</sup> day of the month or is down for an extended period of time as determined by the Department when a DMR is required to be submitted, the facility may submit the data in an alternate manner and format acceptable to the Department. Preapproved alternate

acceptable methods include faxing, e-mailing, mailing, or hand-delivery of data such that they are received by the required reporting date. Within five calendar days of the E2 DMR system resuming operation, the permittee shall enter the data into the E2 DMR system, unless an alternate timeframe is approved by the Department. An attachment should be included with the E2 DMR submittal verifying the original submittal date (date of the fax, copy of dated e-mail, or hand-delivery stamped date). If a permittee is allowed to submit via the US Postal Service, the DMR must be legible and bear an original signature. Photo and electronic copies of the signature are not acceptable and shall not satisfy the reporting requirements of this permit. If the permittee, using approved analytical methods as specified in Provision I.B.2, monitors any discharge from a point source for a limited substance identified in Provision I.A of this permit more frequently than required by this permit, the results of such monitoring shall be included in the calculation and reporting of values on the DMR form and the increased frequency shall be indicated on the DMR form. In the event no discharge from a point source identified in Provision I.A of this permit and described more fully in the permittee's application occurs during a monitoring period, the permittee shall report "No Discharge" for such period on the appropriate DMR form.

- d. All reports and forms required to be submitted by this permit, the AWPCA and the Department's Rules and regulations, shall be electronically signed (or, if allowed by the Department, traditionally signed) by a "responsible official" of the permittee as defined in ADEM Administrative Code Rule 335-6-6-.09 or a "duly authorized representative" of such official as defined in ADEM Administrative Code Rule 335-6-6-.09 and shall bear the following certification:

**"I certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations."**

- e. The permittee may certify in writing that a discharge will not occur for an extended period of time and after such certification shall not be required to submit monitoring reports. Written notification of a planned resumption of discharge shall be submitted at least 30 days prior to resumption of the discharge. If an unplanned resumption of discharge occurs, written notification shall be submitted within 7 days of the resumption. In any case, all discharges shall comply with all provisions of this permit.
- f. All reports and forms required to be submitted by this permit, the AWPCA and the Department's Rules, shall be addressed to:

**Alabama Department of Environmental Management  
Municipal Section, Water Division  
Post Office Box 301463  
Montgomery, Alabama 36130-1463**

Certified and Registered Mail shall be addressed to:

**Alabama Department of Environmental Management  
Municipal Section, Water Division  
1400 Coliseum Boulevard  
Montgomery, Alabama 36110-2059**

DMRs required to be submitted by this permit shall be addressed to:

**Alabama Department of Environmental Management  
Environmental Data Section, Permits & Services Division  
Post Office Box 301463  
Montgomery, Alabama 36130-1463**

- g. If this permit is a re-issuance, then the permittee shall continue to submit DMRs in accordance with the requirements of their previous permit until such time as DMRs are due as discussed in Part I.C.1.b. above.

## 2. Noncompliance Notification

- a. The Permittee must notify the Department if, for any reason, the Permittee's discharge:
  - (1) Does not comply with any daily minimum or maximum discharge limitation for an effluent characteristic specified in Provision I. A. of this permit which is denoted by an "(X)"
  - (2) Potentially threatens human health or welfare,
  - (3) Threatens fish or aquatic life
  - (4) Causes an in-stream water quality criterion to be exceeded;
  - (5) Does not comply with an applicable toxic pollutant effluent standard or prohibition established under Section 307(a) of the FWPCA, 33 U.S.C. Section 1317(a);
  - (6) Contains a quantity of a hazardous substance that may be harmful to public health or welfare under Section 311(b)(4) of the FWPCA, 33 U.S.C. Section 1321(b)(4);
  - (7) Exceeds any discharge limitation for an effluent parameter listed in Part I.A as a result of an unanticipated bypass or upset; or
  - (8) Is an unpermitted direct or indirect discharge of a pollutant to a water of the state (Note that unpermitted discharges properly reported to the Department under any other requirement are not required to be reported under this provision)

The Permittee shall orally or electronically report any of the above occurrences, describing the circumstances and potential effects, to the Department within 24-hours after the Permittee becomes aware of the occurrence of such discharge. In addition to the oral or electronic report, the Permittee shall submit a written report to the Director or Designee, as provided in Provision I.C.2.c, no later than five days after becoming aware of the occurrence of such discharge or occurrence.

- b. If for any reason, the Permittee's discharge does not comply with any limitation of this permit, then the Permittee must submit a written report to the Director or Designee, as provided in Provision I.C.2.c below. This report must be submitted with the next Discharge Monitoring Report required to be submitted by Provision I.C.1 of this permit after becoming aware of the occurrence of such noncompliance.
- c. Form 421 must be submitted to the Director or Designee in accordance with Provisions I.C.2a. or b. The completed form must document the following information:
  - (1) A description of the discharge and cause of noncompliance;
  - (2) The period of noncompliance, including exact dates, times, and duration of the noncompliance. If not corrected by the due date of the written report, then the Permittee is to state the anticipated timeframe that is expected to transpire before the noncompliance is resolved; and
  - (3) A description of the steps taken by the Permittee and the steps planned to be taken by the Permittee to reduce or eliminate the noncompliant discharge, including all steps taken to prevent recurrence.

### d. Immediate notification

The permittee shall provide notification to the Director, the public, the county health department, and any other affected entity such as public water systems, as soon as possible upon becoming aware of any notifiable sanitary sewer overflow. The Permittee shall also report notification of the noncompliance event to any other affected entity such as the public.

- e. The Permittee shall report SSO and other illicit or anomalous discharge events on Form 415 in accordance with Part I.C.2.a. This form is available on the ADEM web page or upon request from the Permittee.

**D. OTHER REPORTING AND NOTIFICATION REQUIREMENTS**

## 1. Anticipated Noncompliance

The permittee shall give the Director written advance notice of any planned changes or other circumstances regarding a facility which may result in noncompliance with permit requirements.

## 2. Termination of Discharge

The permittee shall notify the Director, in writing, when all discharges from any point source(s) identified in Provision I. A. of this permit have permanently ceased. This notification shall serve as sufficient cause for instituting procedures for modification or termination of the permit.

## 3. Updating Information

a. The permittee shall inform the Director of any change in the permittee's mailing address or telephone number or in the permittee's designation of a facility contact or office having the authority and responsibility to prevent and abate violations of the AWPCA, the Department's Rules and the terms and conditions of this permit, in writing, no later than ten (10) days after such change. Upon request of the Director or his designee, the permittee shall furnish the Director with an update of any information provided in the permit application.

b. If the permittee becomes aware that it failed to submit any relevant facts in a permit application, or submitted incorrect information in a permit application or in any report to the Director, it shall promptly submit such facts or information with a written explanation for the mistake and/or omission.

## 4. Duty to Provide Information

The permittee shall furnish to the Director, within a reasonable time, any information which the Director or his designee may request to determine whether cause exists for modifying, revoking and re-issuing, suspending, or terminating this permit, in whole or in part, or to determine compliance with this permit.

**E. SCHEDULE OF COMPLIANCE**

## 1. Compliance with discharge limits

The permittee shall achieve compliance with the discharge limitations specified in Provision I. A. in accordance with the following schedule:

COMPLIANCE SHALL BE ATTAINED ON THE EFFECTIVE DATE OF THIS PERMIT

## 2. Schedule

No later than 14 calendar days following a date identified in the above schedule of compliance, the permittee shall submit either a report of progress or, in the case of specific actions being required by identified dates, a written notice of compliance or noncompliance. In the latter case, the notice shall include the cause of noncompliance, any remedial actions taken, and the probability of meeting the next scheduled requirement.

## **PART II OTHER REQUIREMENTS, RESPONSIBILITIES, AND DUTIES**

### **A. OPERATIONAL AND MANAGEMENT REQUIREMENTS**

#### **1. Facilities Operation and Maintenance**

The permittee shall at all times properly operate and maintain all facilities and systems of treatment and control (and related appurtenances) which are installed or used by the permittee to achieve compliance with the conditions of the permit. Proper operation and maintenance includes effective performance, adequate funding, adequate operator staffing and training, and adequate laboratory and process controls, including appropriate quality assurance procedures. This provision requires the operation of backup or auxiliary facilities only when necessary to achieve compliance with the conditions of the permit.

#### **2. Best Management Practices**

- a. Dilution water shall not be added to achieve compliance with discharge limitations except when the Director or his designee has granted prior written authorization for dilution to meet water quality requirements.
- b. The permittee shall prepare, implement, and maintain a Spill Prevention, Control and Countermeasures (SPCC) Plan in accordance with 40 C.F.R. Section 112 if required thereby.
- c. The permittee shall prepare, submit for approval and implement a Best Management Practices (BMP) Plan for containment of any or all process liquids or solids, in a manner such that these materials do not present a significant potential for discharge, if so required by the Director or his designee. When submitted and approved, the BMP Plan shall become a part of this permit and all requirements of the BMP Plan shall become requirements of this permit.

#### **3. Certified Operator**

The permittee shall not operate any wastewater treatment plant unless the competency of the operator to operate such plant has been duly certified by the Director pursuant to AWPCA, and meets the requirements specified in ADEM Administrative Code, Rule 335-10-1.

### **B. OTHER RESPONSIBILITIES**

#### **1. Duty to Mitigate Adverse Impacts**

The permittee shall promptly take all reasonable steps to mitigate and minimize or prevent any adverse impact on human health or the environment resulting from noncompliance with any discharge limitation specified in Provision I. A. of this permit, including such accelerated or additional monitoring of the discharge and/or the receiving waterbody as necessary to determine the nature and impact of the noncomplying discharge.

#### **2. Right of Entry and Inspection**

- a. The permittee shall allow the Director, or an authorized representative, upon the presentation of proper credentials and other documents as may be required by law to:
  - (1) Enter upon the permittee's premises where a regulated facility or activity or point source is located or conducted, or where records must be kept under the conditions of the permit;
  - (2) Have access to and copy, at reasonable times, any records that must be kept under the conditions of the permits.
  - (3) Inspect any facilities, equipment (including monitoring and control equipment), practices, or operations regulated or required under the permit; and
  - (4) Sample or monitor, for the purposes of assuring permit compliance or as otherwise authorized by the AWPCA, any substances or parameters at any location.

### **C. BYPASS AND UPSET**

#### **1. Bypass**

- a. Any bypass is prohibited except as provided in b. and c. below:

- b. A bypass is not prohibited if:
    - (1) It does not cause any discharge limitation specified in Provision I. A. of this permit to be exceeded;
    - (2) It enters the same receiving stream as the permitted outfall and;
    - (3) It is necessary for essential maintenance of a treatment or control facility or system to assure efficient operation of such facility or system.
  - c. A bypass is not prohibited and need not meet the discharge limitations specified in Provision I. A. of this permit if:
    - (1) It is unavoidable to prevent loss of life, personal injury, or severe property damage;
    - (2) There are no feasible alternatives to the bypass, such as the use of auxiliary treatment facilities, retention of untreated wastes, or maintenance during normal periods of equipment downtime (this condition is not satisfied if adequate back-up equipment should have been installed in the exercise of reasonable engineering judgment to prevent a bypass which occurred during normal periods of equipment downtime or preventive maintenance); and
    - (3) The permittee submits a written request for authorization to bypass to the Director at least ten (10) days prior to the anticipated bypass (if possible), the permittee is granted such authorization, and the permittee complies with any conditions imposed by the Director to minimize any adverse impact on human health or the environment resulting from the bypass.
  - d. The permittee has the burden of establishing that each of the conditions of Provision II. C. 1. b. or c. have been met to qualify for an exception to the general prohibition against bypassing contained in a. and an exemption, where applicable, from the discharge limitations specified in Provision I. A. of this permit.
2. Upset
- a. A discharge which results from an upset need not meet the discharge limitations specified in Provision I. A. of this permit if:
    - (1) No later than 24-hours after becoming aware of the occurrence of the upset, the Permittee orally reports the occurrence and circumstances of the upset to the Director or his designee; and
    - (2) No later than five (5) days after becoming aware of the occurrence of the upset, the Permittee furnishes the Director with evidence, including properly signed, contemporaneous operating logs, or other relevant evidence, demonstrating that:
      - (i) An upset occurred;
      - (ii) The Permittee can identify the specific cause(s) of the upset;
      - (iii) The Permittee's facility was being properly operated at the time of the upset; and
      - (iv) The Permittee promptly took all reasonable steps to minimize any adverse impact on human health or the environment resulting from the upset.
  - b. The permittee has the burden of establishing that each of the conditions of Provision II C. 2. a. of this permit have been met to qualify for an exemption from the discharge limitations specified in Provision I. A. of this permit.

#### **D. DUTY TO COMPLY WITH PERMIT, RULES, AND STATUTES**

##### **1. Duty to Comply**

- a. The permittee must comply with all conditions of this permit. Any permit noncompliance constitutes a violation of the AWPCA and the FWPCA and is grounds for enforcement action, for permit termination, revocation and reissuance, suspension, modification, or denial of a permit renewal application.
- b. The necessity to halt or reduce production or other activities in order to maintain compliance with the conditions of the permit shall not be a defense for a permittee in an enforcement action.

- c. The discharge of a pollutant from a source not specifically identified in the permit application for this permit and not specifically included in the description of an outfall in this permit is not authorized and shall constitute noncompliance with this permit.
  - d. The permittee shall take all reasonable steps, including cessation of production or other activities, to minimize or prevent any violation of this permit or to minimize or prevent any adverse impact of any permit violation.
  - e. Nothing in this permit shall be construed to preclude or negate the Permittee's responsibility to apply for, obtain, or comply with other Federal, State, or Local Government permits, certifications, or licenses or to preclude from obtaining other federal, state, or local approvals, including those applicable to other ADEM programs and regulations.
2. **Removed Substances**

Solids, sludges, filter backwash, or any other pollutant or other waste removed in the course of treatment or control of wastewaters shall be disposed of in a manner that complies with all applicable Department Rules.
  3. **Loss or Failure of Treatment Facilities**

Upon the loss or failure of any treatment facilities, including but not limited to the loss or failure of the primary source of power of the treatment facility, the permittee shall, where necessary to maintain compliance with the discharge limitations specified in Provision I. A. of this permit, or any other terms or conditions of this permit, cease, reduce, or otherwise control production and/or all discharges until treatment is restored. If control of discharge during loss or failure of the primary source of power is to be accomplished by means of alternate power sources, standby generators, or retention of inadequately treated effluent, the permittee must furnish to the Director within six months a certification that such control mechanisms have been installed.
  4. **Compliance With Statutes and Rules**
    - a. This permit has been issued under ADEM Administrative Code, Chapter 335-6-6. All provisions of this chapter, that are applicable to this permit, are hereby made a part of this permit. A copy of this chapter may be obtained for a small charge from the Office of General Counsel, Alabama Department of Environmental Management, 1400 Coliseum Boulevard Montgomery, Alabama 36110-2059.
    - b. This permit does not authorize the noncompliance with or violation of any Laws of the State of Alabama or the United States of America or any regulations or rules implementing such laws. FWPCA, 33 U.S.C. Section 1319, and Code of Alabama 1975, Section 22-22-14.

#### **E. PERMIT TRANSFER, MODIFICATION, SUSPENSION, REVOCATION, AND REISSUANCE**

1. **Duty to Reapply or Notify of Intent to Cease Discharge**
  - a. If the permittee intends to continue to discharge beyond the expiration date of this permit, the permittee shall file a complete permit application for reissuance of this permit at least 180 days prior to its expiration. If the permittee does not intend to continue discharge beyond the expiration of this permit, the permittee shall submit written notification of this intent which shall be signed by an individual meeting the signatory requirements for a permit application as set forth in ADEM Administrative Code Rule 335-6-6-.09.
  - b. Failure of the permittee to apply for reissuance at least 180 days prior to permit expiration will void the automatic continuation of the expiring permit provided by ADEM Administrative Code Rule 335-6-6-.06 and should the permit not be reissued for any reason any discharge after expiration of this permit will be an unpermitted discharge.
2. **Change in Discharge**

Prior to any facility expansion, process modification or any significant change in the method of operation of the permittee's treatment works, the permittee shall provide the Director with information concerning the planned expansion, modification or change. The permittee shall apply for a permit modification at least 180 days prior to any facility expansion, process modification, any significant change in the method of operation of the permittee's treatment works or other actions that could result in the discharge of

additional pollutants or increase the quantity of a discharged pollutant or could result in an additional discharge point. This condition applies to pollutants that are or that are not subject to discharge limitations in this permit. No new or increased discharge may begin until the Director has authorized it by issuance of a permit modification or a reissued permit.

### 3. Transfer of Permit

This permit may not be transferred or the name of the permittee changed without notice to the Director and subsequent modification or revocation and reissuance of the permit to identify the new permittee and to incorporate any other changes as may be required under the FWPCA or AWPCA. In the case of a change in name, ownership or control of the permittee's premises only, a request for permit modification in a format acceptable to the Director is required at least 30 days prior to the change. In the case of a change in name, ownership or control of the permittee's premises accompanied by a change or proposed change in effluent characteristics, a complete permit application is required to be submitted to the Director at least 180 days prior to the change. Whenever the Director is notified of a change in name, ownership or control, he may decide not to modify the existing permit and require the submission of a new permit application.

### 4. Permit Modification and Revocation

- a. This permit may be modified or revoked and reissued, in whole or in part, during its term for cause, including but not limited to, the following:
  - (1) If cause for termination under Provision II. E. 5. of this permit exists, the Director may choose to revoke and reissue this permit instead of terminating the permit;
  - (2) If a request to transfer this permit has been received, the Director may decide to revoke and reissue or to modify the permit; or
  - (3) If modification or revocation and reissuance is requested by the permittee and cause exists, the Director may grant the request.
- b. This permit may be modified during its term for cause, including but not limited to, the following:
  - (1) If cause for termination under Provision II. E. 5. of this permit exists, the Director may choose to modify this permit instead of terminating this permit;
  - (2) There are material and substantial alterations or additions to the facility or activity generating wastewater which occurred after permit issuance which justify the application of permit conditions that are different or absent in the existing permit;
  - (3) The Director has received new information that was not available at the time of permit issuance and that would have justified the application of different permit conditions at the time of issuance;
  - (4) A new or revised requirement(s) of any applicable standard or limitation is promulgated under Sections 301(b)(2)(C), (D), (E), and (F), and 307(a)(2) of the FWPCA;
  - (5) Errors in calculation of discharge limitations or typographical or clerical errors were made;
  - (6) To the extent allowed by ADEM Administrative Code, Rule 335-6-6-.17, when the standards or regulations on which the permit was based have been changed by promulgation of amended standards or regulations or by judicial decision after the permit was issued;
  - (7) To the extent allowed by ADEM Administrative Code, Rule 335-6-6-.17, permits may be modified to change compliance schedules;
  - (8) To agree with a granted variance under 301(c), 301(g), 301(h), 301(k), or 316(a) of the FWPCA or for fundamentally different factors;
  - (9) To incorporate an applicable 307(a) FWPCA toxic effluent standard or prohibition;
  - (10) When required by the reopener conditions in this permit;
  - (11) When required under 40 CFR 403.8(e) (compliance schedule for development of pretreatment program);

- (12) Upon failure of the state to notify, as required by Section 402(b)(3) of the FWPCA, another state whose waters may be affected by a discharge permitted by this permit;
- (13) When required to correct technical mistakes, such as errors in calculation, or mistaken interpretations of law made in determining permit conditions; or
- (14) When requested by the permittee and the Director determines that the modification has cause and will not result in a violation of federal or state law, regulations or rules; or

#### 5. Termination

This permit may be terminated during its term for cause, including but not limited to, the following:

- a. Violation of any term or condition of this permit;
- b. The permittee's misrepresentation or failure to disclose fully all relevant facts in the permit application or during the permit issuance process or the permittee's misrepresentation of any relevant facts at any time;
- c. Materially false or inaccurate statements or information in the permit application or the permit;
- d. A change in any condition that requires either a temporary or permanent reduction or elimination of the permitted discharge;
- e. The permittee's discharge threatens human life or welfare or the maintenance of water quality standards;
- f. Permanent closure of the facility generating the wastewater permitted to be discharged by this permit or permanent cessation of wastewater discharge;
- g. New or revised requirements of any applicable standard or limitation that is promulgated under Sections 301(b)(2)(C), (D), (E), and (F), and 307(a)(2) of the FWPCA that the Director determines cannot be complied with by the permittee.
- h. Any other cause allowed by the ADEM Administrative Code, Chapter 335-6-6.

#### 6. Suspension

This permit may be suspended during its term for noncompliance until the permittee has taken action(s) necessary to achieve compliance.

#### 7. Stay

The filing of a request by the permittee for modification, suspension or revocation of this permit, in whole or in part, does not stay any permit term or condition.

### **F. COMPLIANCE WITH TOXIC POLLUTANT STANDARD OR PROHIBITION**

If any applicable effluent standard or prohibition (including any schedule of compliance specified in such effluent standard or prohibition) is established under Section 307(a) of the FWPCA, 33 U.S.C. Section 1317(a), for a toxic pollutant discharged by the permittee and such standard or prohibition is more stringent than any discharge limitation on the pollutant specified in Provision I. A. of this permit, or controls a pollutant not limited in Provision I. A. of this permit, this permit shall be modified to conform to the toxic pollutant effluent standard or prohibition and the permittee shall be notified of such modification. If this permit has not been modified to conform to the toxic pollutant effluent standard or prohibition before the effective date of such standard or prohibition, the permittee shall attain compliance with the requirements of the standard or prohibition within the time period required by the standard or prohibition and shall continue to comply with the standard or prohibition until this permit is modified or reissued.

### **G. NOTICE TO DIRECTOR OF INDUSTRIAL USERS**

1. The permittee shall not allow the introduction of wastewater, other than domestic wastewater, from a new direct discharger prior to approval and permitting, if applicable, of the discharge by the Department.
2. The permittee shall not allow an existing indirect discharger to increase the quantity or change the character of its wastewater, other than domestic wastewater, prior to approval and permitting, if applicable, of the increased discharge by the Department.

3. The permittee shall report to the Department any adverse impact caused or believed to be caused by an indirect discharger on the treatment process, quality of discharged water or quality of sludge. Such report shall be submitted within seven days of the permittee becoming aware of the adverse impacts.

#### **H. PROHIBITIONS**

The permittee shall not allow, and shall take effective enforcement action to prevent and terminate, the introduction of any of the following into its treatment works by industrial users:

1. Pollutants which create a fire or explosion hazard in the treatment works;
2. Pollutants which will cause corrosive structural damage to the treatment works, or dischargers with a pH lower than 5.0 s.u., unless the works are specifically designed to accommodate such discharges;
3. Solid or viscous pollutants in amounts which will cause obstruction of flow in sewers, or other interference with the treatment works;
4. Pollutants, including oxygen demanding pollutants, released in a discharge of such volume or strength as to cause interference in the treatment works;
5. Heat in amounts which will inhibit biological activity in the treatment plant resulting in interference or in such quantities that the temperature of the treatment plant influent exceeds 40°C (104° F) unless the treatment plant is designed to accommodate such heat;
6. Pollutants in amounts which exceed any applicable pretreatment standard under Section 307 of FWPCA or any approved revisions thereof.

## **PART III ADDITIONAL REQUIREMENTS, CONDITIONS, AND LIMITATIONS**

### **A. CIVIL AND CRIMINAL LIABILITY**

#### 1. Tampering

Any person who falsifies, tampers with, or knowingly renders inaccurate any monitoring device or method required to be maintained or performed under the permit shall, upon conviction, be subject to penalties as provided by the AWPCA.

#### 2. False Statements

Any person who knowingly makes any false statement, representation, or certification in any record or other document submitted or required to be maintained under this permit, including monitoring reports or reports of compliance or noncompliance shall, upon conviction, be subject to penalties as provided by the AWPCA.

#### 3. Permit Enforcement

a. Any NPDES permit issued or reissued by the Department is a permit for the purpose of the AWPCA and the FWPCA and as such any terms, conditions, or limitations of the permit are enforceable under state and federal law.

b. Any person required to have a NPDES permit pursuant to ADEM Administrative Code Chapter 335-6-6 and who discharges pollutants without said permit, who violates the conditions of said permit, who discharges pollutants in a manner not authorized by the permit, or who violates applicable orders of the Department or any applicable rule or standard of the Department, is subject to any one or combination of the following enforcement actions under applicable state statutes.

(1) An administrative order requiring abatement, compliance, mitigation, cessation, clean-up, and/or penalties;

(2) An action for damages;

(3) An action for injunctive relief; or

(4) An action for penalties.

c. If the permittee is not in compliance with the conditions of an expiring or expired permit the Director may choose to do any or all of the following provided the permittee has made a timely and complete application for reissuance of the permit:

(1) Initiate enforcement action based upon the permit which has been continued;

(2) Issue a notice of intent to deny the permit reissuance. If the permit is denied, the owner or operator would then be required to cease the activities authorized by the continued permit or be subject to enforcement action for operating without a permit;

(3) Reissue the new permit with appropriate conditions; or

(4) Take other actions authorized by these rules and AWPCA.

#### 4. Relief from Liability

Except as provided in Provision II. C. 1. (Bypass) and Provision II. C. 2. (Upset), nothing in this permit shall be construed to relieve the permittee of civil or criminal liability under the AWPCA or FWPCA for noncompliance with any term or condition of this permit.

### **B. OIL AND HAZARDOUS SUBSTANCE LIABILITY**

Nothing in this permit shall be construed to preclude the institution of any legal action or relieve the permittee from any responsibilities, liabilities or penalties to which the permittee is or may be subject under Section 311 of the FWPCA, 33 U.S.C. Section 1321.

**C. PROPERTY AND OTHER RIGHTS**

This permit does not convey any property rights in either real or personal property, or any exclusive privileges, nor does it authorize any injury to persons or property or invasion of other private rights, or any infringement of federal, state, or local laws or regulations, nor does it authorize or approve the construction of any physical structures or facilities or the undertaking of any work in any waters of the state or of the United States.

**D. AVAILABILITY OF REPORTS**

Except for data determined to be confidential under Code of Alabama 1975, Section 22-22-9(c), all reports prepared in accordance with the terms of this permit shall be available for public inspection at the offices of the Department. Effluent data shall not be considered confidential.

**E. EXPIRATION OF PERMITS FOR NEW OR INCREASED DISCHARGES**

1. If this permit was issued for a new discharger or new source, this permit shall expire eighteen months after the issuance date if construction of the facility has not begun during the eighteen-month period.
2. If this permit was issued or modified to allow the discharge of increased quantities of pollutants to accommodate the modification of an existing facility and if construction of this modification has not begun during the eighteen month period after issuance of this permit or permit modification, this permit shall be modified to reduce the quantities of pollutants allowed to be discharged to those levels that would have been allowed if the modification of the facility had not been planned.
3. Construction has begun when the owner or operator has:
  - a. Begun, or caused to begin as part of a continuous on-site construction program:
    - (1) Any placement, assembly, or installation of facilities or equipment; or
    - (2) Significant site preparation work including clearing, excavation, or removal of existing buildings, structures, or facilities which are necessary for the placement, assembly, or installation of new source facilities or equipment; or
  - b. Entered into a binding contractual obligation for the purpose of placement, assembly, or installation of facilities or equipment which are intended to be used in its operation within a reasonable time. Options to purchase or contracts which can be terminated or modified without substantial loss, and contracts for feasibility, engineering, and design studies do not constitute a contractual obligation under this paragraph.
4. Final plans and specifications for a waste treatment facility at a new source or new discharger, or a modification to an existing waste treatment facility must be submitted to and examined by the Department prior to initiating construction of such treatment facility by the permittee.
5. Upon completion of construction of waste treatment facilities and prior to operation of such facilities, the permittee shall submit to the Department a certification from a registered professional engineer, licensed to practice in the State of Alabama, that the treatment facilities have been built according to plans and specifications submitted to and examined by the Department.

**F. COMPLIANCE WITH WATER QUALITY STANDARDS**

1. On the basis of the permittee's application, plans, or other available information, the Department has determined that compliance with the terms and conditions of this permit should assure compliance with the applicable water quality standards.
2. Compliance with permit terms and conditions notwithstanding, if the permittee's discharge(s) from point sources identified in Provision I. A. of this permit cause or contribute to a condition in contravention of state water quality standards, the Department may require abatement action to be taken by the permittee in emergency situations or modify the permit pursuant to the Department's Rules, or both.
3. If the Department determines, on the basis of a notice provided pursuant to this permit or any investigation, inspection or sampling, that a modification of this permit is necessary to assure maintenance of water quality standards or compliance with other provisions of the AWPCA or FWPCA, the Department may require such modification and, in cases of emergency, the Director may prohibit the discharge until the permit has been modified.

## G. GROUNDWATER

Unless specifically authorized under this permit, this permit does not authorize the discharge of pollutants to groundwater. Should a threat of groundwater contamination occur, the Director may require groundwater monitoring to properly assess the degree of the problem, and the Director may require that the permittee undertake measures to abate any such discharge and/or contamination.

## H. DEFINITIONS

1. Average monthly discharge limitation – means the highest allowable average of "daily discharges" over a calendar month, calculated as the sum of all "daily discharges" measured during a calendar month divided by the number of "daily discharges" measured during that month (zero discharge days shall not be included in the number of "daily discharges" measured and a less than detectable test result shall be treated as a concentration of zero if the most sensitive EPA approved method was used).
2. Average weekly discharge limitation - means the highest allowable average of "daily discharges" over a calendar week, calculated as the sum of all "daily discharges" measured during a calendar week divided by the number of "daily discharges" measured during that week (zero discharge days shall not be included in the number of "daily discharges" measured and a less than detectable test result shall be treated as a concentration of zero if the most sensitive EPA approved method was used).
3. Arithmetic Mean – means the summation of the individual values of any set of values divided by the number of individual values.
4. AWPCA – means the Alabama Water Pollution Control Act.
5. BOD – means the five-day measure of the pollutant parameter biochemical oxygen demand.
6. Bypass – means the intentional diversion of waste streams from any portion of a treatment facility.
7. CBOD – means the five-day measure of the pollutant parameter carbonaceous biochemical oxygen demand.
8. Daily discharge – means the discharge of a pollutant measured during any consecutive 24-hour period in accordance with the sample type and analytical methodology specified by the discharge permit.
9. Daily maximum – means the highest value of any individual sample result obtained during a day.
10. Daily minimum – means the lowest value of any individual sample result obtained during a day.
11. Day – means any consecutive 24-hour period.
12. Department – means the Alabama Department of Environmental Management.
13. Director – means the Director of the Department.
14. Discharge – means "[t]he addition, introduction, leaking, spilling or emitting of any sewage, industrial waste, pollutant or other waste into waters of the state". Code of Alabama 1975, Section 22-22-1(b)(9).
15. Discharge Monitoring Report (DMR) – means the form approved by the Director to accomplish reporting requirements of an NPDES permit.
16. DO – means dissolved oxygen.
17. 8HC – means 8-hour composite sample, including any of the following:
  - a. The mixing of at least 8 equal volume samples collected at constant time intervals of not more than 1 hour over a period of not less than 8 hours between the hours of 6:00 a.m. and 6:00 p.m. If the sampling period exceeds 8 hours, sampling may be conducted beyond the 6:00 a.m. to 6:00 p.m. period.
  - b. A sample continuously collected at a constant rate over period of not less than 8 hours between the hours of 6:00 a.m. and 6:00 p.m. If the sampling period exceeds 8 hours, sampling may be conducted beyond the 6:00 a.m. to 6:00 p.m. period.
18. EPA – means the United States Environmental Protection Agency.
19. FC – means the pollutant parameter fecal coliform.

20. Flow – means the total volume of discharge in a 24-hour period.
21. FWPCA – means the Federal Water Pollution Control Act.
22. Geometric Mean – means the Nth root of the product of the individual values of any set of values where N is equal to the number of individual values. The geometric mean is equivalent to the antilog of the arithmetic mean of the logarithms of the individual values. For purposes of calculating the geometric mean, values of zero (0) shall be considered one (1).
23. Grab Sample – means a single influent or effluent portion which is not a composite sample. The sample(s) shall be collected at the period(s) most representative of the discharge.
24. Indirect Discharger – means a nondomestic discharger who discharges pollutants to a publicly owned treatment works or a privately owned treatment facility operated by another person.
25. Industrial User – means those industries identified in the Standard Industrial Classification manual, Bureau of the Budget 1967, as amended and supplemented, under the category “Division D – Manufacturing” and such other classes of significant waste producers as, by regulation, the Director deems appropriate.
26. MGD – means million gallons per day.
27. Monthly Average – means the arithmetic mean of all the composite or grab samples taken for the daily discharges collected in one month period. The monthly average for flow is the arithmetic mean of all flow measurements taken in a one month period.
28. New Discharger – means a person, owning or operating any building, structure, facility or installation:
  - a. From which there is or may be a discharge of pollutants;
  - b. From which the discharge of pollutants did not commence prior to August 13, 1979, and which is not a new source; and
  - c. Which has never received a final effective NPDES permit for dischargers at that site.
29. NH3-N – means the pollutant parameter ammonia, measured as nitrogen.
30. Notifiable sanitary sewer overflow – means an overflow, spill, release or diversion of wastewater from a sanitary sewer system that:
  - a. Reaches a surface water of the State; or
  - b. May imminently and substantially endanger human health based on potential for public exposure including but not limited to close proximity to public or private water supply wells or in areas where human contact would be likely to occur.
31. Permit application – means forms and additional information that is required by ADEM Administrative Code Rule 335-6-6-.08 and applicable permit fees.
32. Point source – means "any discernible, confined and discrete conveyance, including but not limited to any pipe, channel, ditch, tunnel, conduit, well, discrete fissure, container, rolling stock, concentrated animal feeding operation, or vessel or other floating craft, . . . from which pollutants are or may be discharged." Section 502(14) of the FWPCA, 33 U.S.C. Section 1362(14).
33. Pollutant – includes for purposes of this permit, but is not limited to, those pollutants specified in Code of Alabama 1975, Section 22-22-1(b)(3) and those effluent characteristics specified in Provision I. A. of this permit.
34. Privately Owned Treatment Works – means any devices or system which is used to treat wastes from any facility whose operator is not the operator of the treatment works, and which is not a “POTW”.
35. Publicly Owned Treatment Works – means a wastewater collection and treatment facility owned by the State, municipality, regional entity composed of two or more municipalities, or another entity created by the State or local authority for the purpose of collecting and treating municipal wastewater.
36. Receiving Stream – means the “waters” receiving a “discharge” from a “point source”.
37. Severe property damage – means substantial physical damage to property, damage to the treatment facilities which causes them to become inoperable, or substantial and permanent loss of natural resources

which can reasonably be expected to occur in the absence of a bypass. Severe property damage does not mean economic loss caused by delays in production.

38. Significant Source – means a source which discharges 0.025 MGD or more to a POTW or greater than five percent of the treatment work's capacity, or a source which is a primary industry as defined by the U.S. EPA or which discharges a priority or toxic pollutant.
39. TKN – means the pollutant parameter Total Kjeldahl Nitrogen.
40. TON – means the pollutant parameter Total Organic Nitrogen.
41. TRC – means Total Residual Chlorine.
42. TSS – means the pollutant parameter Total Suspended Solids.
43. 24HC – means 24-hour composite sample, including any of the following:
  - a. The mixing of at least 8 equal volume samples collected at constant time intervals of not more than 2 hours over a period of 24 hours;
  - b. A sample collected over a consecutive 24-hour period using an automatic sampler composite to one sample. As a minimum, samples shall be collected hourly and each shall be no more than one twenty-fourth (1/24) of the total sample volume collected; or
  - c. A sample collected over a consecutive 24-hour period using an automatic composite sampler composited proportional to flow.
44. Upset – means an exceptional incident in which there is an unintentional and temporary noncompliance with technology-based permit discharge limitations because of factors beyond the reasonable control of the Permittee. An upset does not include noncompliance to the extent caused by operational error, improperly designed treatment facilities, inadequate treatment facilities, lack of preventive maintenance, or careless or improper operation.
45. Waters – means "[a]ll waters of any river, stream, watercourse, pond, lake, coastal, ground, or surface water, wholly or partially within the state, natural or artificial. This does not include waters which are entirely confined and retained completely upon the property of a single individual, partnership, or corporation unless such waters are used in interstate commerce." Code of Alabama 1975, Section 22-22-1(b)(2). Waters "include all navigable waters" as defined in Section 502(7) of the FWPCA, 22 U.S.C. Section 1362(7), which are within the State of Alabama.
46. Week – means the period beginning at twelve midnight Saturday and ending at twelve midnight the following Saturday.
47. Weekly (7-day and calendar week) Average – is the arithmetic mean of all samples collected during a consecutive 7-day period or calendar week, whichever is applicable. The calendar week is defined as beginning on Sunday and ending on Saturday. Weekly averages shall be calculated for all calendar weeks with Saturdays in the month. If a calendar week overlaps two months (i.e., the Sunday is in one month and the Saturday in the following month), the weekly average calculated for the calendar week shall be included in the data for the month that contains the Saturday.

## **I. SEVERABILITY**

The provisions of this permit are severable, and if any provision of this permit or the application of any provision of this permit to any circumstance is held invalid, the application of such provision to other circumstances, and the remainder of this permit, shall not be affected thereby.

## **PART IV SPECIFIC REQUIREMENTS, CONDITIONS, AND LIMITATIONS**

### **A. SLUDGE MANAGEMENT PRACTICES**

1. Applicability
  - a. Provisions of Provision IV.A. apply to a sewage sludge generated or treated in treatment works that is applied to agricultural and non-agricultural land, or that is otherwise distributed, marketed, incinerated, or disposed in landfills or surface disposal sites.
  - b. Provisions of Provision IV.A. do not apply to:
    - (1) Sewage sludge generated or treated in a privately owned treatment works operated in conjunction with industrial manufacturing and processing facilities and which receive no domestic wastewater.
    - (2) Sewage sludge that is stored in surface impoundments located at the treatment works prior to ultimate disposal.
2. Submitting Information
  - a. If applicable, the permittee must submit annually with its Municipal Water Pollution Prevention (MWPP) report the following:
    - (1) Type of sludge stabilization/digestion method;
    - (2) Daily or annual sludge production (dry weight basis);
    - (3) Ultimate sludge disposal practice(s).
  - b. The permittee shall provide sludge inventory data to the Director as requested. These data may include, but are not limited to, sludge quantity and quality reported in Provision IV.A.2.a as well as other specific analyses required to comply with State and Federal laws regarding solid and hazardous waste disposal.
  - c. The permittee shall give prior notice to the Director of at least 30 days of any change planned in the permittee's sludge disposal practices.
3. Reopener or Modification
  - a. Upon review of information provided by the permittee as required by Provision IV.A.2. or, based on the results of an on-site inspection, the permit shall be subject to modification to incorporate appropriate requirements.
  - b. If an applicable "acceptable management practice" or if a numerical limitation for a pollutant in sewage sludge promulgated under Section 405 of FWPCA is more stringent than the sludge pollutant limit or acceptable management practice in this permit, this permit shall be modified or revoked or reissued to conform to requirements promulgated under Section 405. The permittee shall comply with the limitations no later than the compliance deadline specified in applicable regulations as required by Section 405 of FWPCA.

### **B. EFFLUENT TOXICITY TESTING REOPENER**

Upon notification under Part II.G. of any newly introduced toxic industrial wastewaters, the Director may reopen the permit to include effluent toxicity limitations and testing requirements.

### **C. TOTAL RESIDUAL CHLORINE (TRC) REQUIREMENTS**

1. If chlorine is not utilized for disinfection purposes, TRC monitoring under Part I of this Permit is not required. If TRC monitoring is not required, "NODI = 9" (conditional monitoring) should be reported on the DMR forms.
2. Testing for TRC shall be conducted according to either the amperometric titration method or the DPD colorimetric method as specified in Section 408(C) or (E), Standards Methods for the Examination of Water and Wastewater, 18th edition. If chlorine is not detected prior to actual discharge to the receiving

stream using one of these methods (i.e., the analytical result is less than the detection level), the Permittee shall report on the DMR form "NODI = B" or "0". The Permittee shall then be considered to be in compliance with the daily maximum concentration limit for TRC.

3. This permit contains a maximum allowable TRC level in the effluent. The Permittee is responsible for determining the minimum TRC level needed in the chlorine contact chamber to comply with E.coli limits. The effluent shall be dechlorinated if necessary to meet the maximum allowable effluent TRC level.
4. The sample collection point for effluent TRC shall be at a point downstream of the chlorine contact chamber (downstream of dechlorination if applicable). The exact location is to be approved by the Director.

#### **D. PLANT CLASSIFICATION**

The Permittee shall report to the Director within 30 days of the effective date of this permit, the name, address and operator number of the certified wastewater operator in responsible charge of the facility. Unless specified elsewhere in this permit, this facility shall be classified in accordance with ADEM Admin. Code R. 335-10-1-.03.

ALABAMA DEPARTMENT OF ENVIRONMENTAL MANAGEMENT  
 WATER DIVISION – INDUSTRIAL AND MUNICIPAL SECTIONS  
**NONCOMPLIANCE NOTIFICATION FORM**

PERMITTEE NAME: \_\_\_\_\_ PERMIT NO: \_\_\_\_\_

FACILITY LOCATION: \_\_\_\_\_

DMR REPORTING PERIOD: \_\_\_\_\_

1. DESCRIPTION OF DISCHARGE: (Include outfall number (s))

2. DESCRIPTION OF NON-COMPLIANCE: (Attach additional pages if necessary):

| <b>LIST EFFLUENT VIOLATIONS (If applicable)</b>               |                            |  |                              |
|---|----------------------------|--|------------------------------|
| Outfall Number (s)  | NONCOMPLIANCE PARAMETER(S) | Result Reported (Include units)                        | Permit Limit (Include units) |
|   |                            |  |                              |
|   |                            |  |                              |
|   |                            |  |                              |
|   |                            |  |                              |
| <b>LIST MONITORING / REPORTING VIOLATIONS (If applicable)</b> |                            |  |                              |
| Outfall Number (s)  | NONCOMPLIANCE PARAMETER(S) | Monitoring / Reporting Violation (Provide description) |                              |
|   |                            |  |                              |
|   |                            |  |                              |
|   |                            |  |                              |
|   |                            |  |                              |

3. CAUSE OF NON-COMPLIANCE (Attach additional pages if necessary):

4. PERIOD OF NONCOMPLIANCE: (Include exact date(s) and time(s) or, if not corrected, the anticipated time the noncompliance is expected to continue):

5. DESCRIPTION OF STEPS TAKEN AND/OR BEING TAKEN TO REDUCE OR ELIMINATE THE NONCOMPLYING DISCHARGE AND TO PREVENT ITS RECURRENCE (attach additional pages if necessary):

"I certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations."

\_\_\_\_\_  
 NAME AND TITLE OF RESPONSIBLE OFFICIAL (type or print)

\_\_\_\_\_  
 SIGNATURE OF RESPONSIBLE OFFICIAL / DATE SIGNED

## NPDES PERMIT RATIONALE

NPDES Permit No: **AL0048488** Date: 2/1/2016

Permit Applicant: Alabama Department of Conservation and Natural Resources  
201 McLean Drive  
Rogersville, Alabama 35652

Location: Joe Wheeler State Park South Lagoon  
24921 Alabama Highway 101  
Town Creek, Alabama 35672

Draft Permit is: Initial Issuance:  
Reissuance due to expiration: X  
Modification of existing permit:  
Revocation and Reissuance:

Basis for Limitations: Water Quality Model: CBOD, NH3-N  
Reissuance with no modification: pH, TSS, NH3-N, TRC, E. coli, CBOD,  
CBOD % Removal, TSS % Removal  
Instream calculation at 7Q10: 1%  
Toxicity based: TRC  
Secondary Treatment Levels: CBOD, NH3-N, CBOD % Removal  
Other (described below): TSS, TSS % Removal, pH, E. coli

Design Flow in Million Gallons per Day: 0.010

Major: No

Description of Discharge: Outfall Number 001; Effluent discharge to Tennessee River, which is classified as Swimming, Public Water Supply, and Fish & Wildlife.

Discussion: This is a reissuance due to expiration.

The limits for Five Day Carbonaceous Biochemical Oxygen Demand (CBOD) and Total Ammonia as Nitrogen (NH3-N) are based on the memo that was prepared by ADEM's Water Quality Branch on January 25, 2016. The monthly average limit for CBOD is 25.0 mg/L. The monthly average limit for NH3-N is 20.0 mg/L.

The monthly average TSS limit is 90 mg/L in accordance with 40 CFR Part 133.105. A minimum percent removal of 65 percent is imposed on TSS in accordance with 40 CFR Part 133.105. A minimum percent removal of 85 percent is imposed on CBOD in accordance with 40 CFR Part 133.102.

The imposed E. coli limits were determined based on the water-use classification of the receiving stream. Since the Tennessee River is classified as Swimming, Public Water Supply, and Fish & Wildlife, the more stringent limits for the Swimming classification apply. The monthly average E. coli limit is 126 col/100mL and the daily maximum E. coli limit is 235 col/100mL.

The pH limits were developed in accordance with the Water-Use designation of the receiving stream and to be consistent with the Department's permitting approach and procedures. The minimum pH limit of 6.0 S.U. and a maximum limit of 9.0 S.U. are imposed.

The Total Residual Chlorine (TRC) limit of 1.0 mg/L (maximum daily) is based on EPA's recommended water quality value and on the current Toxicity Rationale, which considers the available dilution and should be protective of acute and chronic criteria in the receiving stream. Monitoring for TRC is only applicable if chlorine is utilized for disinfection purposes. That is, if chlorine disinfection is not utilized, monitoring would not be applicable during the monitoring period, and "NODI=9" should be entered on the monthly DMR.

This permit imposes monitoring during the growing season (April-October) for the following nutrient-related parameters: Total Kjeldahl Nitrogen (TKN), Nitrite plus Nitrate as Nitrogen (NO<sub>2</sub>+NO<sub>3</sub>-N), and Total Phosphorus (TP). Monitoring for these nutrient-related parameters is imposed so that sufficient information will be available regarding the nutrient contribution from this point source, should it be necessary at some later time to impose nutrient limits on this discharge.

No toxicity testing is required because there are no industrial indirect discharges to the plant and because this is a minor facility.

Monitoring will be conducted once per month for most parameters. Percent removal for CBOD and TSS will be calculated once per month. Monitoring for nutrient-related parameters will be once per month during the growing season. Flow will be monitored instantaneously, once per month.

ADEM Administrative Rule 335-6-10-.04 requires applicants to new or expanded discharges to Tier II waters demonstrate that the proposed discharge is necessary for important economic or social development in the area in which the waters are located. The application submitted by the facility is not for a new or expanded discharge to a Tier II stream, so the applicant is not required to demonstrate that the discharge is necessary for economic and social development.

The discharge is within a 24 hour travel time to a segment of the Tennessee River, which is on the most recent 303(d) list for Nutrients. Until a final TMDL for Nutrients is developed for the Tennessee River, the limits imposed in this Permit are expected to be protective of the Tennessee River.

Prepared by: Nicholas Lowe

## TOXICITY AND DISINFECTION RATIONALE

|  |  |   |
|--|--|---|
| Facility Name:                                 | <b>Joe Wheeler State Park South Lagoon</b> |   |
| NPDES Permit Number:                           | <b>AL0048488</b>                           |   |
| Receiving Stream:                              | <b>Tennessee River</b>                     |   |
| Facility Design Flow (Q <sub>w</sub> ):        | <b>0.010 MGD</b>                           |   |
| Receiving Stream 7Q <sub>10</sub> :            | <b>6950.000 cfs</b>                        |   |
| Receiving Stream 1Q <sub>10</sub> :            | <b>5210.000 cfs</b>                        |   |
| Winter Headwater Flow (WHF):                   | <b>11640.00 cfs</b>                        |   |
| Summer Temperature for CCC:                    | <b>28 deg. Celsius</b>                     |   |
| Winter Temperature for CCC:                    | <b>28 deg. Celsius</b>                     |   |
| Headwater Background NH <sub>3</sub> -N Level: | <b>0.11 mg/l</b>                           |   |
| Receiving Stream pH:                           | <b>7.0 s.u.</b>                            |   |
| Headwater Background FC Level (summer):        | <b>N/A.</b>                                | <b>(Only applicable for facilities with diffusers.)</b> |
| (winter):                                      | <b>N/A.</b>                                |   |

The Stream Dilution Ratio (SDR) is calculated using the 7Q<sub>10</sub> for all stream classifications.

$$\text{Stream Dilution Ratio (SDR)} = \frac{Q_w}{7Q_{10} + Q_w} = 0.0002\%$$

### AMMONIA TOXICITY LIMITATIONS

Toxicity-based ammonia limits are calculated in accordance with the *Ammonia Toxicity Protocol* and the *General Guidance for Writing Water Quality Based Toxicity Permits*.

If the Limiting Dilution is less than 1%, the waterbody is considered stream-dominated and the CMC applies.

If the Limiting Dilution is greater than 1%, the waterbody is considered effluent-dominated and the CCC applies.

$$\begin{aligned} \text{Limiting Dilution} &= \frac{Q_w}{7Q_{10} + Q_w} \\ &= 0.00\% \qquad \qquad \qquad \text{Stream-Dominated, CMC Applies} \end{aligned}$$

$$\begin{aligned} \text{Criterion Maximum Concentration (CMC):} & \quad \text{CMC} = 0.411 / (1 + 10^{(7.204 - \text{pH})}) + 58.4 / (1 + 10^{(\text{pH} - 7.204)}) \\ \text{Criterion Continuous Concentration (CCC):} & \quad \text{CCC} = [0.0577 / (1 + 10^{(7.688 - \text{pH})}) + 2.487 / (1 + 10^{(\text{pH} - 7.688)})] * \text{Min}[2.85, 1.45 * 10^{(0.028 * (25 - T))}] \end{aligned}$$

|   |                   |                  |
|---|-------------------|------------------|
|   | <u>CMC</u>        | <u>CCC</u>       |
| Allowable Summer Instream NH <sub>3</sub> -N: | <b>36.09 mg/l</b> | <b>2.48 mg/l</b> |
| Allowable Winter Instream NH <sub>3</sub> -N: | <b>36.09 mg/l</b> | <b>2.48 mg/l</b> |

$$\begin{aligned} \text{Summer NH}_3\text{-N Toxicity Limit} &= \frac{[(\text{Allowable Instream NH}_3\text{-N}) * (7Q_{10} + Q_w)] - [(\text{Headwater NH}_3\text{-N}) * (7Q_{10})]}{Q_w} \\ &= 16163120.4 \text{ mg/l NH}_3\text{-N at 7Q}_{10} \end{aligned}$$

$$\begin{aligned} \text{Winter NH}_3\text{-N Toxicity Limit} &= \frac{[(\text{Allowable Instream NH}_3\text{-N}) * (\text{WHF} + Q_w)] - [(\text{Headwater NH}_3\text{-N}) * (\text{WHF})]}{Q_w} \\ &= \text{N/A.} \end{aligned}$$

The ammonia limits established in the permit will be the lesser of the DO-based ammonia limit (from the wasteload allocation model) or the toxicity limits calculated above.

|        |  |  |
|--------|--|--|
|        | <u>DO-based NH<sub>3</sub>-N limit</u> | <u>Toxicity-based NH<sub>3</sub>-N limit</u> |
| Summer | <b>20.00 mg/l NH<sub>3</sub>-N</b>     | <b>16163120.40 mg/l NH<sub>3</sub>-N</b>     |
| Winter | <b>N/A.</b>                            | <b>N/A.</b>                                  |

**Summer: The DO based limit of 20.00 mg/l NH<sub>3</sub>-N applies.**  
**Winter limits are not applicable.**

**TOXICITY TESTING REQUIREMENTS (REFERENCE: MUNICIPAL BRANCH TOXICITY PERMITTING STRATEGY)**

The following factors trigger toxicity testing requirements:

1. Facility design flow is equal to or greater than 1.0 MGD (major facility).
2. There are significant industrial contributors (SID permits).

Acute toxicity testing is specified for A&I receiving streams, or for stream dilution ratios of 1% or less. Chronic toxicity testing is specified for all other situations requiring toxicity testing.

**This is a minor facility (Qw < 1.0 MGD) with no SID permits. No toxicity testing is required.**

$$\text{Instream Waste Concentration (IWC)} = \frac{Q_w}{1Q_{10} + Q_w} = 0.0003\% \quad \text{Note: This number will be rounded up for toxicity testing purposes.}$$

**DISINFECTION REQUIREMENTS**

Bacteria limits are required, and will be the water quality limit for the receiving stream, except where diffusers are used the limit may be adjusted for the dilution provided by the diffuser.

See the attached Disinfection Guidance for applicable stream standards.

**(Non-coastal limits apply)**

Applicable Stream Classification: **Public Water Supply, Swimming, Fish & Wildlife**

Disinfection Type: **Chlorination**

Limit calculation method: **Limits based on meeting stream standards at the point of discharge.**

|   | Stream Standard<br>(colonies/100ml) | Effluent Limit<br>(colonies/100ml) |
|---|-------------------------------------|------------------------------------|
| <b><u>E. Coli (applies to Non-coastal and Shellfish Harvesting Coastal)</u></b> |                                     |                                    |
| Monthly limit as monthly average (October through May):                         | 126                                 | <b>126</b>                         |
| Monthly limit as monthly average (June through September):                      | 126                                 | <b>126</b>                         |
| Daily Max (October through May):  | 235                                 | <b>235</b>                         |
| Daily Max (June through September):   | 235                                 | <b>235</b>                         |
| <b><u>Enterococci (applies to Coastal)</u></b>                                  |                                     |                                    |
| Monthly limit as geometric mean (October through May):                          | Not applicable                      | <b>Not applicable</b>              |
| Monthly limit as geometric mean (June through September):                       | Not applicable                      | <b>Not applicable</b>              |
| Daily Max (October through May):  | Not applicable                      | <b>Not applicable</b>              |
| Daily Max (June through September):   | Not applicable                      | <b>Not applicable</b>              |

**MAXIMUM ALLOWABLE CHLORINATION LIMITS**

Toxicity-based chlorine limits are calculated in accordance with the General Guidance for Writing Water Quality Based Toxicity Permits.

Chlorine has been shown to be acutely toxic at 0.019 mg/l and chronically toxic at 0.011 mg/l.

|                                    |                         |               |
|------------------------------------|-------------------------|---------------|
| Maximum allowable TRC in effluent: | 4941.099 mg/l (chronic) | (0.011)/(SDR) |
| Maximum allowable TRC in effluent: | 8534.626 mg/l (acute)   | (0.019)/(SDR) |

NOTE: A maximum chlorine limit will be imposed such that the instream concentration will not exceed acutely toxic concentrations in A & I streams and chronically toxic concentrations in all other streams, but may not exceed 1.0 mg/l.

Prepared By: Nicholas Lowe Date: 2/8/2016

# Waste Load Allocation Summary

Page 1

## REQUEST INFORMATION

request number: 3298

|                      |                 |   |                                     |  |     |
|----------------------|-----------------|---|-------------------------------------|--|-----|
| From:                | Nicholas Lowe   | In Branch/Section                                 | Municipal                           |  |     |
| Date Submitted       | 1/25/2016       | Date Required                                     | 1/27/2016                           | FUND Code                                | 605 |
| Receiving Waterbody  | Tennessee River | Date Permit application received by NPDES program | 5/6/2015                            |  |     |
| Previous Stream Name |                 | Facility Name                                     | Joe Wheeler State Park South Lagoon | (Name of Discharger-WQ will use to file) |     |
|                      |                 | Previous Discharger Name                          |                                     |  |     |
| River Basin          | Tennessee       | Outfall Latitude                                  | 34.79648                            | (decimal degrees)                        |     |
| *County              | Lawrence        | Outfall Longitude                                 | -87.38557                           | (decimal degrees)                        |     |
| Permit Number        | AL0048488       | Permit Type                                       | Permit Reissuance                   |  |     |
|                      |                 | Permit Status                                     | Active                              |  |     |
|                      |                 | Type of Discharger                                | MUNICIPAL                           |  |     |

Do other discharges exist that may impact the model?  Yes  No

If yes, impacting dischargers names.

Impacting dischargers permit numbers.

Existing Discharge Design Flow 0.01 MGD

Proposed Discharge Design Flow MGD

Note: The flow rates given should be those requested for modeling.

Comments included

Yes  No

Information Verified By REC

Year File Was Created 2004

Lat/Long Method Arcview

12 Digit HUC Code 060300050801

Use Classification PWS / S / F&W

Site Visit Completed?  Yes  No

Waterbody Impaired?  Yes  No

Antidegradation  Yes  No

Waterbody Tier Level Tier II

Use Support Category 1

Date of Site Visit

Date of WLA Response 1/25/2016

Approved TMDL?

Yes  No

Approval Date of TMDL

## Waste Load Allocation Information

Modeled Reach Length Miles

Date of Allocation

Name of Model Used

Allocation Type

Model Completed by

Type of Model Used

Allocation Developed by

# Waste Load Allocation Summary

| Annual Effluent Limits | Conventional Parameters |     |         |     | Other Parameters |     |         |     |
|------------------------|-------------------------|-----|---------|-----|------------------|-----|---------|-----|
|                        | Qw                      | MGD | Qw      | MGD | Qw               | MGD | Qw      | MGD |
| Season                 |                         |     | Season  |     | Season           |     | Season  |     |
| From                   |                         |     | From    |     | From             |     | From    |     |
| Through                |                         |     | Through |     | Through          |     | Through |     |
| CBOD5                  | 25                      |     | CBOD5   |     | TP               |     | TP      |     |
| NH3-N                  | 20                      |     | NH3-N   |     | TN               |     | TN      |     |
| TKN                    |                         |     | TKN     |     | TSS              |     | TSS     |     |
| D.O.                   |                         |     | D.O.    |     |                  |     |         |     |

| "Monitor Only" Parameters for Effluent: |  | Parameter | Frequency         | Parameter | Frequency |
|---|--|-----------|-------------------|-----------|-----------|
|   |  | TP        | Monthly (Apr-Oct) | DO        | Monthly   |
|   |  | TKN       | Monthly (Apr-Oct) |           |           |
|   |  | NO2+NO3-N | Monthly (Apr-Oct) |           |           |

| Water Quality Characteristics Immediately Upstream of Discharge |        |      |      |        |      |      |
|---|--------|------|------|--------|------|------|
| Parameter   | Summer |      |      | Winter |      |      |
|   | CBODu  |      | mg/l |        |      | mg/l |
| NH3-N   |        | mg/l |      |        | mg/l |      |
| Temperature   |        | °C   |      |        | °C   |      |
| pH  |        | su   |      |        | su   |      |

### Hydrology at Discharge Location

**Drainage Area Qualifier**  
Exact

|                |       |       |
|----------------|-------|-------|
| Drainage Area  | 29590 | sq mi |
| Stream 7Q10    | 6590  | cfs   |
| Stream 1Q10    | 5210  | cfs   |
| Stream 7Q2     | 11640 | cfs   |
| Annual Average | 48120 | cfs   |

| Method Used to Calculate      |
|-------------------------------|
| ADEM Estimate w/TVA Gage Data |

**Comments and/or Notations**

See MEMO dated 1/25/16.

LANCE R. LEFLEUR  
DIRECTOR



ROBERT J. BENTLEY  
GOVERNOR

Alabama Department of Environmental Management  
adem.alabama.gov

1400 Coliseum Blvd. 36110-2400 ■ Post Office Box 301463  
Montgomery, Alabama 36130-1463  
(334) 271-7700 ■ FAX (334) 271-7950

Monday January 25, 2016

**MEMORANDUM**

TO: Nicholas Lowe  
Municipal Branch

FROM: Ross Caton  
Water Quality Branch

RE: Tennessee River Permit Renewal – Joe Wheeler State Park South Lagoon

The Water Quality Branch has completed its annual wasteload allocation (WLA) for the Joe Wheeler State Park South Lagoon discharge to the Tennessee River/Wilson Lake in Lawrence County at a flow rate of 0.01 MGD. A water quality model for this portion of the Tennessee River is not required at this time. Based on best professional judgment, it is not expected that the discharge of 0.01 MGD will have a negative effect on the instream water quality. It is recommended that the permit be re-issued with secondary limits and with the following monitoring requirements:

- Monthly - Dissolved Oxygen
- Monthly (April-October) - TKN, TP, and NO<sub>2</sub>-NO<sub>3</sub>-N

| PARAMETER          | ANNUAL LIMIT |
|--------------------|--------------|
| Flow               | 0.01 MGD     |
| CBOD <sub>5</sub>  | 25.0 mg/L    |
| NH <sub>3</sub> -N | 20.0 mg/L    |

The following are the estimated low flows at the point of discharge:

|            |           |
|------------|-----------|
| 7Q10       | 6950 cfs  |
| 7Q2        | 11640 cfs |
| 1Q10       | 5210 cfs  |
| Annual Avg | 48120 cfs |

REC:rec

Facility: Joe Wheeler State Park South Lagoon  
Permit #: AL0048488  
Receiving Waterbody: *Tennessee River – Tennessee River Basin*  
County: *Lawrence*  
Date Completed: 1/25/16  
Performed by: *REC, Water Quality*

**Birmingham Branch**  
110 Vulcan Road  
Birmingham, AL 35209-4702  
(205) 942-6168  
(205) 941-1603 (FAX)

**Decatur Branch**  
2715 Sandlin Road, S.W.  
Decatur, AL 35603-1333  
(256) 353-1713  
(256) 340-9359 (FAX)



**Mobile Branch**  
2204 Perimeter Road  
Mobile, AL 36615-1131  
(251) 450-3400  
(251) 479-2593 (FAX)

**Mobile-Coastal**  
4171 Commanders Drive  
Mobile, AL 36615-1421  
(251) 432-6533  
(251) 432-6598 (FAX)



CONTINUED FROM THE FRONT

| VII. SIC CODES (4-digit, in order of priority) |   |           |             |
|--|---|-----------|-------------|
| A. FIRST                                       |   | B. SECOND |             |
| C  | 7 7999 (specify) Amusement & Recreation Service, Not elsewhere classified | C         | 7 (specify) |
| 15   | 16 19   | 15        | 16 19       |
| C. THIRD                                       |   | D. FOURTH |             |
| C  | 7 (specify)   | C         | 7 (specify) |
| 15   | 16 19   | 15        | 16 19       |

| VIII. OPERATOR INFORMATION   |   |
|--|---|
| A. NAME  | B. Is the name listed in Item VIII-A also the owner?<br><input checked="" type="checkbox"/> YES <input type="checkbox"/> NO |
| 8 State of Alabama, Department of Conservation and Natural Resources |   |
| 15 16  | 55 66   |

| C. STATUS OF OPERATOR (Enter the appropriate letter into the answer box: if "Other," specify.) |   | D. PHONE (area code & no.) |
|--|---|----------------------------|
| F = FEDERAL<br>S = STATE<br>P = PRIVATE  | M = PUBLIC (other than federal or state)<br>O = OTHER (specify) | A (256) 247-5466           |
| S  |   | 15 16 18 19 21 22 26       |

| E. STREET OR P.O. BOX |
|-----------------------|
| 201 McLean Drive      |
| 26                    |

| F. CITY OR TOWN | G. STATE | H. ZIP CODE | IX. INDIAN LAND<br>Is the facility located on Indian lands?<br><input type="checkbox"/> YES <input checked="" type="checkbox"/> NO |
|-----------------|----------|-------------|--|
| B Rogersville   | AL       | 35652       |  |
| 15 16           | 40 41    | 42 47 51    | 52   |

| X. EXISTING ENVIRONMENTAL PERMITS        |             |  |             |
|--|-------------|--|-------------|
| A. NPDES (Discharges to Surface Water)   |             | D. PSD (Air Emissions from Proposed Sources) |             |
| C  | T I         | C  | T I         |
| 9  | N AL0048488 | 9  | P           |
| 15                                       | 16 17 18 30 | 15   | 16 17 18 30 |
| B. UIC (Underground Injection of Fluids) |             | E. OTHER (specify)                           |             |
| C  | T I         | (specify)                                    |             |
| 9  | U           | 9  |             |
| 15                                       | 16 17 18 30 | 15 16 17 18 30                               |             |
| C. RCRA (Hazardous Wastes)               |             | E. OTHER (specify)                           |             |
| C  | T I         | (specify)                                    |             |
| 9  | R           | 9  |             |
| 15                                       | 16 17 18 30 | 15 16 17 18 30                               |             |

XI. MAP  
Attach to this application a topographic map of the area extending to at least one mile beyond property boundaries. The map must show the outline of the facility, the location of each of its existing and proposed intake and discharge structures, each of its hazardous waste treatment, storage, or disposal facilities, and each well where it injects fluids underground. Include all springs, rivers, and other surface water bodies in the map area. See instructions for precise requirements.

XII. NATURE OF BUSINESS (provide a brief description)  
Joe Wheeler State Park Facility

XIII. CERTIFICATION (see instructions)  
I certify under penalty of law that I have personally examined and am familiar with the information submitted in this application and all attachments and that, based on my inquiry of those persons immediately responsible for obtaining the information contained in the application, I believe that the information is true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment.

| A. NAME & OFFICIAL TITLE (type or print) | B. SIGNATURE | C. DATE SIGNED |
|--|--------------|----------------|
| Jim Haney Park Superintendent            |              | 01/23/15       |

| COMMENTS FOR OFFICIAL USE ONLY |
|--------------------------------|
| C                              |
| C                              |
| 15 16                          |

FACILITY NAME AND PERMIT NUMBER:

Form Approved 1/14/99  
OMB Number 2040-0086

FORM  
2A  
NPDES

## NPDES FORM 2A APPLICATION OVERVIEW

### APPLICATION OVERVIEW

Form 2A has been developed in a modular format and consists of a "Basic Application Information" packet and a "Supplemental Application Information" packet. The Basic Application Information packet is divided into two parts. All applicants must complete Parts A and C. Applicants with a design flow greater than or equal to 0.1 mgd must also complete Part B. Some applicants must also complete the Supplemental Application Information packet. The following items explain which parts of Form 2A you must complete.


#### BASIC APPLICATION INFORMATION:

- A. **Basic Application Information for all Applicants.** All applicants must complete questions A.1 through A.8. A treatment works that discharges effluent to surface waters of the United States must also answer questions A.9 through A.12.
- B. **Additional Application Information for Applicants with a Design Flow  $\geq$  0.1 mgd.** All treatment works that have design flows greater than or equal to 0.1 million gallons per day must complete questions B.1 through B.6.
- C. **Certification.** All applicants must complete Part C (Certification).

#### SUPPLEMENTAL APPLICATION INFORMATION:

- D. **Expanded Effluent Testing Data.** A treatment works that discharges effluent to surface waters of the United States and meets one or more of the following criteria must complete Part D (Expanded Effluent Testing Data):
  - 1. Has a design flow rate greater than or equal to 1 mgd,
  - 2. Is required to have a pretreatment program (or has one in place), or
  - 3. Is otherwise required by the permitting authority to provide the information.
- E. **Toxicity Testing Data.** A treatment works that meets one or more of the following criteria must complete Part E (Toxicity Testing Data):
  - 1. Has a design flow rate greater than or equal to 1 mgd,
  - 2. Is required to have a pretreatment program (or has one in place), or
  - 3. Is otherwise required by the permitting authority to submit results of toxicity testing.
- F. **Industrial User Discharges and RCRA/CERCLA Wastes.** A treatment works that accepts process wastewater from any significant industrial users (SIUs) or receives RCRA or CERCLA wastes must complete Part F (Industrial User Discharges and RCRA/CERCLA Wastes). SIUs are defined as:
  - 1. All industrial users subject to Categorical Pretreatment Standards under 40 Code of Federal Regulations (CFR) 403.6 and 40 CFR Chapter I, Subchapter N (see instructions); and
  - 2. Any other industrial user that:
    - a. Discharges an average of 25,000 gallons per day or more of process wastewater to the treatment works (with certain exclusions); or
    - b. Contributes a process wastestream that makes up 5 percent or more of the average dry weather hydraulic or organic capacity of the treatment plant; or
    - c. Is designated as an SIU by the control authority.
- G. **Combined Sewer Systems.** A treatment works that has a combined sewer system must complete Part G (Combined Sewer Systems).

**ALL APPLICANTS MUST COMPLETE PART C (CERTIFICATION)**



FACILITY NAME AND PERMIT NUMBER:

Form Approved 1/14/99  
OMB Number 2040-0086

### BASIC APPLICATION INFORMATION

#### PART A. BASIC APPLICATION INFORMATION FOR ALL APPLICANTS:

All treatment works must complete questions A.1 through A.8 of this Basic Application Information packet.

##### A.1. Facility Information.

Facility name Joe wheeler State Park South Lagoon

Mailing Address 201 McLean Drive Rogersville, AL 35652

Contact person Tim Haney

Title Park Superintendant

Telephone number (256) 247-5466

Facility Address 24921 Alabama Highway 101 Town Creek, AL 35672  
(not P.O. Box)

##### A.2. Applicant Information. If the applicant is different from the above, provide the following:

Applicant name \_\_\_\_\_

Mailing Address \_\_\_\_\_

Contact person \_\_\_\_\_

Title \_\_\_\_\_

Telephone number \_\_\_\_\_

Is the applicant the owner or operator (or both) of the treatment works?

owner       operator

Indicate whether correspondence regarding this permit should be directed to the facility or the applicant.

facility       applicant

##### A.3. Existing Environmental Permits. Provide the permit number of any existing environmental permits that have been issued to the treatment works (include state-issued permits).

NPDES AL0048488 PSD \_\_\_\_\_

UIC \_\_\_\_\_ Other \_\_\_\_\_

RCRA \_\_\_\_\_ Other \_\_\_\_\_

##### A.4. Collection System Information. Provide information on municipalities and areas served by the facility. Provide the name and population of each entity and, if known, provide information on the type of collection system (combined vs. separate) and its ownership (municipal, private, etc.).

| Name                               | Population Served           | Type of Collection System | Ownership    |
|------------------------------------|-----------------------------|---------------------------|--------------|
| <u>South Side Lagoon</u>           | <u>29 Cabins, Restroo</u>   | <u>gravity sewer</u>      | <u>State</u> |
| _____                              | <u>in dam, &amp; public</u> | _____                     | _____        |
| _____                              | <u>restrooms</u>            | _____                     | _____        |
| Total population served <u>N/A</u> |                             |                           |              |

**A.5. Indian Country.**

a. Is the treatment works located in Indian Country?

Yes  No

b. Does the treatment works discharge to a receiving water that is either in Indian Country or that is upstream from (and eventually flows through) Indian Country?

Yes  No

**A.6. Flow.** Indicate the design flow rate of the treatment plant (i.e., the wastewater flow rate that the plant was built to handle). Also provide the average daily flow rate and maximum daily flow rate for each of the last three years. Each year's data must be based on a 12-month time period with the 12th month of "this year" occurring no more than three months prior to this application submittal.

a. Design flow rate 0.010 mgd

|                                   | <u>Two Years Ago</u> | <u>Last Year</u> | <u>This Year</u> |
|-----------------------------------|----------------------|------------------|------------------|
| b. Annual average daily flow rate | <u>0.000</u>         | <u>0.000</u>     | <u>0.000</u> mgd |
| c. Maximum daily flow rate        | <u>0.000</u>         | <u>0.000</u>     | <u>0.000</u> mgd |

**A.7. Collection System.** Indicate the type(s) of collection system(s) used by the treatment plant. Check all that apply. Also estimate the percent contribution (by miles) of each.

Separate sanitary sewer 100.00 %  
 Combined storm and sanitary sewer \_\_\_\_\_ %

**A.8. Discharges and Other Disposal Methods.**

a. Does the treatment works discharge effluent to waters of the U.S.?  Yes  No

If yes, list how many of each of the following types of discharge points the treatment works uses:

- i. Discharges of treated effluent \_\_\_\_\_
- ii. Discharges of untreated or partially treated effluent \_\_\_\_\_
- iii. Combined sewer overflow points \_\_\_\_\_
- iv. Constructed emergency overflows (prior to the headworks) \_\_\_\_\_
- v. Other \_\_\_\_\_

b. Does the treatment works discharge effluent to basins, ponds, or other surface impoundments that do not have outlets for discharge to waters of the U.S.?  Yes  No

If yes, provide the following for each surface impoundment:

Location: \_\_\_\_\_  
 Annual average daily volume discharged to surface impoundment(s) \_\_\_\_\_ mgd  
 Is discharge  continuous or  intermittent?

c. Does the treatment works land-apply treated wastewater?  Yes  No

If yes, provide the following for each land application site:

Location: \_\_\_\_\_  
 Number of acres: \_\_\_\_\_  
 Annual average daily volume applied to site: \_\_\_\_\_ Mgd  
 Is land application  continuous or  intermittent?

d. Does the treatment works discharge or transport treated or untreated wastewater to another treatment works?  Yes  No

FACILITY NAME AND PERMIT NUMBER:

Form Approved 1/14/99  
OMB Number 2040-0086

If yes, describe the mean(s) by which the wastewater from the treatment works is discharged or transported to the other treatment works (e.g., tank truck, pipe).

If transport is by a party other than the applicant, provide:

Transporter name: \_\_\_\_\_

Mailing Address: \_\_\_\_\_

Contact person: \_\_\_\_\_

Title: \_\_\_\_\_

Telephone number: \_\_\_\_\_

For each treatment works that receives this discharge, provide the following:

Name: \_\_\_\_\_

Mailing Address: \_\_\_\_\_

Contact person: \_\_\_\_\_

Title: \_\_\_\_\_

Telephone number: \_\_\_\_\_

If known, provide the NPDES permit number of the treatment works that receives this discharge. \_\_\_\_\_

Provide the average daily flow rate from the treatment works into the receiving facility. \_\_\_\_\_ mgd

- e. Does the treatment works discharge or dispose of its wastewater in a manner not included in A.8.a through A.8.d above (e.g., underground percolation, well injection)? \_\_\_\_\_ Yes  No

If yes, provide the following for each disposal method:

Description of method (including location and size of site(s) if applicable):

Annual daily volume disposed of by this method: \_\_\_\_\_

Is disposal through this method \_\_\_\_\_ continuous or \_\_\_\_\_ intermittent?

FACILITY NAME AND PERMIT NUMBER:

Form Approved 1/14/99  
OMB Number 2040-0086

**WASTEWATER DISCHARGES:**

If you answered "yes" to question A.8.a, complete questions A.9 through A.12 once for each outfall (including bypass points) through which effluent is discharged. Do not include information on combined sewer overflows in this section. If you answered "no" to question A.8.a, go to Part B, "Additional Application Information for Applicants with a Design Flow Greater than or Equal to 0.1 mgd."

**A.9. Description of Outfall.**

- a. Outfall number 001
- b. Location Town Creek 35672  
(City or town, if applicable) (Zip Code)  
Lawrence AL  
(County) (State)  
34°47'32.78" N 87°22'56.81" W  
(Latitude) (Longitude)
- c. Distance from shore (if applicable) \_\_\_\_\_ ft.
- d. Depth below surface (if applicable) \_\_\_\_\_ ft.
- e. Average daily flow rate \_\_\_\_\_ mgd
- f. Does this outfall have either an intermittent or a periodic discharge? \_\_\_\_\_ Yes  No (go to A.9.g.)
- If yes, provide the following information:
- Number of times per year discharge occurs: \_\_\_\_\_
- Average duration of each discharge: \_\_\_\_\_
- Average flow per discharge: \_\_\_\_\_ mgd
- Months in which discharge occurs: \_\_\_\_\_
- g. Is outfall equipped with a diffuser? \_\_\_\_\_ Yes \_\_\_\_\_ No

**A.10. Description of Receiving Waters.**

- a. Name of receiving water Tennessee River Wilson Lake
- b. Name of watershed (if known) \_\_\_\_\_
- United States Soil Conservation Service 14-digit watershed code (if known): \_\_\_\_\_
- c. Name of State Management/River Basin (if known): \_\_\_\_\_
- United States Geological Survey 8-digit hydrologic cataloging unit code (if known): \_\_\_\_\_
- d. Critical low flow of receiving stream (if applicable):  
acute \_\_\_\_\_ cfs chronic \_\_\_\_\_ cfs
- e. Total hardness of receiving stream at critical low flow (if applicable): \_\_\_\_\_ mg/l of CaCO<sub>3</sub>

FACILITY NAME AND PERMIT NUMBER:

Form Approved 1/14/99  
OMB Number 2040-0086

ALDCNR Joe Wheeler Park AL0048488

A.11. Description of Treatment SOUTHside LAGOON

a. What levels of treatment are provided? Check all that apply.

Primary  Secondary  
 Advanced  Other. Describe: \_\_\_\_\_

b. Indicate the following removal rates (as applicable):

Design BOD<sub>5</sub> removal or Design CBOD<sub>5</sub> removal 85 %  
Design SS removal 65 %  
Design P removal N/A %  
Design N removal N/A %  
Other \_\_\_\_\_ %

c. What type of disinfection is used for the effluent from this outfall? If disinfection varies by season, please describe.

N/A

If disinfection is by chlorination, is dechlorination used for this outfall?  Yes  No

d. Does the treatment plant have post aeration?  Yes  No

A.12. Effluent Testing Information. All Applicants that discharge to waters of the US must provide effluent testing data for the following parameters. Provide the indicated effluent testing required by the **permitting authority for each outfall through which effluent is discharged**. Do not include information on combined sewer overflows in this section. All information reported must be based on data collected through analysis conducted using 40 CFR Part 136 methods. In addition, this data must comply with QA/QC requirements of 40 CFR Part 136 and other appropriate QA/QC requirements for standard methods for analytes not addressed by 40 CFR Part 136. At a minimum, effluent testing data must be based on at least three samples and must be no more than four and one-half years apart.

Outfall number: 0-011


| PARAMETER            | MAXIMUM DAILY VALUE |       | AVERAGE DAILY VALUE |       |                   |
|----------------------|---------------------|-------|---------------------|-------|-------------------|
|                      | Value               | Units | Value               | Units | Number of Samples |
| pH (Minimum)         | <u>N/A</u>          | s.u.  |                     |       |                   |
| pH (Maximum)         | <u>N/A</u>          | s.u.  |                     |       |                   |
| Flow Rate            | <u>N/A</u>          |       |                     |       |                   |
| Temperature (Winter) | <u>N/A</u>          |       |                     |       |                   |
| Temperature (Summer) | <u>N/A</u>          |       |                     |       |                   |

\* For pH please report a minimum and a maximum daily value

| POLLUTANT | MAXIMUM DAILY DISCHARGE |       | AVERAGE DAILY DISCHARGE |       |                   | ANALYTICAL METHOD | ML / MDL |
|-----------|-------------------------|-------|-------------------------|-------|-------------------|-------------------|----------|
|           | Conc.                   | Units | Conc.                   | Units | Number of Samples |                   |          |
|           |                         |       |                         |       |                   |                   |          |

CONVENTIONAL AND NONCONVENTIONAL COMPOUNDS.

|  |        |            |  |  |  |  |  |
|--|--------|------------|--|--|--|--|--|
| BIOCHEMICAL OXYGEN DEMAND (Report one) | BOD-5  | <u>N/A</u> |  |  |  |  |  |
|  | CBOD-5 | <u>N/A</u> |  |  |  |  |  |
| FECAL COLIFORM                         |        | <u>N/A</u> |  |  |  |  |  |
| TOTAL SUSPENDED SOLIDS (TSS)           |        | <u>N/A</u> |  |  |  |  |  |



END OF PART A.  
REFER TO THE APPLICATION OVERVIEW TO DETERMINE WHICH OTHER PARTS OF FORM 2A YOU MUST COMPLETE

FACILITY NAME AND PERMIT NUMBER:

Form Approved 1/14/99  
OMB Number 2040-0086

## BASIC APPLICATION INFORMATION

### PART B. ADDITIONAL APPLICATION INFORMATION FOR APPLICANTS WITH A DESIGN FLOW GREATER THAN OR EQUAL TO 0.1 MGD (100,000 gallons per day).

All applicants with a design flow rate  $\geq$  0.1 mgd must answer questions B.1 through B.6. All others go to Part C (Certification).

**B.1. Inflow and Infiltration.** Estimate the average number of gallons per day that flow into the treatment works from inflow and/or infiltration.  
\_\_\_\_\_gpd

Briefly explain any steps underway or planned to minimize inflow and infiltration.

\_\_\_\_\_  
\_\_\_\_\_

**B.2. Topographic Map.** Attach to this application a topographic map of the area extending at least one mile beyond facility property boundaries. This map must show the outline of the facility and the following information. (You may submit more than one map if one map does not show the entire area.)

- a. The area surrounding the treatment plant, including all unit processes.
- b. The major pipes or other structures through which wastewater enters the treatment works and the pipes or other structures through which treated wastewater is discharged from the treatment plant. Include outfalls from bypass piping, if applicable.
- c. Each well where wastewater from the treatment plant is injected underground.
- d. Wells, springs, other surface water bodies, and drinking water wells that are: 1) within 1/4 mile of the property boundaries of the treatment works, and 2) listed in public record or otherwise known to the applicant.
- e. Any areas where the sewage sludge produced by the treatment works is stored, treated, or disposed.
- f. If the treatment works receives waste that is classified as hazardous under the Resource Conservation and Recovery Act (RCRA) by truck, rail, or special pipe, show on the map where that hazardous waste enters the treatment works and where it is treated, stored, and/or disposed.

**B.3. Process Flow Diagram or Schematic.** Provide a diagram showing the processes of the treatment plant, including all bypass piping and all backup power sources or redundancy in the system. Also provide a water balance showing all treatment units, including disinfection (e.g., chlorination and dechlorination). The water balance must show daily average flow rates at influent and discharge points and approximate daily flow rates between treatment units. Include a brief narrative description of the diagram.

**B.4. Operation/Maintenance Performed by Contractor(s).**

Are any operational or maintenance aspects (related to wastewater treatment and effluent quality) of the treatment works the responsibility of a contractor? \_\_\_Yes \_\_\_No

If yes, list the name, address, telephone number, and status of each contractor and describe the contractor's responsibilities (attach additional pages if necessary).

Name: \_\_\_\_\_

Mailing Address: \_\_\_\_\_  
\_\_\_\_\_

Telephone Number: \_\_\_\_\_

Responsibilities of Contractor: \_\_\_\_\_

**B.5. Scheduled Improvements and Schedules of Implementation.** Provide information on any uncompleted implementation schedule or uncompleted plans for improvements that will affect the wastewater treatment, effluent quality, or design capacity of the treatment works. If the treatment works has several different implementation schedules or is planning several improvements, submit separate responses to question B.5 for each. (If none, go to question B.6.)

- a. List the outfall number (assigned in question A.9) for each outfall that is covered by this implementation schedule.

\_\_\_\_\_

- b. Indicate whether the planned improvements or implementation schedule are required by local, State, or Federal agencies.

\_\_\_Yes \_\_\_No

FACILITY NAME AND PERMIT NUMBER:

Form Approved 1/14/99  
OMB Number 2040-0086

c. If the answer to B.5.b is "Yes," briefly describe, including new maximum daily inflow rate (if applicable).

\_\_\_\_\_

d. Provide dates imposed by any compliance schedule or any actual dates of completion for the implementation steps listed below, as applicable. For improvements planned independently of local, State, or Federal agencies, indicate planned or actual completion dates, as applicable. Indicate dates as accurately as possible.

| Implementation Stage       | Schedule       | Actual Completion |
|----------------------------|----------------|-------------------|
|                            | MM / DD / YYYY | MM / DD / YYYY    |
| - Begin construction       | ___/___/___    | ___/___/___       |
| - End construction         | ___/___/___    | ___/___/___       |
| - Begin discharge          | ___/___/___    | ___/___/___       |
| - Attain operational level | ___/___/___    | ___/___/___       |

e. Have appropriate permits/clearances concerning other Federal/State requirements been obtained?  Yes  No

Describe briefly: \_\_\_\_\_  
\_\_\_\_\_

**B.6. EFFLUENT TESTING DATA (GREATER THAN 0.1 MGD ONLY).**

Applicants that discharge to waters of the US must provide effluent testing data for the following parameters. Provide the indicated effluent testing required by the permitting authority for each outfall through which effluent is discharged. Do not include information on combined sewer overflows in this section. All information reported must be based on data collected through analysis conducted using 40 CFR Part 136 methods. In addition, this data must comply with QA/QC requirements of 40 CFR Part 136 and other appropriate QA/QC requirements for standard methods for analytes not addressed by 40 CFR Part 136. At a minimum, effluent testing data must be based on at least three pollutant scans and must be no more than four and one-half years old.

Outfall Number: \_\_\_\_\_

| POLLUTANT  | MAXIMUM DAILY DISCHARGE |       | AVERAGE DAILY DISCHARGE |       |                   | ANALYTICAL METHOD | ML / MDL |
|--|-------------------------|-------|-------------------------|-------|-------------------|-------------------|----------|
|  | Conc.                   | Units | Conc.                   | Units | Number of Samples |                   |          |
| <b>CONVENTIONAL AND NONCONVENTIONAL COMPOUNDS.</b> |                         |       |                         |       |                   |                   |          |
| AMMONIA (as N)                                     |                         |       |                         |       |                   |                   |          |
| CHLORINE (TOTAL RESIDUAL, TRC)                     |                         |       |                         |       |                   |                   |          |
| DISSOLVED OXYGEN                                   |                         |       |                         |       |                   |                   |          |
| TOTAL KJELDAHL NITROGEN (TKN)                      |                         |       |                         |       |                   |                   |          |
| NITRATE PLUS NITRITE NITROGEN                      |                         |       |                         |       |                   |                   |          |
| OIL and GREASE                                     |                         |       |                         |       |                   |                   |          |
| PHOSPHORUS (Total)                                 |                         |       |                         |       |                   |                   |          |
| TOTAL DISSOLVED SOLIDS (TDS)                       |                         |       |                         |       |                   |                   |          |
| OTHER  |                         |       |                         |       |                   |                   |          |

**END OF PART B.  
REFER TO THE APPLICATION OVERVIEW TO DETERMINE WHICH OTHER PARTS OF FORM 2A YOU MUST COMPLETE**

FACILITY NAME AND PERMIT NUMBER:

Form Approved 1/14/99  
OMB Number 2040-0086

**BASIC APPLICATION INFORMATION**

**PART C. CERTIFICATION**

All applicants must complete the Certification Section. Refer to instructions to determine who is an officer for the purposes of this certification. All applicants must complete all applicable sections of Form 2A, as explained in the Application Overview. Indicate below which parts of Form 2A you have completed and are submitting. By signing this certification statement, applicants confirm that they have reviewed Form 2A and have completed all sections that apply to the facility for which this application is submitted.

Indicate which parts of Form 2A you have completed and are submitting:

- |  |  |
|--|--|
| <input checked="" type="checkbox"/> Basic Application Information packet | Supplemental Application Information packet:                     |
|  | _____ Part D (Expanded Effluent Testing Data)                    |
|  | _____ Part E (Toxicity Testing: Biomonitoring Data)              |
|  | _____ Part F (Industrial User Discharges and RCRA/CERCLA Wastes) |
|  | _____ Part G (Combined Sewer Systems)                            |

**ALL APPLICANTS MUST COMPLETE THE FOLLOWING CERTIFICATION.**

I certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system or those persons directly responsible for gathering the information, the information is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations.

Name and official title Tim Haney Park Superintendent

Signature 

Telephone number 256-249-5466

Date signed 04/23/15

Upon request of the permitting authority, you must submit any other information necessary to assess wastewater treatment practices at the treatment works or identify appropriate permitting requirements.

**SEND COMPLETED FORMS TO:**

FACILITY NAME AND PERMIT NUMBER:

Form Approved 1/14/99  
OMB Number 2040-0086

**SUPPLEMENTAL APPLICATION INFORMATION**

**PART D. EXPANDED EFFLUENT TESTING DATA**

Refer to the directions on the cover page to determine whether this section applies to the treatment works.

**Effluent Testing: 1.0 mgd and Pretreatment Treatment Works.** If the treatment works has a design flow greater than or equal to 1.0 mgd or it has (or is required to have) a pretreatment program, or is otherwise required by the permitting authority to provide the data, then provide effluent testing data for the following pollutants. Provide the indicated effluent testing information and any other information required by the permitting authority for each outfall through which effluent is discharged. Do not include information on combined sewer overflows in this section. All information reported must be based on data collected through analyses conducted using 40 CFR Part 136 methods. In addition, these data must comply with QA/QC requirements of 40 CFR Part 136 and other appropriate QA/QC requirements for standard methods for analytes not addressed by 40 CFR Part 136. Indicate in the blank rows provided below any data you may have on pollutants not specifically listed in this form. At a minimum, effluent testing data must be based on at least three pollutant scans and must be no more than four and one-half years old.

Outfall number: \_\_\_\_\_ (Complete once for each outfall discharging effluent to waters of the United States.)

| POLLUTANT   | MAXIMUM DAILY DISCHARGE |       |      |       | AVERAGE DAILY DISCHARGE |       |      |       |                   | ANALYTICAL METHOD | ML/ MDL |
|---|-------------------------|-------|------|-------|-------------------------|-------|------|-------|-------------------|-------------------|---------|
|   | Conc.                   | Units | Mass | Units | Conc.                   | Units | Mass | Units | Number of Samples |                   |         |
| <b>METALS (TOTAL RECOVERABLE), CYANIDE, PHENOLS, AND HARDNESS.</b>  |                         |       |      |       |                         |       |      |       |                   |                   |         |
| ANTIMONY  |                         |       |      |       |                         |       |      |       |                   |                   |         |
| ARSENIC   |                         |       |      |       |                         |       |      |       |                   |                   |         |
| BERYLLIUM   |                         |       |      |       |                         |       |      |       |                   |                   |         |
| CADMIUM   |                         |       |      |       |                         |       |      |       |                   |                   |         |
| CHROMIUM  |                         |       |      |       |                         |       |      |       |                   |                   |         |
| COPPER  |                         |       |      |       |                         |       |      |       |                   |                   |         |
| LEAD  |                         |       |      |       |                         |       |      |       |                   |                   |         |
| MERCURY   |                         |       |      |       |                         |       |      |       |                   |                   |         |
| NICKEL  |                         |       |      |       |                         |       |      |       |                   |                   |         |
| SELENIUM  |                         |       |      |       |                         |       |      |       |                   |                   |         |
| SILVER  |                         |       |      |       |                         |       |      |       |                   |                   |         |
| THALLIUM  |                         |       |      |       |                         |       |      |       |                   |                   |         |
| ZINC  |                         |       |      |       |                         |       |      |       |                   |                   |         |
| CYANIDE   |                         |       |      |       |                         |       |      |       |                   |                   |         |
| TOTAL PHENOLIC COMPOUNDS  |                         |       |      |       |                         |       |      |       |                   |                   |         |
| HARDNESS (AS CaCO <sub>3</sub> )  |                         |       |      |       |                         |       |      |       |                   |                   |         |
| Use this space (or a separate sheet) to provide information on other metals requested by the permit writer. |                         |       |      |       |                         |       |      |       |                   |                   |         |
|   |                         |       |      |       |                         |       |      |       |                   |                   |         |
|   |                         |       |      |       |                         |       |      |       |                   |                   |         |

FACILITY NAME AND PERMIT NUMBER:

Form Approved 1/14/99  
OMB Number 2040-0086

Outfall number: \_\_\_\_\_ (Complete once for each outfall discharging effluent to waters of the United States.)

| POLLUTANT                          | MAXIMUM DAILY DISCHARGE |       |      |       | AVERAGE DAILY DISCHARGE |       |      |       |                   | ANALYTICAL METHOD | ML/ MDL |
|------------------------------------|-------------------------|-------|------|-------|-------------------------|-------|------|-------|-------------------|-------------------|---------|
|                                    | Conc.                   | Units | Mass | Units | Conc.                   | Units | Mass | Units | Number of Samples |                   |         |
| <b>VOLATILE ORGANIC COMPOUNDS.</b> |                         |       |      |       |                         |       |      |       |                   |                   |         |
| ACROLEIN                           |                         |       |      |       |                         |       |      |       |                   |                   |         |
| ACRYLONITRILE                      |                         |       |      |       |                         |       |      |       |                   |                   |         |
| BENZENE                            |                         |       |      |       |                         |       |      |       |                   |                   |         |
| BROMOFORM                          |                         |       |      |       |                         |       |      |       |                   |                   |         |
| CARBON TETRACHLORIDE               |                         |       |      |       |                         |       |      |       |                   |                   |         |
| CLOROBENZENE                       |                         |       |      |       |                         |       |      |       |                   |                   |         |
| CHLORODIBROMO-METHANE              |                         |       |      |       |                         |       |      |       |                   |                   |         |
| CHLOROETHANE                       |                         |       |      |       |                         |       |      |       |                   |                   |         |
| 2-CHLORO-ETHYLVINYL ETHER          |                         |       |      |       |                         |       |      |       |                   |                   |         |
| CHLOROFORM                         |                         |       |      |       |                         |       |      |       |                   |                   |         |
| DICHLOROBROMO-METHANE              |                         |       |      |       |                         |       |      |       |                   |                   |         |
| 1,1-DICHLOROETHANE                 |                         |       |      |       |                         |       |      |       |                   |                   |         |
| 1,2-DICHLOROETHANE                 |                         |       |      |       |                         |       |      |       |                   |                   |         |
| TRANS-1,2-DICHLORO-ETHYLENE        |                         |       |      |       |                         |       |      |       |                   |                   |         |
| 1,1-DICHLOROETHYLENE               |                         |       |      |       |                         |       |      |       |                   |                   |         |
| 1,2-DICHLOROPROPANE                |                         |       |      |       |                         |       |      |       |                   |                   |         |
| 1,3-DICHLORO-PROPYLENE             |                         |       |      |       |                         |       |      |       |                   |                   |         |
| ETHYLBENZENE                       |                         |       |      |       |                         |       |      |       |                   |                   |         |
| METHYL BROMIDE                     |                         |       |      |       |                         |       |      |       |                   |                   |         |
| METHYL CHLORIDE                    |                         |       |      |       |                         |       |      |       |                   |                   |         |
| METHYLENE CHLORIDE                 |                         |       |      |       |                         |       |      |       |                   |                   |         |
| 1,1,2,2-TETRACHLORO-ETHANE         |                         |       |      |       |                         |       |      |       |                   |                   |         |
| TETRACHLORO-ETHYLENE               |                         |       |      |       |                         |       |      |       |                   |                   |         |
| TOLUENE                            |                         |       |      |       |                         |       |      |       |                   |                   |         |

FACILITY NAME AND PERMIT NUMBER:

Form Approved 1/14/99  
OMB Number 2040-0086

Outfall number: \_\_\_\_\_ (Complete once for each outfall discharging effluent to waters of the United States.)

| POLLUTANT             | MAXIMUM DAILY DISCHARGE |       |      |       | AVERAGE DAILY DISCHARGE |       |      |       |                   | ANALYTICAL METHOD | ML/ MDL |  |
|-----------------------|-------------------------|-------|------|-------|-------------------------|-------|------|-------|-------------------|-------------------|---------|--|
|                       | Conc.                   | Units | Mass | Units | Conc.                   | Units | Mass | Units | Number of Samples |                   |         |  |
| 1,1,1-TRICHLOROETHANE |                         |       |      |       |                         |       |      |       |                   |                   |         |  |
| 1,1,2-TRICHLOROETHANE |                         |       |      |       |                         |       |      |       |                   |                   |         |  |
| TRICHLORETHYLENE      |                         |       |      |       |                         |       |      |       |                   |                   |         |  |
| VINYL CHLORIDE        |                         |       |      |       |                         |       |      |       |                   |                   |         |  |

Use this space (or a separate sheet) to provide information on other volatile organic compounds requested by the permit writer.

|  |  |  |  |  |  |  |  |  |  |  |  |  |
|--|--|--|--|--|--|--|--|--|--|--|--|--|
|  |  |  |  |  |  |  |  |  |  |  |  |  |
|--|--|--|--|--|--|--|--|--|--|--|--|--|

**ACID-EXTRACTABLE COMPOUNDS**

|                       |  |  |  |  |  |  |  |  |  |  |  |  |
|-----------------------|--|--|--|--|--|--|--|--|--|--|--|--|
| P-CHLORO-M-CRESOL     |  |  |  |  |  |  |  |  |  |  |  |  |
| 2-CHLOROPHENOL        |  |  |  |  |  |  |  |  |  |  |  |  |
| 2,4-DICHLOROPHENOL    |  |  |  |  |  |  |  |  |  |  |  |  |
| 2,4-DIMETHYLPHENOL    |  |  |  |  |  |  |  |  |  |  |  |  |
| 4,6-DINITRO-O-CRESOL  |  |  |  |  |  |  |  |  |  |  |  |  |
| 2,4-DINITROPHENOL     |  |  |  |  |  |  |  |  |  |  |  |  |
| 2-NITROPHENOL         |  |  |  |  |  |  |  |  |  |  |  |  |
| 4-NITROPHENOL         |  |  |  |  |  |  |  |  |  |  |  |  |
| PENTACHLOROPHENOL     |  |  |  |  |  |  |  |  |  |  |  |  |
| PHENOL                |  |  |  |  |  |  |  |  |  |  |  |  |
| 2,4,6-TRICHLOROPHENOL |  |  |  |  |  |  |  |  |  |  |  |  |

Use this space (or a separate sheet) to provide information on other acid-extractable compounds requested by the permit writer.

|  |  |  |  |  |  |  |  |  |  |  |  |  |
|--|--|--|--|--|--|--|--|--|--|--|--|--|
|  |  |  |  |  |  |  |  |  |  |  |  |  |
|--|--|--|--|--|--|--|--|--|--|--|--|--|

**BASE-NEUTRAL COMPOUNDS.**

|                    |  |  |  |  |  |  |  |  |  |  |  |  |
|--------------------|--|--|--|--|--|--|--|--|--|--|--|--|
| ACENAPHTHENE       |  |  |  |  |  |  |  |  |  |  |  |  |
| ACENAPHTHYLENE     |  |  |  |  |  |  |  |  |  |  |  |  |
| ANTHRACENE         |  |  |  |  |  |  |  |  |  |  |  |  |
| BENZIDINE          |  |  |  |  |  |  |  |  |  |  |  |  |
| BENZO(A)ANTHRACENE |  |  |  |  |  |  |  |  |  |  |  |  |
| BENZO(A)PYRENE     |  |  |  |  |  |  |  |  |  |  |  |  |

FACILITY NAME AND PERMIT NUMBER:

Form Approved 1/14/99  
OMB Number 2040-0086

Outfall number: \_\_\_\_\_ (Complete once for each outfall discharging effluent to waters of the United States.)

| POLLUTANT                      | MAXIMUM DAILY DISCHARGE |       |      |       | AVERAGE DAILY DISCHARGE |       |      |       |                   | ANALYTICAL METHOD | ML/ MDL |  |
|--------------------------------|-------------------------|-------|------|-------|-------------------------|-------|------|-------|-------------------|-------------------|---------|--|
|                                | Conc.                   | Units | Mass | Units | Conc.                   | Units | Mass | Units | Number of Samples |                   |         |  |
| 3,4 BENZO-FLUORANTHENE         |                         |       |      |       |                         |       |      |       |                   |                   |         |  |
| BENZO(GH)PERYLENE              |                         |       |      |       |                         |       |      |       |                   |                   |         |  |
| BENZO(K)FLUORANTHENE           |                         |       |      |       |                         |       |      |       |                   |                   |         |  |
| BIS (2-CHLOROETHOXY) METHANE   |                         |       |      |       |                         |       |      |       |                   |                   |         |  |
| BIS (2-CHLOROETHYL)-ETHER      |                         |       |      |       |                         |       |      |       |                   |                   |         |  |
| BIS (2-CHLOROISO-PROPYL) ETHER |                         |       |      |       |                         |       |      |       |                   |                   |         |  |
| BIS (2-ETHYLHEXYL) PHTHALATE   |                         |       |      |       |                         |       |      |       |                   |                   |         |  |
| 4-BROMOPHENYL PHENYL ETHER     |                         |       |      |       |                         |       |      |       |                   |                   |         |  |
| BUTYL BENZYL PHTHALATE         |                         |       |      |       |                         |       |      |       |                   |                   |         |  |
| 2-CHLORONAPHTHALENE            |                         |       |      |       |                         |       |      |       |                   |                   |         |  |
| 4-CHLORPHENYL PHENYL ETHER     |                         |       |      |       |                         |       |      |       |                   |                   |         |  |
| CHRYSENE                       |                         |       |      |       |                         |       |      |       |                   |                   |         |  |
| DI-N-BUTYL PHTHALATE           |                         |       |      |       |                         |       |      |       |                   |                   |         |  |
| DI-N-OCTYL PHTHALATE           |                         |       |      |       |                         |       |      |       |                   |                   |         |  |
| DIBENZO(A,H) ANTHRACENE        |                         |       |      |       |                         |       |      |       |                   |                   |         |  |
| 1,2-DICHLOROENZENE             |                         |       |      |       |                         |       |      |       |                   |                   |         |  |
| 1,3-DICHLOROENZENE             |                         |       |      |       |                         |       |      |       |                   |                   |         |  |
| 1,4-DICHLOROENZENE             |                         |       |      |       |                         |       |      |       |                   |                   |         |  |
| 3,3-DICHLOROENZIDINE           |                         |       |      |       |                         |       |      |       |                   |                   |         |  |
| DIETHYL PHTHALATE              |                         |       |      |       |                         |       |      |       |                   |                   |         |  |
| DIMETHYL PHTHALATE             |                         |       |      |       |                         |       |      |       |                   |                   |         |  |
| 2,4-DINITROTOLUENE             |                         |       |      |       |                         |       |      |       |                   |                   |         |  |
| 2,6-DINITROTOLUENE             |                         |       |      |       |                         |       |      |       |                   |                   |         |  |
| 1,2-DIPHENYLHYDRAZINE          |                         |       |      |       |                         |       |      |       |                   |                   |         |  |

FACILITY NAME AND PERMIT NUMBER:

Form Approved 1/14/99  
OMB Number 2040-0086

Outfall number: \_\_\_\_\_ (Complete once for each outfall discharging effluent to waters of the United States.)

| POLLUTANT                  | MAXIMUM DAILY DISCHARGE |       |      |       | AVERAGE DAILY DISCHARGE |       |      |       |                   | ANALYTICAL METHOD | ML/ MDL |
|----------------------------|-------------------------|-------|------|-------|-------------------------|-------|------|-------|-------------------|-------------------|---------|
|                            | Conc.                   | Units | Mass | Units | Conc.                   | Units | Mass | Units | Number of Samples |                   |         |
| FLUORANTHENE               |                         |       |      |       |                         |       |      |       |                   |                   |         |
| FLUORENE                   |                         |       |      |       |                         |       |      |       |                   |                   |         |
| HEXACHLOROBENZENE          |                         |       |      |       |                         |       |      |       |                   |                   |         |
| HEXACHLOROBUTADIENE        |                         |       |      |       |                         |       |      |       |                   |                   |         |
| HEXACHLOROCYCLO-PENTADIENE |                         |       |      |       |                         |       |      |       |                   |                   |         |
| HEXACHLOROETHANE           |                         |       |      |       |                         |       |      |       |                   |                   |         |
| INDENO(1,2,3-CD)PYRENE     |                         |       |      |       |                         |       |      |       |                   |                   |         |
| ISOPHORONE                 |                         |       |      |       |                         |       |      |       |                   |                   |         |
| NAPHTHALENE                |                         |       |      |       |                         |       |      |       |                   |                   |         |
| NITROBENZENE               |                         |       |      |       |                         |       |      |       |                   |                   |         |
| N-NITROSODI-N-PROPYLAMINE  |                         |       |      |       |                         |       |      |       |                   |                   |         |
| N-NITROSODI- METHYLAMINE   |                         |       |      |       |                         |       |      |       |                   |                   |         |
| N-NITROSODI-PHENYLAMINE    |                         |       |      |       |                         |       |      |       |                   |                   |         |
| PHENANTHRENE               |                         |       |      |       |                         |       |      |       |                   |                   |         |
| PYRENE                     |                         |       |      |       |                         |       |      |       |                   |                   |         |
| 1,2,4-TRICHLOROBENZENE     |                         |       |      |       |                         |       |      |       |                   |                   |         |

Use this space (or a separate sheet) to provide information on other base-neutral compounds requested by the permit writer.

Use this space (or a separate sheet) to provide information on other pollutants (e.g., pesticides) requested by the permit writer.

**END OF PART D.  
REFER TO THE APPLICATION OVERVIEW TO DETERMINE WHICH OTHER PARTS OF FORM  
2A YOU MUST COMPLETE**

**SUPPLEMENTAL APPLICATION INFORMATION**

**PART E. TOXICITY TESTING DATA**

POTWs meeting one or more of the following criteria must provide the results of whole effluent toxicity tests for acute or chronic toxicity for each of the facility's discharge points: 1) POTWs with a design flow rate greater than or equal to 1.0 mgd; 2) POTWs with a pretreatment program (or those that are required to have one under 40 CFR Part 403); or 3) POTWs required by the permitting authority to submit data for these parameters.

- At a minimum, these results must include quarterly testing for a 12-month period within the past 1 year using multiple species (minimum of two species), or the results from four tests performed at least annually in the four and one-half years prior to the application, provided the results show no appreciable toxicity, and testing for acute and/or chronic toxicity, depending on the range of receiving water dilution. Do not include information on combined sewer overflows in this section. All information reported must be based on data collected through analysis conducted using 40 CFR Part 136 methods. In addition, this data must comply with QA/QC requirements of 40 CFR Part 136 and other appropriate QA/QC requirements for standard methods for analytes not addressed by 40 CFR Part 136.
- In addition, submit the results of any other whole effluent toxicity tests from the past four and one-half years. If a whole effluent toxicity test conducted during the past four and one-half years revealed toxicity, provide any information on the cause of the toxicity or any results of a toxicity reduction evaluation, if one was conducted.
- If you have already submitted any of the information requested in Part E, you need not submit it again. Rather, provide the information requested in question E.4 for previously submitted information. If EPA methods were not used, report the reasons for using alternate methods. If test summaries are available that contain all of the information requested below, they may be submitted in place of Part E.

If no biomonitoring data is required, do not complete Part E. Refer to the Application Overview for directions on which other sections of the form to complete.

**E.1. Required Tests.**

Indicate the number of whole effluent toxicity tests conducted in the past four and one-half years.

\_\_\_\_ chronic      \_\_\_\_ acute

**E.2. Individual Test Data.** Complete the following chart for each whole effluent toxicity test conducted in the last four and one-half years. Allow one column per test (where each species constitutes a test). Copy this page if more than three tests are being reported.

Test number: \_\_\_\_\_      Test number: \_\_\_\_\_      Test number: \_\_\_\_\_

**a. Test information.**

|                                   |  |  |  |
|-----------------------------------|--|--|--|
| Test species & test method number |  |  |  |
| Age at initiation of test         |  |  |  |
| Outfall number                    |  |  |  |
| Dates sample collected            |  |  |  |
| Date test started                 |  |  |  |
| Duration                          |  |  |  |

**b. Give toxicity test methods followed.**

|  |  |  |  |
|--|--|--|--|
| Manual title                           |  |  |  |
| Edition number and year of publication |  |  |  |
| Page number(s)                         |  |  |  |

**c. Give the sample collection method(s) used. For multiple grab samples, indicate the number of grab samples used.**

|                   |  |  |  |
|-------------------|--|--|--|
| 24-Hour composite |  |  |  |
| Grab              |  |  |  |

**d. Indicate where the sample was taken in relation to disinfection. (Check all that apply for each)**

|                      |  |  |  |
|----------------------|--|--|--|
| Before disinfection  |  |  |  |
| After disinfection   |  |  |  |
| After dechlorination |  |  |  |

FACILITY NAME AND PERMIT NUMBER:

Form Approved 1/14/99  
OMB Number 2040-0086

Test number: \_\_\_\_\_ Test number: \_\_\_\_\_ Test number: \_\_\_\_\_

e. Describe the point in the treatment process at which the sample was collected.

Sample was collected:

f. For each test, include whether the test was intended to assess chronic toxicity, acute toxicity, or both.

Chronic toxicity

Acute toxicity

g. Provide the type of test performed.

Static

Static-renewal

Flow-through

h. Source of dilution water. If laboratory water, specify type; if receiving water, specify source.

Laboratory water


Receiving water

i. Type of dilution water. If salt water, specify "natural" or type of artificial sea salts or brine used.

Fresh water

Salt water

j. Give the percentage effluent used for all concentrations in the test series.



k. Parameters measured during the test. (State whether parameter meets test method specifications)

pH

Salinity

Temperature

Ammonia

Dissolved oxygen

l. Test Results.

Acute:

|                                   |   |   |   |
|-----------------------------------|---|---|---|
| Percent survival in 100% effluent | % | % | % |
| LC <sub>50</sub>                  |   |   |   |
| 95% C.I.                          | % | % | % |
| Control percent survival          | % | % | % |
| Other (describe)                  |   |   |   |

FACILITY NAME AND PERMIT NUMBER:

Form Approved 1/14/99  
OMB Number 2040-0086

Chronic:

|                          |   |   |   |
|--------------------------|---|---|---|
| NOEC                     | % | % | % |
| IC <sub>25</sub>         | % | % | % |
| Control percent survival | % | % | % |
| Other (describe)         |   |   |   |

m. Quality Control/Quality Assurance.

|   |  |  |  |
|---|--|--|--|
| Is reference toxicant data available?                   |  |  |  |
| Was reference toxicant test within acceptable bounds?   |  |  |  |
| What date was reference toxicant test run (MM/DD/YYYY)? |  |  |  |
| Other (describe)  |  |  |  |

**E.3. Toxicity Reduction Evaluation.** Is the treatment works involved in a Toxicity Reduction Evaluation?

Yes  No      If yes, describe: \_\_\_\_\_  
\_\_\_\_\_  
\_\_\_\_\_

**E.4. Summary of Submitted Biomonitoring Test Information.** If you have submitted biomonitoring test information, or information regarding the cause of toxicity, within the past four and one-half years, provide the dates the information was submitted to the permitting authority and a summary of the results.

Date submitted: \_\_\_\_\_ (MM/DD/YYYY)

Summary of results: (see instructions)  
\_\_\_\_\_  
\_\_\_\_\_

**END OF PART E.  
REFER TO THE APPLICATION OVERVIEW TO DETERMINE WHICH OTHER PARTS OF FORM  
2A YOU MUST COMPLETE.**

FACILITY NAME AND PERMIT NUMBER:

Form Approved 1/14/99  
OMB Number 2040-0086

**SUPPLEMENTAL APPLICATION INFORMATION**

**PART F. INDUSTRIAL USER DISCHARGES AND RCRA/CERCLA WASTES**

All treatment works receiving discharges from significant industrial users or which receive RCRA, CERCLA, or other remedial wastes must complete Part F.

**GENERAL INFORMATION:**

**F.1. Pretreatment Program.** Does the treatment works have, or is it subject to, an approved pretreatment program?

\_\_\_ Yes \_\_\_ No

**F.2. Number of Significant Industrial Users (SIUs) and Categorical Industrial Users (CIUs).** Provide the number of each of the following types of industrial users that discharge to the treatment works.

- a. Number of non-categorical SIUs. \_\_\_\_\_
- b. Number of CIUs. \_\_\_\_\_

**SIGNIFICANT INDUSTRIAL USER INFORMATION:**

Supply the following information for each SIU. If more than one SIU discharges to the treatment works, copy questions F.3 through F.8 and provide the information requested for each SIU.

**F.3. Significant Industrial User Information.** Provide the name and address of each SIU discharging to the treatment works. Submit additional pages as necessary.

Name: \_\_\_\_\_

Mailing Address: \_\_\_\_\_

\_\_\_\_\_

**F.4. Industrial Processes.** Describe all of the industrial processes that affect or contribute to the SIU's discharge.

\_\_\_\_\_

**F.5. Principal Product(s) and Raw Material(s).** Describe all of the principal processes and raw materials that affect or contribute to the SIU's discharge.

Principal product(s): \_\_\_\_\_

Raw material(s): \_\_\_\_\_

**F.6. Flow Rate.**

a. Process wastewater flow rate. Indicate the average daily volume of process wastewater discharged into the collection system in gallons per day (gpd) and whether the discharge is continuous or intermittent.

\_\_\_\_\_ gpd ( \_\_\_ continuous or \_\_\_ intermittent)

b. Non-process wastewater flow rate. Indicate the average daily volume of non-process wastewater flow discharged into the collection system in gallons per day (gpd) and whether the discharge is continuous or intermittent.

\_\_\_\_\_ gpd ( \_\_\_ continuous or \_\_\_ intermittent)

**F.7. Pretreatment Standards.** Indicate whether the SIU is subject to the following:

- a. Local limits \_\_\_\_\_ Yes \_\_\_ No
- b. Categorical pretreatment standards \_\_\_\_\_ Yes \_\_\_ No

If subject to categorical pretreatment standards, which category and subcategory?

\_\_\_\_\_

FACILITY NAME AND PERMIT NUMBER:

Form Approved 1/14/99  
OMB Number 2040-0086

**F.8. Problems at the Treatment Works Attributed to Waste Discharged by the SIU.** Has the SIU caused or contributed to any problems (e.g., upsets, interference) at the treatment works in the past three years?

Yes  No If yes, describe each episode.

\_\_\_\_\_  
\_\_\_\_\_

**RCRA HAZARDOUS WASTE RECEIVED BY TRUCK, RAIL, OR DEDICATED PIPELINE:**

**F.9. RCRA Waste.** Does the treatment works receive or has it in the past three years received RCRA hazardous waste by truck, rail, or dedicated pipe?  Yes  No (go to F.12.)

**F.10. Waste Transport.** Method by which RCRA waste is received (check all that apply):

Truck  Rail  Dedicated Pipe

**F.11. Waste Description.** Give EPA hazardous waste number and amount (volume or mass, specify units).

| <u>EPA Hazardous Waste Number</u> | <u>Amount</u> | <u>Units</u> |
|-----------------------------------|---------------|--------------|
| _____                             | _____         | _____        |
| _____                             | _____         | _____        |
| _____                             | _____         | _____        |

**CERCLA (SUPERFUND) WASTEWATER, RCRA REMEDIATION/CORRECTIVE ACTION WASTEWATER, AND OTHER REMEDIAL ACTIVITY WASTEWATER:**

**F.12. Remediation Waste.** Does the treatment works currently (or has it been notified that it will) receive waste from remedial activities?

Yes (complete F.13 through F.15.)  No

Provide a list of sites and the requested information (F.13 - F.15.) for each current and future site.

**F.13. Waste Origin.** Describe the site and type of facility at which the CERCLA/RCRA/or other remedial waste originates (or is expected to originate in the next five years).

\_\_\_\_\_  
\_\_\_\_\_  
\_\_\_\_\_

**F.14. Pollutants.** List the hazardous constituents that are received (or are expected to be received). Include data on volume and concentration, if known. (Attach additional sheets if necessary).

\_\_\_\_\_  
\_\_\_\_\_

**F.15. Waste Treatment.**

a. Is this waste treated (or will it be treated) prior to entering the treatment works?

Yes  No

If yes, describe the treatment (provide information about the removal efficiency):

\_\_\_\_\_  
\_\_\_\_\_

b. Is the discharge (or will the discharge be) continuous or intermittent?

Continuous  Intermittent If intermittent, describe discharge schedule.

\_\_\_\_\_

**END OF PART F.  
REFER TO THE APPLICATION OVERVIEW TO DETERMINE WHICH OTHER PARTS OF FORM  
2A YOU MUST COMPLETE**

**SUPPLEMENTAL APPLICATION INFORMATION**

**PART G. COMBINED SEWER SYSTEMS**

**if the treatment works has a combined sewer system, complete Part G.**

**G.1. System Map.** Provide a map indicating the following: (may be included with Basic Application Information)

- a. All CSO discharge points.
- b. Sensitive use areas potentially affected by CSOs (e.g., beaches, drinking water supplies, shellfish beds, sensitive aquatic ecosystems, and outstanding natural resource waters).
- c. Waters that support threatened and endangered species potentially affected by CSOs.

**G.2. System Diagram.** Provide a diagram, either in the map provided in G.1. or on a separate drawing, of the combined sewer collection system that includes the following information:

- a. Locations of major sewer trunk lines, both combined and separate sanitary.
- b. Locations of points where separate sanitary sewers feed into the combined sewer system.
- c. Locations of in-line and off-line storage structures.
- d. Locations of flow-regulating devices.
- e. Locations of pump stations.

**CSO OUTFALLS:**

**Complete questions G.3 through G.6 once for each CSO discharge point.**

**G.3. Description of Outfall.**

- a. Outfall number \_\_\_\_\_
- b. Location \_\_\_\_\_  
 (City or town, if applicable) (Zip Code)  
 \_\_\_\_\_  
 (County) (State)  
 \_\_\_\_\_  
 (Latitude) (Longitude)
- c. Distance from shore (if applicable) \_\_\_\_\_ ft.
- d. Depth below surface (if applicable) \_\_\_\_\_ ft.
- e. Which of the following were monitored during the last year for this CSO?  
 \_\_\_ Rainfall      \_\_\_ CSO pollutant concentrations      \_\_\_ CSO frequency  
 \_\_\_ CSO flow volume      \_\_\_ Receiving water quality
- f. How many storm events were monitored during the last year? \_\_\_\_\_

**G.4. CSO Events.**

- a. Give the number of CSO events in the last year.  
 \_\_\_\_\_ events (\_\_\_ actual or \_\_\_ approx.)
- b. Give the average duration per CSO event.  
 \_\_\_\_\_ hours (\_\_\_ actual or \_\_\_ approx.)

FACILITY NAME AND PERMIT NUMBER:

Form Approved 1/14/99  
OMB Number 2040-0086

- c. Give the average volume per CSO event.  
\_\_\_\_\_ million gallons (\_\_\_\_\_ actual or \_\_\_\_\_ approx.)
- d. Give the minimum rainfall that caused a CSO event in the last year.  
\_\_\_\_\_ inches of rainfall

**G.5. Description of Receiving Waters.**

- a. Name of receiving water: \_\_\_\_\_
- b. Name of watershed/river/stream system: \_\_\_\_\_  
  
United States Soil Conservation Service 14-digit watershed code (if known): \_\_\_\_\_
- c. Name of State Management/River Basin: \_\_\_\_\_  
  
United States Geological Survey 8-digit hydrologic cataloging unit code (if known): \_\_\_\_\_

**G.6. CSO Operations.**

Describe any known water quality impacts on the receiving water caused by this CSO (e.g., permanent or intermittent beach closings, permanent or intermittent shell fish bed closings, fish kills, fish advisories, other recreational loss, or violation of any applicable State water quality standard).

\_\_\_\_\_  
\_\_\_\_\_

**END OF PART G.  
REFER TO THE APPLICATION OVERVIEW TO DETERMINE WHICH OTHER PARTS OF FORM  
2A YOU MUST COMPLETE.**

**SUPPLEMENTARY INFORMATION**  
**NATIONAL POLLUTANT DISCHARGE ELIMINATION SYSTEM (NPDES)**  
**PERMIT APPLICATION FORM 188- Municipal, Semi-Public & Private Facilities**

ALABAMA DEPARTMENT OF ENVIRONMENTAL MANAGEMENT  
WATER DIVISION – MUNICIPAL PERMIT SECTION  
POST OFFICE BOX 301463  
MONTGOMERY, ALABAMA 36130-1463



**INSTRUCTIONS:** APPLICATIONS SHOULD BE TYPED OR PRINTED IN INK AND SUBMITTED TO THE DEPARTMENT. PLEASE CONTINUE ON AN ATTACHED SHEET OF PAPER IF INSUFFICIENT SPACE IS AVAILABLE TO ADDRESS ANY ITEM BELOW. PLEASE MARK N/A IN THE APPROPRIATE BOX WHEN AN ITEM IS NON-APPLICABLE TO THE APPLICANT.

**PURPOSE OF THIS APPLICATION**

- INITIAL PERMIT APPLICATION FOR NEW FACILITY
- MODIFICATION OF EXISTING PERMIT
- REVOCATION & REISSUANCE OF EXISTING PERMIT
- INITIAL PERMIT APPLICATION FOR EXISTING FACILITY
- REISSUANCE OF EXISTING PERMIT

**SECTION A – GENERAL INFORMATION**

1. Facility Name: Joe Wheeler State Park South Lagoon
  - a. Operator Name: Joe Wheeler State Park / AL Department of Conservation & Natural Resources
  - b. Is the operator identified in 1.a, the owner of the facility? Yes  No   
If no, provide name and address of the operator and submit information indicating the operator's scope of responsibility for the facility.
  - c. Name of Permittee\* if different than Operator: \_\_\_\_\_  
*\*Permittee will be responsible for compliance with the conditions of the permit*
2. NPDES Permit Number AL 0048488 (Not applicable if initial permit application)
3. Facility Location: (**Attach a map with location marked; street, route no. or other specific identifier**)  
Street: 24921 Alabama Highway 101  
City: Town Creek County: Lawrence State: Alabama Zip: 35672  
Facility (Front Gate) Location: Latitude (Deg Min Sec): 34°47'26.66" N Longitude (Deg. Min Sec): 87°22'47.04" W
4. Facility Mailing Address (Street or Post Office Box): 201 McLean Drive  
City: Rogersville County: Lauderdale State: AL Zip: 35672
5. Responsible Official (as described on page 7 of this application):  
Name and Title: Tim Haney  
Address: 201 McLean Drive  
City: Rogersville State: AL Zip: 35672  
Phone Number: 256-247-5466  
Email Address: (Optional): \_\_\_\_\_



6. Designated Facility/DMR Contact:

Name and Title: Tim Haney - Park Superintendant

Phone Number: 256-247-5466

DMR Email Address (Optional – for receipt of blank DMR Forms): \_\_\_\_\_

7. Please complete this section if the Applicant's business entity is a Proprietorship or limited liability Corporation with a responsible official not listed in Item 5.

a) Proprietor:

Name: \_\_\_\_\_

Address: \_\_\_\_\_

City: \_\_\_\_\_ State: \_\_\_\_\_ Zip: \_\_\_\_\_

8. Permit numbers for Applicant's previously issued NPDES Permits and identification of any other State Environmental Permits presently held by the Applicant within the State of Alabama:

| <u>Permit Name</u> | <u>Permit Number</u> | <u>Held by</u>              |
|--------------------|----------------------|-----------------------------|
| NPDES _____        | AL0048488 _____      | State of Alabama DCNR _____ |
| NPDES _____        | AL0032387 _____      | ADCNR/Rogersville _____     |
| _____              | _____                | _____                       |
| _____              | _____                | _____                       |

9. Identify all Administrative Complaints, Notices of Violation, Directives, or Administrative Orders, Consent Decrees, or Litigation concerning water pollution or other permit violations, if any against the Applicant within the State of Alabama in the past five years (attach additional sheets if necessary):

| <u>Facility Name</u> | <u>Permit Number</u> | <u>Type of Action</u> | <u>Date of Action</u> |
|----------------------|----------------------|-----------------------|-----------------------|
| _____                | _____                | _____                 | _____                 |
| _____                | _____                | _____                 | _____                 |
| _____                | _____                | _____                 | _____                 |
| _____                | _____                | _____                 | _____                 |
| _____                | _____                | _____                 | _____                 |

**SECTION B – WASTEWATER DISCHARGE INFORMATION**

1. List the following historical monthly flow rates recorded for the past five years for each outfall:

| <u>Outfall Number</u> | <u>Highest in Last 12 Months<br/>MGD</u> | <u>Highest Daily Flow<br/>MGD</u> | <u>Average Flow<br/>MGD</u> |
|-----------------------|--|-----------------------------------|-----------------------------|
| No Discharge Ever     | _____                                    | _____                             | _____                       |
| Recorded              | _____                                    | _____                             | _____                       |

2. Report E-coli (Freshwater) or Enterococci (Coastal Waters) monitoring results for the past five years for each outfall if available:

| Outfall Number | Ecoli or Enterococci | Maximum Daily E-coli / Enterococci Discharge (per 100 ml) | Maximum Monthly Average E-Coli / Enterococci Discharge (per 100 ml) | No. of Analyses | Analytical Method | ML/MDL |
|----------------|----------------------|---|---|-----------------|-------------------|--------|
|                |                      |   |   |                 |                   |        |
|                |                      |   |   |                 |                   |        |
|                |                      |   |   |                 |                   |        |

3. Attached a process flow schematic of the treatment process, including the size of each unit operation.

4. Do you have, or plan to have, automatic sampling equipment or continuous wastewater flow metering equipment at this facility?

|          |                    |                              |  |                              |
|----------|--------------------|------------------------------|--|------------------------------|
| Current: | Flow Metering      | Yes <input type="checkbox"/> | No <input checked="" type="checkbox"/> | N/A <input type="checkbox"/> |
|          | Sampling Equipment | Yes <input type="checkbox"/> | No <input checked="" type="checkbox"/> | N/A <input type="checkbox"/> |
| Planned: | Flow Metering      | Yes <input type="checkbox"/> | No <input checked="" type="checkbox"/> | N/A <input type="checkbox"/> |
|          | Sampling Equipment | Yes <input type="checkbox"/> | No <input checked="" type="checkbox"/> | N/A <input type="checkbox"/> |

If so, please attach a schematic diagram of the sewer system indicating the present or future location of this equipment and describe the equipment below:

---



---

5. Are any wastewater collection or treatment modifications or expansions planned during the next three years that could alter wastewater volumes or characteristics (Note: Permit Modification may be required)? Yes  No

Briefly describe these changes and any potential or anticipated effects on the wastewater quality and quantity: (Attach additional sheets if needed.)

---



---

**SECTION C – WASTE STORAGE AND DISPOSAL INFORMATION**

Describe the location of all sites used for the storage of solids or liquids that have any potential for accidental discharge to a water of the state, either directly or indirectly via storm sewer, municipal sewer, municipal wastewater treatment plants, or other collection or distribution systems that are located at or operated by the subject existing or proposed NPDES-permitted facility. Indicate the location of any potential release areas and provide a map or detailed narrative description of the areas of concern as an attachment to this application:

|                      |                                 |
|----------------------|---------------------------------|
| Description of Waste | Description of Storage Location |
| N/A                  |                                 |

Describe the location of any sites used for the ultimate disposal of solid or liquid waste materials or residuals (e.g. sludges) generated by any wastewater treatment system located at the facility.

| Description of Waste | Quantity (lbs/day) | Disposal Method* |
|----------------------|--------------------|------------------|
|                      |                    |                  |
|                      |                    |                  |

\*Indicate any wastes disposed at an off-site treatment facility and any wastes that are disposed on-site

**SECTION D – INDUSTRIAL INDIRECT DISCHARGE CONTRIBUTORS**

1. List the existing and proposed industrial source wastewater contributions to the municipal wastewater treatment system (Attach other sheets if necessary)

| Company Name | Description of Industrial Wastewater | Existing or Proposed | Flow (MGD) | Subject to SID Permit? Y/N |
|--------------|--------------------------------------|----------------------|------------|----------------------------|
| N/A          |                                      |                      |            |                            |
|              |                                      |                      |            |                            |
|              |                                      |                      |            |                            |
|              |                                      |                      |            |                            |

2. Are industrial wastewater contributions regulated via a locally approved sewer use ordinance [Y/N]? If so, please attach a copy of the ordinance.

**SECTION E – COASTAL ZONE INFORMATION**

Is the discharge(s) located within the 10-foot elevation contour and within the limits of Mobile or Baldwin County?  
 Yes [] No [] If yes, then complete items A through M below:

|  | YES                      | NO                       |
|--|--------------------------|--------------------------|
| A. Does the project require new construction?  | <input type="checkbox"/> | <input type="checkbox"/> |
| B. Will the project be a source of new air emissions?  | <input type="checkbox"/> | <input type="checkbox"/> |
| C. Does the project involve dredging and/or filling of a wetland area or water way?  | <input type="checkbox"/> | <input type="checkbox"/> |
| Has the Corps of Engineers (COE) permit been issued?   | <input type="checkbox"/> | <input type="checkbox"/> |
| Corps Project Number _____   |                          |                          |
| D. Does the project involve wetlands and/or submersed grassbeds?   | <input type="checkbox"/> | <input type="checkbox"/> |
| E. Are oyster reefs located near the project site?<br>(Include a map showing project and discharge location with respect to oyster reefs)              | <input type="checkbox"/> | <input type="checkbox"/> |
| F. Does the project involve the site development, construction and operation of an energy facility as defined in ADEM Admin. Code R. 335-8-1-.02(bb)?  | <input type="checkbox"/> | <input type="checkbox"/> |
| G. Does the project involve mitigation of shoreline or coastal area erosion?   | <input type="checkbox"/> | <input type="checkbox"/> |
| H. Does the project involve construction on beaches or dunes areas?  | <input type="checkbox"/> | <input type="checkbox"/> |
| I. Will the project interfere with public access to coastal waters?  | <input type="checkbox"/> | <input type="checkbox"/> |
| J. Does the project lie within the 100-year floodplain?  | <input type="checkbox"/> | <input type="checkbox"/> |
| K. Does the project involve the registration, sale, use, or application of pesticides?   | <input type="checkbox"/> | <input type="checkbox"/> |
| L. Does the project propose or require construction of a new well or to alter an existing groundwater well to pump more than 50 gallons per day (GPD)? | <input type="checkbox"/> | <input type="checkbox"/> |
| M. Has the applicable permit for groundwater recovery or for groundwater well installation been obtained?  | <input type="checkbox"/> | <input type="checkbox"/> |

**SECTION F – ANTI-DEGRADATION EVALUATION**

It is the applicant's responsibility to demonstrate the social and economic importance of the proposed activity, if subject to antidegradation requirements. In accordance with 40 CFR 131.12 and Section 335-6-10-.04 of the Alabama Department of Environmental Management Administrative Code, the following information must be provided, if applicable. If further information is required to make this demonstration, attach additional sheets to the application.

1. Is this a new or increased discharge that began after April 3, 1991? Yes [] No [].  
 If "yes", complete question 2 below. If "no", do not complete this section.

2. Has an Anti-Degradation Analysis been previously conducted and submitted to the Department for the new or increased discharge referenced in question 1? Yes [] No [].

If "no" and the discharge is to a Tier II waterbody as defined in ADEM Admin. Code r. 335-6-10-.12(4), complete questions A through F below and also ADEM forms 311 and 312 or 313, whichever is applicable, (attached). Form 312 or 313, whichever is applicable, must be provided for each treatment discharge alternative considered technically viable. If "yes", do not complete this section.

Information required for new or increased discharges to high quality waters:

- A. What environmental or public health problem will the discharger be correcting?
- B. Explain if and to what degree the discharger will be increasing employment as a result of the proposed discharge, either at its existing facility or as the result of the start-up of a related new facility or industry.
- C. Explain if and to what degree the discharge will prevent employment reductions?
- D. Describe any additional state or local taxes that the prospective discharger will be paying.
- E. Describe any public service the discharger will be providing to the community.
- F. Describe the economic or social benefit the discharger will be providing to the community.

**SECTION G – EPA Application Forms**

All Applicants must submit certain EPA permit application forms. More than one application form may be required from a municipal facility depending on the number and types of discharges or outfalls. The EPA application forms are found on the Department's website at <http://www.adem.state.al.us/> and are also listed in Attachment 4.

**SECTION H– ENGINEERING REPORT/BMP PLAN REQUIREMENTS**

Any Engineering Report or Best Management Practice (BMP) Plans required to be submitted to ADEM by the applicant must be in accordance with ADEM 335-6-6-.08(i) & (j).

**SECTION I– RECEIVING WATERS**

| Receiving Water(s) | 303(d) Segment?<br>(Y / N) | Included in TMDL?* |
|--------------------|----------------------------|--------------------|
| Tennessee River    | N                          | N                  |
|                    |                            |                    |
|                    |                            |                    |

\*If a TMDL Compliance Schedule is requested the following should be attached as supporting documentation: (1) Justification for the proposed Compliance Schedule (e.g. time for design and installation of control equipment, etc.); (2) Monitoring results for the pollutant(s) of concern which have not previously been submitted to the Department (sample collection dates, analytical results (mass and concentration), methods utilized, MDL/ML, etc. should be reported as available); (3) Requested interim limitations, if applicable; (4) Date of final compliance with the TMDL limitations; and (5) Any other additional information available to support the requested compliance schedule.

**SECTION J – APPLICATION CERTIFICATION**

THE INFORMATION CONTAINED IN THIS FORM MUST BE CERTIFIED BY A RESPONSIBLE OFFICIAL AS DEFINED IN ADEM ADMINISTRATIVE RULE 335-6-6-.09 "SIGNATORY REQUIREMENTS FOR PERMIT APPLICATIONS" (SEE BELOW).

"I CERTIFY UNDER PENALTY OF LAW THAT THIS DOCUMENT AND ALL ATTACHMENTS WERE PREPARED UNDER MY DIRECTION OR SUPERVISION IN ACCORDANCE WITH A SYSTEM DESIGNED TO ASSURE THAT QUALIFIED PERSONNEL PROPERLY GATHER AND EVALUATE THE INFORMATION SUBMITTED. BASED ON MY INQUIRY OF THE PERSON OR PERSONS WHO MANAGE THE SYSTEM, OR THOSE PERSONS DIRECTLY RESPONSIBLE FOR GATHERING THE INFORMATION, THE INFORMATION SUBMITTED IS, TO THE BEST OF MY KNOWLEDGE AND BELIEF, TRUE, ACCURATE, AND COMPLETE. I AM AWARE THAT THERE ARE SIGNIFICANT PENALTIES FOR SUBMITTING FALSE INFORMATION INCLUDING THE POSSIBILITY OF FINE AND IMPRISONMENT FOR KNOWING VIOLATIONS."

"I FURTHER CERTIFY UNDER PENALTY OF LAW THAT THE RESULTS OF ANY ANALYSES REPORTED AS LESS THAN DETECTABLE IN THIS APPLICATION OR IN ATTACHMENTS THERETO WERE PERFORMED USING THE EPA APPROVED TEST METHOD HAVING THE LOWEST DETECTION LIMIT READILY ACHIEVABLE FOR THE SUBSTANCE TESTED."

SIGNATURE OF RESPONSIBLE OFFICIAL: *Tim Haney* DATE SIGNED: 7/23/15

(TYPE OR PRINT) Tim Haney

NAME OF RESPONSIBLE OFFICIAL: \_\_\_\_\_

OFFICIAL TITLE OF RESPONSIBLE OFFICIAL: Park Superintendent

MAILING ADDRESS: 4403 McLean Dr. Rogersville, AL.

AREA CODE & PHONE NUMBER: 256-247-5466

**SIGNATORY REQUIREMENTS FOR PERMIT APPLICATIONS**

Responsible official is defined as follows:

1. In the case of a corporation, by a principal executive officer of at least the level of vice president, or a manager assigned or delegated in accordance with corporate procedures, with such delegation submitted in writing if required by the Department, who is responsible for manufacturing, production, or operating facilities and is authorized to make management decisions which govern the operation of the regulated facility
2. In the case of a partnership, by a general partner
3. In the case of a sole proprietorship, by the proprietor, or
4. In the case of a municipal, state, federal, or other public facility, by either a principal executive officer, or a ranking elected official.
5. In the case of a private or semi-public facility, the responsible official is either a principal executive officer or the owner of the corporation or other entity.

# Attachment 1 to Supplementary Form ADEM Form 311

## *Alternatives Analysis*

*Applicant/Project:* \_\_\_\_\_

All new or expanded discharges (except discharges eligible for coverage under general permits) covered by the NPDES permitting program are subject to the provisions of ADEM's antidegradation policy. Applicants for such discharges to Tier 2 waters are required to demonstrate "... that the proposed discharge is necessary for important economic or social development." As a part of this demonstration, the applicant must complete an evaluation of the discharge alternatives listed below, including a calculation of the total annualized project costs for each technically feasible alternative (using ADEM Form 312 for public-sector projects and ADEM Form 313 for private-sector projects). Alternatives with total annualized project costs that are less than 110% of the total annualized project costs for the Tier 2 discharge proposal are considered viable alternatives.

| Alternative   | Viable | Non-Viable | Comment |
|---|--------|------------|---------|
| 1 Land Application  |        |            |         |
| 2 Pretreatment/Discharge to POTW  |        |            |         |
| 3 Relocation of Discharge   |        |            |         |
| 4 Reuse/Recycle   |        |            |         |
| 5 Process/Treatment Alternatives  |        |            |         |
| 6 On-site/Sub-surface Disposal  |        |            |         |
| <i>(other project-specific alternatives considered by the applicant; attach additional sheets if necessary)</i> |        |            |         |
| 7   |        |            |         |
| 8   |        |            |         |
| 9   |        |            |         |

*Pursuant to ADEM Administrative Code Rule 335-6-3-.04, I certify on behalf of the applicant that I have completed an evaluation of the discharge alternatives identified above, and reached the conclusions indicated.*

*Signature:* \_\_\_\_\_  
*(Professional Engineer)*

*Date:* \_\_\_\_\_

*(Supporting documentation to be attached, referenced, or otherwise handled as appropriate.)*

## Attachment 2 to Supplementary Form

### Calculation of Total Annualized Project Costs for Public-Sector Projects

#### A. Capital Costs

Capital Cost of Project \$ \_\_\_\_\_

Other One-Time Costs of Project (Please List, if any):

\_\_\_\_\_ \$ \_\_\_\_\_  
 \_\_\_\_\_ \$ \_\_\_\_\_  
 \_\_\_\_\_ \$ \_\_\_\_\_

**Total Capital Costs (Sum column)** \$ \_\_\_\_\_ (1)

Portion of Capital Costs to be Paid for with Grant Monies \$ \_\_\_\_\_ (2)

Capital Costs to be Financed [Calculate: (1) – (2) ] \$ \_\_\_\_\_ (3)

Type of Financing (e.g., G.O. bond, revenue bond, bank loan) \_\_\_\_\_

Interest Rate for Financing (expressed as decimal) \_\_\_\_\_ (i)

Time Period of Financing (in years) \_\_\_\_\_ (n)

Annualization Factor =  $\frac{i}{(1+i)^n - 1} + i$  \_\_\_\_\_ (4)

**Annualized Capital Cost** [Calculate: (3) x (4) ] \_\_\_\_\_ (5)

#### B. Operating and Maintenance Costs

Annual Costs of Operation and Maintenance (including but not limited to: monitoring, inspection, permitting fees, waste disposal charges, repair, administration and replacement.) (Please list below.)

\_\_\_\_\_ \$ \_\_\_\_\_  
 \_\_\_\_\_ \$ \_\_\_\_\_  
 \_\_\_\_\_ \$ \_\_\_\_\_  
 \_\_\_\_\_ \$ \_\_\_\_\_

**Total Annual O & M Costs (Sum column)** \$ \_\_\_\_\_ (6)

#### C. Total Annual Cost of Pollution Control Project

Total Annual Cost of Pollution Control Project [ (5) + (6) ] \$ \_\_\_\_\_ (7)

## Attachment 3 to Supplementary Form ADEM Form 313

### Calculation of Total Annualized Project Costs for Private-Sector Projects

|  |    |                    |
|--|----|--------------------|
| Capital Costs to be Financed (Supplied by applicant)   | \$ | _____ (1)          |
| Interest rate for Financing (Expressed as a decimal)   |    | _____ (i)          |
| Time Period of Financing (Assume 10 years*)  |    | _____ 10 years (n) |
| Annualization Factor = $\frac{i}{(1+i)^{10} - 1} + i$  |    | _____ (2)          |
| Annualized Capital Cost [Calculate: (1) x (2) ]  | \$ | _____ (3)          |
| Annual Cost of Operation and Maintenance<br>(including but not limited to monitoring, inspection, permitting fees, waste disposal charges, repair, administration and replacement)** | \$ | _____ (4)          |
| <b>Total Annual Cost of Pollution Control Project [ (3) + (4) ]</b>  | \$ | _____ (5)          |

\* While actual payback schedules may differ across projects and companies, assume equal annual payments over a 10-year period for consistency in comparing projects.

\*\* For recurring costs that occur less frequently than once a year, pro rate the cost over the relevant number of years (e.g., for pumps replaced once every three years, include one-third of the cost in each year).

## Attachment 4 to Supplementary Form

**NPDES PROGRAM  
PERMIT APPLICATION FORMS  
ALABAMA DEPARTMENT OF ENVIRONMENTAL MANAGEMENT**

| <b>TYPE DISCHARGE</b>  | <b>ADEM FORMS</b>  | <b>EPA FORMS</b>  |
|--|--|---|
| New or existing once through non-contact cooling water and/or cooling tower blowdown, and/or sanitary wastewater (non-process wastewater only). Note: POTWs and privately owned domestic treatment works should use Form 2A. | Supplemental Information Form 187 – (Industrial) or Form 188 (Municipal) | Forms 1 and 2E  |
| Existing discharges of process wastewater  | Supplemental Information Form 187 – (Industrial) or Form 188 (Municipal) | Forms 1 and 2C  |
| New discharges of process wastewater   | Supplemental Information Form 187 – (Industrial) or Form 188 (Municipal) | Forms 1 and 2D  |
| New or existing discharges composed entirely of stormwater meeting the EPA definition of stormwater associated with industrial activity  | Supplemental Information Form 187 – (Industrial) or Form 188 (Municipal) | Forms 1 and 2F  |
| New or existing discharges composed of stormwater meeting the EPA definition of stormwater associated with industrial activity, and any other non-stormwater discharges.   | Supplemental Information Form 187 – (Industrial) or Form 188 (Municipal) | Forms 1 and 2F and, as appropriate, Forms 2E, 2E, 2C, and/or 2D |
| New or existing Publicly-Owned Treatment Works (POTWs) and Privately-Owned Treatment Works composed of sanitary wastewater   | Supplemental Information Form 187 – (Industrial) or Form 188 (Municipal) | Forms 1 and 2A  |
| New or existing land application of process wastewater. Form 2F is required for stormwater runoff from the land application site, if the site is not completely bermed to prevent runoff.                                    | Supplemental Information Form 187 – (Industrial)                         | Forms 1, 2F, and 2C or 2D, as appropriate                       |
| New or existing land application of sanitary wastewater. Form 2F is required for stormwater runoff from the land application site, if the site is not completely bermed to prevent runoff.                                   | Supplemental Information Form 187 – (Industrial) or Form 188 (Municipal) | Forms 1, 2A, and 2F   |

---

Testing requirements: Test procedures for all analyses shall conform to 40 CFR Part 136 or an alternate method specifically approved by the Department. If more than one method of analysis is approved, then the method having the lowest detection level shall be used.

## **Directions to Joe Wheeler South Lagoons**

### **From Florence:**

- Drive East on Highway 72 approx. 14 Miles
- Turn right onto AL 101 for 4.2 miles
- Park Office on your left, lagoons on your right (will need park assistance for entrance)

### **From Hunstville:**

- Drive southwest on I-565 W for approx. 18.6 miles
- Take exit 1 to I-65 N toward Nashville for approximately 11 miles
- Take exit 351 for US-72 for approximately 26.8 miles
- Turn left onto AL 101 for approximately 4.2 miles
- Park Office on your left, lagoons on your right (will need park assistance for entrance)

### **From Birmingham:**

- Drive north on I-65 toward Nashville
- Take exit 351 for US-72 for approximately 26.8 miles
- Turn left onto AL 101 for approximately 4.2 miles
- Park Office on your left, lagoons on your right (will need park assistance for entrance)





South Lagoons

© 2015 Google

GO

Imagery Date: 11/29/2013 34°47'32.02" N 87°22'56.35" W

Joe Wheeler State Park  
South Lagoon Schematic  
(Not To Scale)

