



MAJOR SOURCE OPERATING PERMIT

PERMITTEE: TENNESSEE GAS PIPELINE COMPANY, L.L.C.
FACILITY NAME: COMPRESSOR STATION 550
FACILITY/PERMIT NO.: 710-0019
LOCATION: HAMILTON, MARION COUNTY, ALABAMA

In accordance with and subject to the provisions of the Alabama Air Pollution Control Act of 1971, Ala. Code §§ 22 28 1 to 22 28 23, as amended, the Alabama Environmental Management Act, Ala. Code §§ 22 22A 1 to 22 22A 17, as amended, and rules and regulations adopted there under, and subject further to the conditions set forth in this permit, the Permittee is hereby authorized to construct, install and use the equipment, device or other article described above.

*Pursuant to the **Clean Air Act of 1990**, all conditions of this permit are federally enforceable by EPA, the Alabama Department of Environmental Management, and citizens in general. Those provisions which are not required under the **Clean Air Act of 1990** are considered to be state permit provisions and are not federally enforceable by EPA and citizens in general. Those provisions are contained in separate sections of this permit.*

Issuance Date: DRAFT
Effective Date: November 30, 2019
Expiration Date: November 29, 2024

TABLE OF CONTENTS

GENERAL PERMIT PROVISOS	1
1. <u>Transfer</u>	1
2. <u>Renewals</u>	1
3. <u>Severability Clause</u>	1
4. <u>Compliance</u>	1
5. <u>Termination for Cause</u>	1
6. <u>Property Rights</u>	2
7. <u>Submission of Information</u>	2
8. <u>Economic Incentives, Marketable Permits, and Emissions Trading</u>	2
9. <u>Certification of Truth, Accuracy, and Completeness</u>	2
10. <u>Inspection and Entry</u>	2
11. <u>Compliance Provisions</u>	3
12. <u>Compliance Certification</u>	3
13. <u>Reopening for Cause</u>	4
14. <u>Additional Rules and Regulations</u>	4
15. <u>Equipment Maintenance or Breakdown</u>	4
16. <u>Operation of Capture and Control Devices</u>	5
17. <u>Obnoxious Odors</u>	5
18. <u>Fugitive Dust</u>	5
19. <u>Additions and Revisions</u>	6
20. <u>Recordkeeping Requirements</u>	6
21. <u>Reporting Requirements</u>	6
22. <u>Emission Testing Requirements</u>	7
23. <u>Payment of Emission Fees</u>	7
24. <u>Other Reporting and Testing Requirements</u>	8
25. <u>Title VI Requirements (Refrigerants)</u>	8
26. <u>Chemical Accidental Prevention Provisions</u>	8
27. <u>Display of Permit</u>	9
28. <u>Circumvention</u>	9
29. <u>Visible Emissions</u>	9
30. <u>Fuel-Burning Equipment</u>	9
31. <u>Process Industries – General</u>	9
32. <u>Averaging Time for Emission Limits</u>	9
33. <u>Open Burning</u>	10
34. <u>Permit Shield</u>	10
EMISSION UNIT NOS. 001, 002, 003, AND 004 (ENGINES 1A-4A)	11
<i>Summary Page</i>	11
<i>Unit Specific Provisos</i>	12
1. <u>Applicability</u>	12
2. <u>Emission Standards</u>	12
3. <u>Compliance and Performance Test Methods and Procedures</u>	12
4. <u>Emission Monitoring</u>	13
5. <u>Recordkeeping and Reporting Requirements</u>	13

TABLE OF CONTENTS

EMISSION UNIT NO. 005 (ENGINE 1B)..... 15

Summary Page 15

Unit Specific Provisos..... 16

1. Applicability 16

2. Emission Standards..... 16

3. Compliance and Performance Test Methods and Procedures 16

4. Emission Monitoring..... 16

5. Recordkeeping and Reporting Requirements..... 16

EMISSION UNIT NO. 007 (AUX 1A) 17

Summary Page 17

Unit Specific Provisos..... 18

1. Applicability 18

2. Emission Standards..... 18

3. Compliance and Performance Test Methods and Procedures 18

4. Emission Monitoring..... 18

5. Recordkeeping and Reporting Requirements..... 18

EMISSION UNIT NO. 008 (FUEL GAS HEATER) 19

Summary Page 19

Unit Specific Provisos..... 20

1. Applicability 20

2. Emission Standards..... 20

3. Compliance and Performance Test Methods and Procedures 20

4. Emission Monitoring..... 20

5. Recordkeeping and Reporting Requirements..... 20

General Permit Provisos

Federally Enforceable Provisos	Regulations
<p>1. <u>Transfer</u></p> <p>This permit is not transferable, whether by operation of law or otherwise, either from one location to another, from one piece of equipment to another, or from one person to another, except as provided in ADEM Admin. Code r. 335-3-16-.13(1)(a)5.</p>	ADEM Admin. Code r. 335-3-16-.02(6)
<p>2. <u>Renewals</u></p> <p>An application for permit renewal shall be submitted at least six (6) months, but not more than eighteen (18) months, before the date of expiration of this permit.</p> <p>The source for which this permit is issued shall lose its right to operate upon the expiration of this permit unless a timely and complete renewal application has been submitted within the time constraints listed in the previous paragraph.</p>	ADEM Admin. Code r. 335-3-16-.12(2)
<p>3. <u>Severability Clause</u></p> <p>The provisions of this permit are declared to be severable and if any section, paragraph, subparagraph, subdivision, clause, or phrase of this permit shall be adjudged to be invalid or unconstitutional by any court of competent jurisdiction, the judgment shall not affect, impair, or invalidate the remainder of this permit, but shall be confined in its operation to the section, paragraph, subparagraph, subdivisions, clause, or phrase of this permit that shall be directly involved in the controversy in which such judgment shall have been rendered.</p>	ADEM Admin. Code r. 335-3-16-.05(e)
<p>4. <u>Compliance</u></p> <p>(a) The permittee shall comply with all conditions of ADEM Admin. Code 335-3. Noncompliance with this permit will constitute a violation of the Clean Air Act of 1990 and ADEM Admin. Code 335-3 and may result in an enforcement action; including but not limited to, permit termination, revocation and reissuance, or modification; or denial of a permit renewal application by the permittee.</p> <p>(b) The permittee shall not use as a defense in an enforcement action that maintaining compliance with conditions of this permit would have required halting or reducing the permitted activity.</p>	ADEM Admin. Code r. 335-3-16-.05(f) ADEM Admin. Code r. 335-3-16-.05(g)
<p>5. <u>Termination for Cause</u></p> <p>This permit may be modified, revoked, reopened, and reissued, or terminated for cause. The filing of a request by the permittee for a permit modification, revocation and reissuance, or termination, or of a notification of planned changes or anticipated noncompliance will not stay any permit condition.</p>	ADEM Admin. Code r. 335-3-16-.05(h)

General Permit Provisos

Federally Enforceable Provisos	Regulations
<p>6. <u>Property Rights</u></p> <p>The issuance of this permit does not convey any property rights of any sort, or any exclusive privilege.</p>	ADEM Admin. Code r. 335-3-16-.05(i)
<p>7. <u>Submission of Information</u></p> <p>The permittee must submit to the Air Division, within 30 days or for such other reasonable time as the Air Division may set, any information that the Air Division may request in writing to determine whether cause exists for modifying, revoking and reissuing, or terminating this permit or to determine compliance with this permit. Upon receiving a specific request, the permittee shall also furnish to the Air Division copies of records required to be kept by this permit.</p>	ADEM Admin. Code r. 335-3-16-.05(j)
<p>8. <u>Economic Incentives, Marketable Permits, and Emissions Trading</u></p> <p>No permit revision shall be required, under any approved economic incentives, marketable permits, emissions trading and other similar programs or processes for changes that are provided for in this permit.</p>	ADEM Admin. Code r. 335-3-16-.05(k)
<p>9. <u>Certification of Truth, Accuracy, and Completeness</u></p> <p>Any application form, report, test data, monitoring data, or compliance certification submitted pursuant to this permit shall contain certification by a responsible official of truth, accuracy, and completeness. This certification shall state that, based on information and belief formed after reasonable inquiry, the statements and information in the document are true, accurate and complete.</p>	ADEM Admin. Code r. 335-3-16-.07(a)
<p>10. <u>Inspection and Entry</u></p> <p>Upon presentation of credentials and other documents as may be required by law, the permittee shall allow authorized representatives of the Alabama Department of Environmental Management and EPA to conduct the following:</p> <ul style="list-style-type: none">(a) Enter upon the permittee's premises where a source is located or emissions-related activity is conducted, or where records must be kept pursuant to the conditions of this permit;(b) Review and/or copy, at reasonable times, any records that must be kept pursuant to the conditions of this permit;(c) Inspect, at reasonable times, this facility's equipment (including monitoring equipment and air pollution control equipment), practices, or operations regulated or required pursuant to this permit;	ADEM Admin. Code r. 335-3-16-.07(b)

General Permit Provisos

Federally Enforceable Provisos

Regulations

- (d) Sample or monitor, at reasonable times, substances or parameters for the purpose of assuring compliance with this permit or other applicable requirements.

11. Compliance Provisions

- (a) The permittee shall continue to comply with the applicable requirements with which the company has certified that it is already in compliance.
- (b) The permittee shall comply in a timely manner with applicable requirements that become effective during the term of this permit.

ADEM Admin. Code r.
335-3-16-.07(c)

12. Compliance Certification

The Permittee shall submit a complete and accurate compliance certification by **January 29th** of each year for each annual reporting period of this permit (November 30th – November 29th).

ADEM Admin. Code r.
335-3-16-.07(e)

- (a) The compliance certification shall include the following:
- (1) The identification of each term or condition of this permit that is the basis of the certification;
 - (2) The compliance status;
 - (3) The method(s) used for determining the compliance status of the source, currently and over the reporting period consistent with ADEM Admin. Code r. 335-3-16-.05(c) (Monitoring and Recordkeeping Requirements);
 - (4) Whether compliance has been continuous or intermittent;
 - (5) Such other facts as the Air Division may require to determine the compliance status of the source;
- (b) The compliance certification shall be submitted to:

Alabama Department of Environmental Management
Air Division
P.O. Box 301463
Montgomery, AL 36130-1463

and to:

Director, Air Enforcement and Toxics Branch
EPA Region 4
61 Forsyth Street, SW
Atlanta, GA 30303

General Permit Provisos

Federally Enforceable Provisos

Regulations

13. Reopening for Cause

Under any of the following circumstances, this permit will be reopened prior to the expiration of the permit:

- (a) Additional applicable requirements under the Clean Air Act of 1990 become applicable to the permittee with a remaining permit term of three (3) or more years. Such a reopening shall be completed not later than eighteen (18) months after promulgation of the applicable requirement. No such reopening is required if the effective date of the requirement is later than the date on which this permit is due to expire.
- (b) Additional requirements (including excess emissions requirements) become applicable to an affected source under the acid rain program. Upon approval by the Administrator, excess emissions offset plans shall be deemed to be incorporated into this permit.
- (c) The Department or EPA determines that this permit contains a material mistake or that inaccurate statements were made in establishing the emissions standards or other terms or conditions of this permit.
- (d) The Administrator or the Department determines that this permit must be revised or revoked to assure compliance with the applicable requirements.

ADEM Admin. Code r.
335-3-16-.13(5)

14. Additional Rules and Regulations

This permit is issued on the basis of Rules and Regulations existing on the date of issuance. In the event additional Rules and Regulations are adopted, it shall be the permit holder's responsibility to comply with such rules.

§22-28-16(d), Code of Alabama 1975, as amended

15. Equipment Maintenance or Breakdown

- (a) In case of shutdown of air pollution control equipment (which operates pursuant to any permit issued by the Director) for necessary scheduled maintenance, the intent to shut down such equipment shall be reported to the Air Division at least (24) hours prior to the planned shutdown, unless such shutdown is accompanied by the shutdown of the source which such equipment is intended to control. Such prior notice shall include, but is not limited to the following:
 - (1) Identification of the specific facility to be taken out of service as well as its location and permit number;
 - (2) The expected length of time that the air pollution control equipment will be out of service;
 - (3) The nature and quality of emissions of air contaminants likely to occur during the shutdown period;

ADEM Admin. Code r.
335-3-1-.07(1),(2)

General Permit Provisos

Federally Enforceable Provisos	Regulations
<p>(4) Measures such as the use of off-shift labor and equipment that will be taken to minimize the length of the shutdown period;</p> <p>(5) The reasons that it would be impossible or impractical to shut down the sources operation during the maintenance period.</p> <p>(b) In the event that there is a breakdown of equipment or upset of process in such a manner as to cause, or is expected to cause, increased emissions of air contaminants which are above an applicable standard, the person responsible for such equipment shall notify the Director within 24 hours or the next working day and provide a statement giving all pertinent facts, including the estimated duration of the breakdown. The Director will be notified when the breakdown has been corrected.</p>	
<p>16. <u>Operation of Capture and Control Devices</u></p> <p>All air pollution control devices and capture systems for which this permit is issued shall be maintained and operated at all times in a manner so as to minimize the emissions of air contaminants. Procedures for ensuring that the above equipment is properly operated and maintained so as to minimize the emission of air contaminants shall be established.</p>	<p>§22-28-16(d), <u>Code of Alabama 1975</u>, as amended</p>
<p>17. <u>Obnoxious Odors</u></p> <p>This permit is issued with the condition that, should obnoxious odors arising from the plant operations be verified by Air Division inspectors, measures to abate the odorous emissions shall be taken upon a determination by the Alabama Department of Environmental Management that these measures are technically and economically feasible.</p>	<p>ADEM Admin. Code r. 335-3-1-.08</p>
<p>18. <u>Fugitive Dust</u></p> <p>(a) Precautions shall be taken to prevent fugitive dust emanating from plant roads, grounds, stockpiles, screens, dryers, hoppers, ductwork, etc.</p> <p>(b) Plant or haul roads and grounds will be maintained in the following manner so that dust will not become airborne. A minimum of one, or a combination, of the following methods shall be utilized to minimize airborne dust from plant or haul roads and grounds:</p> <p>(1) By the application of water any time the surface of the road is sufficiently dry to allow the creation of dust emissions by the act of wind or vehicular traffic;</p> <p>(2) By reducing the speed of vehicular traffic to a point below that at which dust emissions are created;</p> <p>(3) By paving;</p>	<p>ADEM Admin. Code r. 335-3-4-.02</p>

General Permit Provisos

Federally Enforceable Provisos	Regulations
<p>(4) By the application of binders to the road surface at any time the road surface is found to allow the creation of dust emissions.</p> <p>Should one, or a combination, of the above methods fail to adequately reduce airborne dust from plant or haul roads and grounds, alternative methods shall be employed, either exclusively or in combination with one or all of the above control techniques, so that dust will not become airborne. Alternative methods shall be approved by the Air Division prior to utilization.</p> <p>19. <u>Additions and Revisions</u></p> <p>Any modifications to this source shall comply with the modification procedures in ADEM Admin. Code r. 335-3-16-.13 or 335-3-16-.14.</p> <p>20. <u>Recordkeeping Requirements</u></p> <p>(a) Records of required monitoring information of the source shall include the following:</p> <ul style="list-style-type: none">(1) The date, place, and time of all sampling or measurements;(2) The date analyses were performed;(3) The company or entity that performed the analyses;(4) The analytical techniques or methods used;(5) The results of all analyses; and(6) The operating conditions that existed at the time of sampling or measurement. <p>(b) Retention of records of all required monitoring data and support information of the source for a period of at least 5 years from the date of the monitoring sample, measurement, report, or application. Support information includes all calibration and maintenance records and all original strip-chart recordings for continuous monitoring instrumentation and copies of all reports required by the permit.</p> <p>21. <u>Reporting Requirements</u></p>	<p>ADEM Admin. Code r. 335-3-16-.13 and 335-3-16-.14</p> <p>ADEM Admin. Code r. 335-3-16-.05(c)2.</p> <p>ADEM Admin. Code r. 335-3-16-.05(c)3.</p>

General Permit Provisos

Federally Enforceable Provisos	Regulations
<p>(b) Deviations from permit requirements shall be reported within 48 hours or 2 working days of such deviations, including those attributable to upset conditions as defined in the permit. The report will include the probable cause of said deviations, and any corrective actions or preventive measures that were taken.</p>	
<p>22. <u>Emission Testing Requirements</u></p>	
<p>Each point of emission which requires testing will be provided with sampling ports, ladders, platforms, and other safety equipment to facilitate testing performed in accordance with procedures established by Part 60 of Title 40 of the Code of Federal Regulations, as the same may be amended or revised.</p>	ADEM Admin. Code r. 335-3-1-.05(3) and 335-3-1-.04(1)
<p>The Air Division must be notified in writing at least 10 days in advance of all emission tests to be conducted and submitted as proof of compliance with the Department's air pollution control rules and regulations.</p>	
<p>To avoid problems concerning testing methods and procedures, the following shall be included with the notification letter:</p>	ADEM Admin. Code r. 335-3-1-.04
<p>(a) The date the test crew is expected to arrive, the date and time anticipated of the start of the first run, how many and which sources are to be tested, and the names of the persons and/or testing company that will conduct the tests.</p>	
<p>(b) A complete description of each sampling train to be used, including type of media used in determining gas stream components, type of probe lining, type of filter media, and probe cleaning method and solvent to be used (if test procedures requires probe cleaning).</p>	
<p>(c) A description of the process(es) to be tested including the feed rate, any operating parameters used to control or influence the operations, and the rated capacity.</p>	
<p>(d) A sketch or sketches showing sampling point locations and their relative positions to the nearest upstream and downstream gas flow disturbances.</p>	
<p>A pretest meeting may be held at the request of the source owner or the Air Division. The necessity for such a meeting and the required attendees will be determined on a case-by-case basis.</p>	ADEM Admin. Code r. 335-3-1-.04
<p>All test reports must be submitted to the Air Division within 30 days of the actual completion of the test unless an extension of time is specifically approved by the Air Division.</p>	
<p>23. <u>Payment of Emission Fees</u></p>	
<p>(a) The permittee shall remit the annual Operating Permit Fees required by ADEM Admin. Code r. 335-1-7-.04 according to the schedule in ADEM Admin. Code r. 335-1-7-.05.</p>	ADEM Admin. Code r. 335-1-7-.04

General Permit Provisos

Federally Enforceable Provisos	Regulations
<p>(b) The permittee shall submit its estimate of actual emissions for the previous calendar year according to the schedule in ADEM Admin. Code r. 335-1-7-.05.</p>	ADEM Admin. Code r. 335-1-7-.05
<p>24. <u>Other Reporting and Testing Requirements</u></p>	
<p>Submission of other reports regarding monitoring records, fuel analyses, operating rates, and equipment malfunctions may be required as authorized in the Department's air pollution control rules and regulations. The Department may require emission testing at any time.</p>	ADEM Admin. Code r. 335-3-1-.04(1)
<p>25. <u>Title VI Requirements (Refrigerants)</u></p>	
<p>Any facility having appliances or refrigeration equipment, including air conditioning equipment, which use Class I or Class II ozone-depleting substances as listed in 40 CFR Part 82, Subpart A, Appendices A and B, shall service, repair, and maintain such equipment according to the work practices, personnel certification requirements, and certified recycling and recovery equipment specified in 40 CFR Part 82, Subpart F.</p>	ADEM Admin. Code r. 335-3-16-.05(a)
<p>No person shall knowingly vent or otherwise release any Class I or Class II substance into the environment during the repair, servicing, maintenance, or disposal of any device except as provided in 40 CFR Part 82, Subpart F.</p>	
<p>The responsible official shall comply with all reporting and recordkeeping requirements of 40 CFR §82.166. Reports shall be submitted to the US EPA and the Department as required.</p>	
<p>26. <u>Chemical Accidental Prevention Provisions</u></p>	
<p>If a chemical listed in Table 1 of 40 CFR §68.130 is present in a process in quantities greater than the threshold quantity listed in Table 1, then:</p>	40 CFR Part 68
<p>(a) The owner or operator shall comply with the provisions in 40 CFR Part 68.</p>	
<p>(b) The owner or operator shall submit one of the following:</p>	
<p>(1) A compliance schedule for meeting the requirements of 40 CFR Part 68 by the date provided in 40 CFR §68.10(a) or,</p>	
<p>(2) A certification statement that the source is in compliance with all requirements of 40 CFR Part 68, including the registration and submission of the Risk Management Plan.</p>	

General Permit Provisos

Federally Enforceable Provisos	Regulations
<p><u>27. Display of Permit</u></p> <p>This permit shall be kept under file or on display at all times at the site where the facility for which the permit is issued is located and will make the permit readily available for inspection by any or all persons who may request to see it.</p>	<p>ADEM Admin. Code r. 335-3-16-.02(2)</p>
<p><u>28. Circumvention</u></p> <p>No person shall cause or permit the installation or use of any device or any means which, without resulting in the reduction in the total amount of air contaminant emitted, conceals or dilutes any emission of air contaminant which would otherwise violate the Division 3 rules and regulations.</p>	<p>ADEM Admin. Code r. 335-3-1-.10</p>
<p><u>29. Visible Emissions</u></p> <p>Unless otherwise specified in the Unit Specific provisos of this permit, any source of particulate emissions shall not discharge more than one 6-minute average opacity greater than 20% in any 60-minute period. At no time shall any source discharge a 6-minute average opacity of particulate emissions greater than 40%. Opacity will be determined by 40 CFR Part 60, Appendix A, Method 9, unless otherwise specified in the Unit Specific provisos of this permit.</p>	<p>ADEM Admin. Code r. 335-3-4-.01(1)&(2)</p>
<p><u>30. Fuel-Burning Equipment</u></p> <p>Unless otherwise specified in the Unit Specific provisos of this permit, no fuel-burning equipment may discharge particulate emissions in excess of the emissions specified in ADEM Admin. Code r. 335-3-4-.03.</p> <p>Unless otherwise specified in the Unit Specific provisos of this permit, no fuel-burning equipment may discharge sulfur dioxide emissions in excess of the emissions specified in ADEM Admin. Code r. 335-3-5-.01.</p>	<p>ADEM Admin. Code r. 335-3-4-.03</p> <p>ADEM Admin. Code r. 335-3-5-.01</p>
<p><u>31. Process Industries – General</u></p> <p>Unless otherwise specified in the Unit Specific provisos of this permit, no process may discharge particulate emissions in excess of the emissions specified in ADEM Admin. Code r. 335-3-4-.04.</p>	<p>ADEM Admin. Code r. 335-3-4-.04</p>
<p><u>32. Averaging Time for Emission Limits</u></p> <p>Unless otherwise specified in the permit, the averaging time for the emission limits listed in this permit shall be the nominal time required by the specific test method.</p>	<p>ADEM Admin. Code r. 335-3-1-.05</p>

General Permit Provisos

Federally Enforceable Provisos	Regulations
<p>33. <u>Open Burning</u></p> <p>Precautions should be taken to ensure that no person shall ignite, cause to ignite, permit to be ignited, or maintain any open fire in such a manner as to cause the Department's rules and regulations applicable to open burning to be violated.</p>	<p>ADEM Admin. Code r. 335-3-3-.01</p>
<p>34. <u>Permit Shield</u></p> <p>A Permit Shield exists under this operating permit in accordance with ADEM Admin. Code r. 335-3-16-.10 in that compliance with the conditions of this permit shall be deemed compliance with any applicable requirements as of the date of permit issuance, provided that such applicable requirements are included and are specifically identified in this operating permit.</p>	<p>ADEM Admin. Code r. 335-3-16-.10</p>

DRAFT

Emission Unit Nos. 001, 002, 003, and 004 (Engines 1A-4A)

Summary Page

Description: Four (4) 5,500 hp Clark TCV16 2-stroke, lean-burn natural gas-fired reciprocating engines

Permitted Operating Schedule: $\frac{24 \text{ Hours}}{\text{Day}} \times \frac{365 \text{ Days}}{\text{Year}} = \frac{8760 \text{ Hours}}{\text{Year}}$

Emission limitations:

Emission Point Nos.	Description	Pollutant	Emission limit	Regulation
ENG 1A-4A	Four (4) 5,500 hp Clark TCV16 2-stroke, lean-burn natural gas-fired reciprocating engines	NO _x	66.69 lb/hr, each	ADEM Admin. Code r. 3-8-.04
		CO	30.80 lb/hr, each	ADEM Admin. Code r. 3-14-.04
		VOC	N/A	N/A
		SO ₂	N/A	N/A
		PM	N/A	N/A
		HAP	N/A	N/A

**Emission Unit Nos. 001, 002, 003, and 004 (Engines 1A-4A)
Unit Specific Provisos**

Federally Enforceable Provisos	Regulations
1. <u>Applicability</u>	
(a) These units are subject to the applicable requirements of ADEM Admin. Code r. 335-3-16-.03, "Major Source Operating Permits."	ADEM Admin. Code r. 335-3-16-.03
(a) These units are subject to the applicable requirements of ADEM Admin. Code r. 335-3-8-.04, Standards for Stationary Reciprocating Internal Combustion Engines	ADEM Admin. Code r. 335-3-8-.04
(b) These units are affected sources under 40 CFR Part 63, Subpart ZZZZ, the National Emission Standards for Hazardous Air Pollutants for Stationary Reciprocating Internal Combustion Engines.	ADEM Admin. Code r. 335-3-11-.06(103)
(c) These units are subject to a synthetic minor source emission limit to restrict their potential to emit below the applicability threshold established at ADEM Admin. Code r. 335-3-14-.04, Air Permits Authorizing Construction in Clean Areas [Prevention of Significant Deterioration (PSD)].	ADEM Admin. Code r. 335-3-14-.04
2. <u>Emission Standards</u>	
(a) The permittee shall not cause or allow emissions of nitrogen oxides (NO _x) from each unit to exceed 66.69 lb/hr.	ADEM Admin. Code r. 335-3-8-.04
(b) The permittee shall not cause or allow emissions of carbon monoxide (CO) from each unit to exceed 30.80 lb/hr.	ADEM Admin. Code r. 335-3-14-.04
3. <u>Compliance and Performance Test Methods and Procedures</u>	
(a) Compliance with the nitrogen oxides (NO _x) emission rate of these units shall be determined by Reference Methods 1, 2, 3 and 4 or 19, and Reference Method 7E in Appendix A of 40 CFR 60. Conditional Test Method (CTM) 034 (portable analyzer) may be utilized in accordance with a protocol/method approved in advance by the Air Division. Alternate test methods may be used provided prior approval by the Air Division is granted.	ADEM Admin. Code r. 335-3-1-.05 & ADEM Admin. Code r. 335-3-8-.04
(b) Compliance with the carbon monoxide (CO) emission rate of these units shall be determined by Reference Methods 1, 2, 3 and 4 or 19, and Reference Method 10 in Appendix A of 40 CFR 60. Conditional Test Method (CTM) 034 (portable analyzer) may be utilized in accordance with a protocol/method approved in advance by the Air Division. Alternate test methods may be used provided prior approval by the Air Division is granted.	ADEM Admin. Code r. 335-3-1-.05

Federally Enforceable Provisos	Regulations
<p>4. <u>Emission Monitoring</u></p> <p>(a) For each unit, the permittee shall conduct emissions testing for NO_x and CO once per year (defined as October 1st - September 30th) during which the unit operates 250 hours or more for the purpose of production (i.e. the compression/transmission of natural gas). The Emission testing shall be conducted with a minimum of three (3) calendar months elapsing between tests. For each unit, the first emission testing conducted following the effective date of this permit shall be conducted in accordance with an approved EPA Reference Method for that pollutant. All subsequent emission testing during the permit term may be conducted using either an approved EPA Reference Method for that pollutant or utilizing CTM-034 with a portable analyzer in accordance with a protocol/method approved in advance by the Air Division.</p> <p>(b) For any ozone season (May 1st- September 30th) in which a unit operates 250 hours or more for the purpose of production (i.e. the compression/transmission of natural gas), the permittee shall conduct emissions testing for NO_x on that unit at least once during that ozone season or at least once during the six-month period preceding the first day of the ozone season. For each unit, the first NO_x ozone emission testing conducted following the effective date of this permit shall be conducted in accordance with an approved EPA Reference Method for that pollutant. All subsequent emission testing during the permit term may be conducted using either an approved EPA Reference Method for that pollutant or utilizing CTM-034 with a portable analyzer in accordance with a protocol/method approved in advance by the Air Division.</p> <p>(c) The permittee shall only fire natural gas in these units.</p>	<p>ADEM Admin. Code r. 335-3-16-.05(c)</p> <p>ADEM Admin. Code r. 335-3-8-.04(6)</p> <p>ADEM Admin. Code r. 335-3-16-.05(c)</p>
<p>5. <u>Recordkeeping and Reporting Requirements</u></p> <p>(a) The permittee shall submit a Semiannual Monitoring Report, as required by General Permit Proviso No. 21(a), no later than 60 days after the end of each semiannual period (November 30th-May 29th and May 30th -November 29th). The report shall include a statement addressing whether only natural gas was fired in these units and all emission monitoring was conducted as required during the reporting period. If all emission monitoring was not conducted, the report shall explain the reason(s) why it was not performed.</p> <p>(b) The permittee shall submit the results of emission testing within 30 days of the actual completion of the test unless the Air Division specifically approves an extension of time.</p>	<p>ADEM Admin. Code r. 335-3-16-.05(c)</p> <p>ADEM Admin. Code r. 335-3-8-.04(7)(c)</p>

Federally Enforceable Provisos	Regulations
<p>(c) The permittee shall maintain the following records for these units for each ozone season (May 1st – September 30th). These records shall be compiled into a permanent form suitable for inspection within 30 days of the end of each ozone season and shall be maintained on-site for a period of five years from the date of generation of each record.</p> <ul style="list-style-type: none"> (i) Identification and location of the unit; (ii) Calendar date of record; (iii) Number of hours operated during the ozone season; (iv) Type and quantity of fuel used during the ozone season; (v) Date and results of each emission-related inspection and a summary of any emissions-related maintenance, if taken; (vi) Results of all emission tests; and (vii) Any additional information described in the permittee's Phase II NO_x SIP Call Compliance Plan. 	<p>ADEM Admin. Code r. 335-3-8-.04(7)(c)</p>

Emission Unit No. 005 (Engine 1B)

Summary Page

Description: 7,500 hp GE M3752HR natural gas-fired combustion turbine

$$\text{Permitted Operating Schedule: } \frac{24 \text{ Hours}}{\text{Day}} \times \frac{365 \text{ Days}}{\text{Year}} = \frac{8760 \text{ Hours}}{\text{Year}}$$

Emission limitations:

Emission Point No.	Description	Pollutant	Emission limit	Regulation
ENG1B	7,500 hp GE M3752HR natural gas-fired combustion turbine	NO _x	N/A	N/A
		CO	N/A	N/A
		VOC	N/A	N/A
		SO ₂	N/A	N/A
		PM	N/A	N/A
		HAP	N/A	N/A

**Emission Unit No. 005 (Engine 1B)
Unit Specific Provisos**

Federally Enforceable Provisos	Regulations
<p>1. <u>Applicability</u></p> <p>(a) This unit is subject to the applicable requirements of ADEM Admin. Code r. 335-3-16-.03, “Major Source Operating Permits.”</p> <p>(b) This unit is an affected source under 40 CFR Part 63, Subpart YYYYY, the National Emission Standards for Hazardous Air Pollutants for Stationary Combustion Turbines.</p>	<p>ADEM Admin. Code r. 335-3-16-.03</p> <p>ADEM Admin. Code r. 335-3-11-.06(102)</p>
<p>2. <u>Emission Standards</u></p> <p>None</p>	
<p>3. <u>Compliance and Performance Test Methods and Procedures</u></p> <p>None</p>	
<p>4. <u>Emission Monitoring</u></p> <p>The permittee shall only fire natural gas in this unit.</p>	<p>ADEM Admin. Code r. 335-3-16-.05(c)</p>
<p>5. <u>Recordkeeping and Reporting Requirements</u></p> <p>The permittee shall submit a Semiannual Monitoring Report, as required by General Permit Proviso No. 21(a), no later than 60 days after the end of each semiannual reporting period (November 30th-May 29th and May 30th -November 29th). The report shall include a statement addressing whether only natural gas was fired in this unit and all emission monitoring was conducted as required during the reporting period. If all emission monitoring was not conducted, the report shall explain the reason(s) why it was not performed.</p>	<p>ADEM Admin. Code r. 335-3-16-.05(c)</p>

Emission Unit No. 007 (AUX 1A)

Summary Page

Description: 637 hp Caterpillar G3412 4-stroke, lean-burn natural gas-fired emergency generator

Permitted Operating Schedule: Unlimited for emergency situations with 100 hours per year for maintenance and testing, and up to 50 hours per year in non-emergency situations, but those 50 hours are counted toward the 100 hours per year provided for maintenance and testing.

Emission limitations:

Emission Point No.	Description	Pollutant	Emission limit	Regulation
AUX1A	637 hp Caterpillar G3412 4-stroke, lean-burn natural gas-fired emergency generator	NO _x	N/A	N/A
		CO	N/A	N/A
		VOC	N/A	N/A
		SO ₂	N/A	N/A
		PM	N/A	N/A
		HAP	N/A	N/A

**Emission Unit No. 007 (AUX 1A)
Unit Specific Provisos**

Federally Enforceable Provisos	Regulations
<p>1. <u>Applicability</u></p> <p>(a) This unit is subject to the applicable requirements of ADEM Admin. Code r. 335-3-16-.03, “Major Source Operating Permits.”</p> <p>(b) This unit is an affected source under to 40 CFR 63, Subpart ZZZZ, National Emission Standards for Hazardous Air Pollutants for Stationary Reciprocating Internal Combustion Engines (RICE), and meets the definition for an emergency stationary RICE as provided by §63.6640(f)(1). The permittee shall only operate this unit as an emergency stationary RICE as defined in this standard.</p> <p>2. <u>Emission Standards</u></p> <p>None</p> <p>3. <u>Compliance and Performance Test Methods and Procedures</u></p> <p>None</p> <p>4. <u>Emission Monitoring</u></p> <p>The permittee shall only fire natural gas in this unit.</p> <p>5. <u>Recordkeeping and Reporting Requirements</u></p> <p>(a) The permittee shall submit a Semiannual Monitoring Report, as required by General Permit Proviso No. 21(a), no later than 60 days after the end of each semiannual reporting period (November 30th-May 29th and May 30th –November 29th). The report shall include a statement addressing whether only natural gas was fired in this unit and all emission monitoring was conducted as required during the reporting period. If all emission monitoring was not conducted, the report shall explain the reason(s) why it was not performed.</p> <p>(b) For each period of operation, the length of operation and the reason the engine was in operation during that time. For periods of operation designated as “emergency operation,” the records shall reflect what classified the operation as emergency. Within 15 days of the end of each month, the permittee shall record the hours of operation for the previous month for this unit and calculate these hours on a 12-month rolling total basis.</p>	<p>ADEM Admin. Code r. 335-3-16-.03</p> <p>ADEM Admin. Code r. 335-3-11-.06(103)</p> <p>ADEM Admin. Code r. 335-3-16-.05(c)</p> <p>ADEM Admin. Code r. 335-3-16-.05(c)</p> <p>ADEM Admin. Code r. 335-3-16-.05(c)</p>

Emission Unit No. 008 (Fuel Gas Heater)

Summary Page

Description: One 0.42 MMBtu/hr Peerless 75-8-WT, natural gas-fired fuel gas heater

Permitted Operating Schedule: $\frac{24 \text{ Hours}}{\text{Day}} \times \frac{365 \text{ Days}}{\text{Year}} = \frac{8760 \text{ Hours}}{\text{Year}}$

Emission limitations:

Emission Point No.	Description	Pollutant	Emission limit	Regulation
008	One 0.42 MMBtu/hr Peerless 75-8-WT, natural gas-fired fuel gas heater	NO _x	N/A	N/A
		CO	N/A	N/A
		VOC	N/A	N/A
		SO ₂	N/A	N/A
		PM	N/A	N/A
		HAP	N/A	N/A

Emission Unit No. 008 (Fuel Gas Heater)
Unit Specific Provisos

Federally Enforceable Provisos	Regulations
<p>1. <u>Applicability</u></p> <p>(a) This unit is subject to the applicable requirements of ADEM Admin. Code r. 335-3-16-.03, "Major Source Operating Permits."</p> <p>(b) This unit is subject to the applicable requirements of 40 CFR Part 63, Subpart DDDDD, National Emission Standards for Hazardous Air Pollutants for Major Sources: Industrial, Commercial, and Institutional Boiler and Process Heaters. Pursuant to 40 CFR §63.7495(b) the facility must comply with this rule no later than January 31, 2016.</p>	<p>ADEM Admin. Code r. 335-3-16-.03</p> <p>40 CFR Part 63, Subpart DDDDD and ADEM Admin. Code r. 335-3-11-.06 (107)</p>
<p>2. <u>Emission Standards</u></p> <p>None</p>	
<p>3. <u>Compliance and Performance Test Methods and Procedures</u></p> <p>None</p>	
<p>4. <u>Emission Monitoring</u></p> <p>(a) The permittee shall only fire natural gas in this unit.</p> <p>(b) The permittee shall complete a tune-up on this unit every five years following the January 31, 2016, compliance date as specified in 40 CFR §63.7540(a)(10)(i) through (vi).</p>	<p>ADEM Admin. Code r. 335-3-16-.05(c)</p> <p>40 CFR §63.7500(e)</p>
<p>5. <u>Recordkeeping and Reporting Requirements</u></p> <p>(a) The permittee shall keep a copy of each notification and report submitted to comply with 40 CFR Part 63, Subpart DDDDD, including all documentation supporting any Initial Notification or Notification of Compliance or compliance report submitted according to the requirements in 40 CFR §63.10(b)(2)(xiv).</p> <p>(b) The permittee shall submit a compliance report every five years after the January 31, 2016, compliance date containing the information specified in 40 CFR §63.7550(c). The compliance report must be postmarked or submitted no later than January 31 following the end of the five year period.</p>	<p>40 CFR §63.7555 and 40 CFR §63.10</p> <p>40 CFR §63.7550</p>

Federally Enforceable Provisos	Regulations
<p>(c) The permittee shall submit a Semiannual Monitoring Report, as required by general Permit Proviso No. 21(a), no later than 60 days after the end of each semiannual reporting period (November 30th-May 29th and May 30th -November 29th). The report shall include a statement addressing whether only natural gas was fired in this unit during the reporting period.</p>	<p>ADEM Admin. Code r. 335-3-16-.05(c)</p>

DRAFT