



MAJOR SOURCE OPERATING PERMIT

PERMITTEE: TRANSCONTINENTAL GAS PIPE LINE COMPANY, LLC

FACILITY NAME: STATION 90

FACILITY/PERMIT NO.: 105-0007

LOCATION: SWEETWATER, MARENGO COUNTY, ALABAMA

In accordance with and subject to the provisions of the Alabama Air Pollution Control Act of 1971, <u>Ala. Code</u> §§ 22-28-1 to 22-28-23, as amended, the Alabama Environmental Management Act, <u>Ala. Code</u> §§ 22-22A-1 to 22-22A-17, as amended, and rules and regulations adopted there under, and subject further to the conditions set forth in this permit, the Permittee is hereby authorized to construct, install and use the equipment, device or other article described above.

Pursuant to the **Clean Air Act of 1990**, all conditions of this permit are federally enforceable by EPA, the Alabama Department of Environmental Management, and citizens in general. Those provisions which are not required under the **Clean Air Act of 1990** are considered to be state permit provisions and are not federally enforceable by EPA and citizens in general. Those provisions are contained in separate sections of this permit.

Issuance Date:

Effective Date: December 28, 2019

Expiration Date: December 27, 2024

TABLE OF CONTENTS

GENE	RAL PERMIT PROVISOS	1
1.	Transfer	. 1
2.	Renewals	. 1
3.	Severability Clause	. 1
4.	Compliance	. 1
5.	Termination for Cause	. 1
6.	Property Rights	. 2
7.	Submission of Information	. 2
8.	Economic Incentives, Marketable Permits, and Emissions Trading	. 2
9.	Certification of Truth, Accuracy, and Completeness	. 2
10.	Inspection and Entry	. 2
11.	Compliance Provisions	. 3
12.	Compliance Certification	. 3
13.	Reopening for Cause	. 4
14.	Additional Rules and Regulations	. 4
15.	Equipment Maintenance or Breakdown	. 4
16.	Operation of Capture and Control Devices	. 5
	Obnoxious Odors	
18.	Fugitive Dust	. 5
19.	Additions and Revisions	. 6
20.	Recordkeeping Requirements	. 6
21.	Reporting Requirements	. 7
22.	Emission Testing Requirements	. 7
	Payment of Emission Fees	
24.	Other Reporting and Testing Requirements	. 8
25.	Title VI Requirements (Refrigerants)	. 8
26.	Chemical Accidental Prevention Provisions	. 8
27.	Display of Permit	. 9
28.	Circumvention	. 9
29.	Visible Emissions	. 9
30.	Fuel-Burning Equipment	. 9
31.	Process Industries – General	. 9
32.	Averaging Time for Emission Limits	10
33.	Open Burning	10
EN HOO		
	SION UNIT NOS. 001-003 AND 005-007 (MAINLINE UNIT NOS. 1-3 AND 5-7)	
Sui	mmary Page	11
Un	it Specific Provisos	12
	1. Applicability	
	2. Emission Standards	
	Compliance and Performance Test Methods and Procedures Emission Monitoring	
	4. Emission Monitoring5. Recordkeeping and Reporting Requirements	
EMISS	SION UNIT NO. 004 (MAINLINE UNIT NO. 4)	13
Su	mmary Page	13
	it Specific Provisos	
	1. Applicability	
	2. Emission Standards	

3.	Compliance and Performance Test Methods and Procedures	. 14
4.	Emission Monitoring	
5.	Recordkeeping and Reporting Requirements	. 15
EMISSION	UNIT NOS. 008 AND 009 (MAINLINE UNIT NOS. 8 AND 9)	. 17
Summo	ıry Page	. 17
	ecific Provisos	
1.	Applicability	
2.	Emission Standards	
3.	Compliance and Performance Test Methods and Procedures	
4.	Emission Monitoring.	
5.	Recordkeeping and Reporting Requirements	
EMISSION	UNIT NOS. 010 AND 011 (MAINLINE UNIT NOS. 10 AND 11)	. 19
Summo	ıry Page	10
	ecific Provisos	
-		
1.	Applicability	
2. 3.	Emission Standards Compliance and Performance Test Methods and Procedures	
3. 4.	Emission Monitoring	
5.	Recordkeeping and Reporting Requirements	
0.	recordiscepting and reporting requirements	20
EMISSION	UNIT NOS. 012 AND 013 (MAINLINE UNIT NOS. 12 AND 13)	. 21
Summo	ıry Page	. 21
Unit Sp	ecific Provisos	. 22
1.	Applicability	. 22
2.	Emission Standards	
3.	Compliance and Performance Test Methods and Procedures	
4.	Emission Monitoring	
5.	Recordkeeping and Reporting Requirements	. 24
EMISSION	UNIT NO. 014 (MAINLINE UNIT NO. 14)	. 25
Summo	ıry Page	25
	ecific Provisos	
-		
1. 2.	Applicability Emission Standards	
3.	Compliance and Performance Test Methods and Procedures	
3. 4.	Emission Monitoring	
5.	Recordkeeping and Reporting Requirements	. 26
EMISSION	UNIT NO. 015 (MAINLINE UNIT NO. 15)	. 27
Summo	ıry Page	. 27
Unit Sp	ecific Provisos	. 28
1.	Applicability	. 28
2.	Emission Standards	
3.	Compliance and Performance Test Methods and Procedures	
4.	Emission Monitoring	
5.	Recordkeeping and Reporting Requirements	
EMISSION	UNIT NO. 016 (MAINLINE UNIT NO. 16)	. 29
	· · · · · · · · · · · · · · · · · · ·	
	rry Page	
	ecific Provisos	
1.	Applicability	. 30

2.	Emission Standards	30
3.	Compliance and Performance Test Methods and Procedures	30
4.	Emission Monitoring	31
5.	Recordkeeping and Reporting Requirements	31
EMISSIO	N UNIT NO. 018 (MAINLINE UNIT NO. 18)	33
	ary Page	
Unit S _i	pecific Provisos	34
1.	Applicability	
2.	Emission Standards	
3.	Compliance and Performance Test Methods and Procedures	
4.	Emission Monitoring	
5.	Recordkeeping and Reporting Requirements	36
EMISSIO	N UNIT NOS. 019-021 (EMERGENCY UNIT NOS. 1-3)	37
	ary Page	
Unit S _i	pecific Provisos	38
1.	Applicability	38
2.	Emission Standards	
3.	Compliance and Performance Test Methods and Procedures	
4.	Emission Monitoring	
5.	Recordkeeping and Reporting Requirements	40
EMISSIO	N UNIT NO. 024 (EMERGENCY AIR COMPRESSOR UNIT NO. 5)	42
Summ	ary Page	42
Unit Si	pecific Provisos	43
1.	Applicability	43
2.	Emission Standards	
3.	Compliance and Performance Test Methods and Procedures	44
4.	Emission Monitoring	
5.	Recordkeeping and Reporting Requirements	45
EMISSIO	N UNIT NO. 025 (MAINLINE UNIT NO. 17)	47
Summ	ary Page	47
Unit S _i	pecific Provisos	48
1.	Applicability	48
2.	Emission Standards	
3.	Compliance and Performance Test Methods and Procedures	
4.	Emission Monitoring	
5.	Recordkeeping and Reporting Requirements	49

Canaral	Dermit	Provisos
General	rermit	PTOVISOS

General Permit Provisos			
	Federally Enforceable Provisos	Regulations	
1.	<u>Transfer</u>		
	This permit is not transferable, whether by operation of law or otherwise, either from one location to another, from one piece of equipment to another, or from one person to another, except as provided in ADEM Admin. Code r. 335-3-1613(1)(a)5.	ADEM Admin. Code r. 335-3-1602(6)	
2.	Renewals		
	An application for permit renewal shall be submitted at least six (6) months, but not more than eighteen (18) months, before the date of expiration of this permit.	ADEM Admin. Code r. 335-3-1612(2)	
	The source for which this permit is issued shall lose its right to operate upon the expiration of this permit unless a timely and complete renewal application has been submitted within the time constraints listed in the previous paragraph.		
3.	Severability Clause		
	The provisions of this permit are declared to be severable and if any section, paragraph, subparagraph, subdivision, clause, or phrase of this permit shall be adjudged to be invalid or unconstitutional by any court of competent jurisdiction, the judgment shall not affect, impair, or invalidate the remainder of this permit, but shall be confined in its operation to the section, paragraph, subparagraph, subdivisions, clause, or phrase of this permit that shall be directly involved in the controversy in which such judgment shall have been rendered.	ADEM Admin. Code r. 335-3-1605(e)	
4.	Compliance		
	(a) The permittee shall comply with all conditions of ADEM Admin. Code 335-3. Noncompliance with this permit will constitute a violation of the Clean Air Act of 1990 and ADEM Admin. Code 335-3 and may result in an enforcement action; including but not limited to, permit termination, revocation and reissuance, or modification; or denial of a permit renewal application by the permittee.	ADEM Admin. Code r. 335-3-1605(f)	
	(b) The permittee shall not use as a defense in an enforcement action that maintaining compliance with conditions of this permit would have required halting or reducing the permitted activity.	ADEM Admin. Code r. 335-3-1605(g)	
5.	<u>Termination for Cause</u>		
	This permit may be modified, revoked, reopened, and reissued, or terminated for cause. The filing of a request by the permittee for a permit modification, revocation and reissuance, or termination, or of a notification of planned changes or anticipated noncompliance will not stay any permit condition.	ADEM Admin. Code r. 335-3-1605(h)	

	General Permit Provisos				
	Federally Enforceable Provisos	Regulations			
6.	Property Rights				
	The issuance of this permit does not convey any property rights of any sort, or any exclusive privilege.	ADEM Admin. Code r. 335-3-1605(i)			
7.	Submission of Information				
	The permittee must submit to the Air Division, within 30 days or for such other reasonable time as the Air Division may set, any information that the Air Division may request in writing to determine whether cause exists for modifying, revoking and reissuing, or terminating this permit or to determine compliance with this permit. Upon receiving a specific request, the permittee shall also furnish to the Air Division copies of records required to be kept by this permit.	ADEM Admin. Code r. 335-3-1605(j)			
8.	Economic Incentives, Marketable Permits, and Emissions Trading				
	No permit revision shall be required, under any approved economic incentives, marketable permits, emissions trading and other similar programs or processes for changes that are provided for in this permit.	ADEM Admin. Code r. 335-3-1605(k)			
9.	Certification of Truth, Accuracy, and Completeness				
	Any application form, report, test data, monitoring data, or compliance certification submitted pursuant to this permit shall contain certification by a responsible official of truth, accuracy, and completeness. This certification shall state that, based on information and belief formed after reasonable inquiry, the statements and information in the document are true, accurate and complete.	ADEM Admin. Code r. 335-3-1607(a)			
10	. Inspection and Entry				
	Upon presentation of credentials and other documents as may be required by law, the permittee shall allow authorized representatives of the Alabama Department of Environmental Management and EPA to conduct the following:	ADEM Admin. Code r. 335-3-1607(b)			
	(a) Enter upon the permittee's premises where a source is located or emissions-related activity is conducted, or where records must be kept pursuant to the conditions of this permit;				
	(b) Review and/or copy, at reasonable times, any records that must be kept pursuant to the conditions of this permit;				
	(c) Inspect, at reasonable times, this facility's equipment (including monitoring equipment and air pollution control equipment), practices, or operations regulated or required pursuant to this permit;				

General Permit Provisos			
Federally Enforceable Provisos	Regulations		
(d) Sample or monitor, at reasonable times, substances or parameters for the purpose of assuring compliance with this permit or other applicable requirements.			
11. Compliance Provisions			
(a) The permittee shall continue to comply with the applicable requirements with which the company has certified that it is already in compliance.	ADEM Admin. Code r. 335-3-1607(c)		
(b) The permittee shall comply in a timely manner with applicable requirements that become effective during the term of this permit.			
12. Compliance Certification			
The permittee shall submit a complete and accurate compliance certification by February 26 th of each year for each annual reporting period of this permit (December 28 th – December 27 th).	ADEM Admin. Code r. 335-3-1607(e)		
(a) The compliance certification shall include the following:			
(1) The identification of each term or condition of this permit that is the basis of the certification;			
(2) The compliance status;			
(3) The method(s) used for determining the compliance status of the source, currently and over the reporting period consistent with ADEM Admin. Code r. 335-3-1605(c) (Monitoring and Recordkeeping Requirements);			
(4) Whether compliance has been continuous or intermittent;			
(5) Such other facts as the Air Division may require to determine the compliance status of the source;			
(b) The compliance certification shall be submitted to:			
Alabama Department of Environmental Management Air Division P.O. Box 301463 Montgomery, AL 36130-1463			
and to:			
Director, Air Enforcement and Toxics Branch EPA Region 4 61 Forsyth Street, SW Atlanta, GA 30303			

General	Permit	Provisos
ucnera	ı ı cımıı	1 10 41202

General Permit Provisos			
Federally Enforceable Provisos	Regulations		
13. Reopening for Cause			
Under any of the following circumstances, this permit will be reopened prior to the expiration of the permit:	ADEM Admin. Code r. 335-3-1613(5)		
(a) Additional applicable requirements under the Clean Air Act of 1990 become applicable to the permittee with a remaining permit term of three (3) or more years. Such a reopening shall be completed not later than eighteen (18) months after promulgation of the applicable requirement. No such reopening is required if the effective date of the requirement is later than the date on which this permit is due to expire.			
(b) Additional requirements (including excess emissions requirements) become applicable to an affected source under the acid rain program. Upon approval by the Administrator, excess emissions offset plans shall be deemed to be incorporated into this permit.			
(c) The Department or EPA determines that this permit contains a material mistake or that inaccurate statements were made in establishing the emissions standards or other terms or conditions of this permit.			
(d) The Administrator or the Department determines that this permit must be revised or revoked to assure compliance with the applicable requirements.			
14. Additional Rules and Regulations			
This permit is issued on the basis of Rules and Regulations existing on the date of issuance. In the event additional Rules and Regulations are adopted, it shall be the permit holder's responsibility to comply with such rules.	§22-28-16(d), <u>Code of</u> <u>Alabama 1975</u> , as amended		
15. Equipment Maintenance or Breakdown			
(a) In case of shutdown of air pollution control equipment (which operates pursuant to any permit issued by the Director) for necessary scheduled maintenance, the intent to shut down such equipment shall be reported to the Air Division at least (24) hours prior to the planned shutdown, unless such shutdown is accompanied by the shutdown of the source which such equipment is intended to control. Such prior notice shall include, but is not limited to the following:	ADEM Admin. Code r. 335-3-107(1),(2)		
(1) Identification of the specific facility to be taken out of service as well as its location and permit number;			
(2) The expected length of time that the air pollution control equipment will be out of service;			

Genera	al Perr	nit Pı	rovisos

General Permit Provisos			
Federally Enforceable Provisos	Regulations		
(3) The nature and quality of emissions of air contaminants likely to occur during the shutdown period;			
(4) Measures such as the use of off-shift labor and equipment that will be taken to minimize the length of the shutdown period;			
(5) The reasons that it would be impossible or impractical to shut down the sources operation during the maintenance period.			
(b) In the event that there is a breakdown of equipment or upset of process in such a manner as to cause, or is expected to cause, increased emissions of air contaminants which are above an applicable standard, the person responsible for such equipment shall notify the Director within 24 hours or the next working day and provide a statement giving all pertinent facts, including the estimated duration of the breakdown. The Director will be notified when the breakdown has been corrected.			
16. Operation of Capture and Control Devices			
All air pollution control devices and capture systems for which this permit is issued shall be maintained and operated at all times in a manner so as to minimize the emissions of air contaminants. Procedures for ensuring that the above equipment is properly operated and maintained so as to minimize the emission of air contaminants shall be established.	§22-28-16(d), <u>Code of</u> <u>Alabama 1975</u> , as amended		
17. Obnoxious Odors			
This permit is issued with the condition that, should obnoxious odors arising from the plant operations be verified by Air Division inspectors, measures to abate the odorous emissions shall be taken upon a determination by the Alabama Department of Environmental Management that these measures are technically and economically feasible.	ADEM Admin. Code r. 335-3-108		
18. Fugitive Dust			
(a) Precautions shall be taken to prevent fugitive dust emanating from plant roads, grounds, stockpiles, screens, dryers, hoppers, ductwork, etc.	ADEM Admin. Code r. 335-3-402		
(b) Plant or haul roads and grounds will be maintained in the following manner so that dust will not become airborne. A minimum of one, or a combination, of the following methods shall be utilized to minimize airborne dust from plant or haul roads and grounds:			

Gene	ra1	Permi	t Pr	ovisos
OCH.	JIGI	1 61 1111		OVISUS

General Permit Provisos				
	Federally Enforceable Provisos	Regulations		
(1) By the application of water any time the surface of the road is sufficiently dry to allow the creation of dust emissions by the act of wind or vehicular traffic;			
(2) By reducing the speed of vehicular traffic to a point below that at which dust emissions are created;			
(3) By paving;			
(4) By the application of binders to the road surface at any time the road surface is found to allow the creation of dust emissions.			
ac gr ex cc Al	hould one, or a combination, of the above methods fail to dequately reduce airborne dust from plant or haul roads and rounds, alternative methods shall be employed, either acclusively or in combination with one or all of the above ontrol techniques, so that dust will not become airborne. Iternative methods shall be approved by the Air Division prior outilization.			
19. <u>Addit</u>	ions and Revisions			
proce	nodifications to this source shall comply with the modification dures in ADEM Admin. Code r. 335-3-1613 or 3-1614.	ADEM Admin. Code r. 335-3-1613 and 335-3-1614		
20. <u>Reco</u>	rdkeeping Requirements			
	ecords of required monitoring information of the source shall aclude the following:	ADEM Admin. Code r. 335-3-1605(c)2.		
(1) The date, place, and time of all sampling or measurements;			
(2) The date analyses were performed;			
(3) The company or entity that performed the analyses;			
(4) The analytical techniques or methods used;			
(5) The results of all analyses; and			
(6) The operating conditions that existed at the time of sampling or measurement.			
st fr or ar re	etention of records of all required monitoring data and apport information of the source for a period of at least 5 years om the date of the monitoring sample, measurement, report, application. Support information includes all calibration and maintenance records and all original strip-chart ecordings for continuous monitoring instrumentation and opies of all reports required by the permit.			

Federally Enforceable Provisos	Regulations			
21. Reporting Requirements				
(a) Reports to the Air Division of any required monitoring shall be submitted at least every 6 months. All instances of deviations from permit requirements must be clearly identified in said reports. All required reports must be certified by a responsible official consistent with ADEM Admin. Code r. 335-3-1604(9).	ADEM Admin. Code r. 335-3-1605(c)3.			
(b) Deviations from permit requirements shall be reported within 48 hours or 2 working days of such deviations, including those attributable to upset conditions as defined in the permit. The report will include the probable cause of said deviations, and any corrective actions or preventive measures that were taken.				
22. Emission Testing Requirements				
Each point of emission which requires testing will be provided with sampling ports, ladders, platforms, and other safety equipment to facilitate testing performed in accordance with procedures established by Part 60 of Title 40 of the Code of Federal Regulations, as the same may be amended or revised.	ADEM Admin. Code r. 335-3-105(3) and 335-3-104(1)			
The Air Division must be notified in writing at least 10 days in advance of all emission tests to be conducted and submitted as proof of compliance with the Department's air pollution control rules and regulations.				
To avoid problems concerning testing methods and procedures, the following shall be included with the notification letter:	ADEM Admin. Code r. 335-3-104			
(a) The date the test crew is expected to arrive, the date and time anticipated of the start of the first run, how many and which sources are to be tested, and the names of the persons and/or testing company that will conduct the tests.				
(b) A complete description of each sampling train to be used, including type of media used in determining gas stream components, type of probe lining, type of filter media, and probe cleaning method and solvent to be used (if test procedures require probe cleaning).				
(c) A description of the process(es) to be tested including the feed rate, any operating parameters used to control or influence the operations, and the rated capacity.				
(d) A sketch or sketches showing sampling point locations and their relative positions to the nearest upstream and downstream gas flow disturbances.				
A pretest meeting may be held at the request of the source owner or the Air Division. The necessity for such a meeting and the required attendees will be determined on a case-by-case basis.	ADEM Admin. Code r. 335-3-104			

Genera	al Perr	nit Pı	rovisos

Federally Enforceable Provisos	Regulations
All test reports must be submitted to the Air Division within 30 days of the actual completion of the test unless an extension of time is specifically approved by the Air Division.	
23. Payment of Emission Fees	
(a) The permittee shall remit the annual Operating Permit Fees required by ADEM Admin. Code r. 335-1-704 according to the schedule in ADEM Admin. Code r. 335-1-705.	ADEM Admin. Code r. 335-1-705
(b) The permittee shall submit its estimate of actual emissions for the previous calendar year according to the schedule in ADEM Admin. Code r. 335-1-705.	ADEM Admin. Code r. 335-1-705
24. Other Reporting and Testing Requirements	
Submission of other reports regarding monitoring records, fuel analyses, operating rates, and equipment malfunctions may be required as authorized in the Department's air pollution control rules and regulations. The Department may require emission testing at any time.	ADEM Admin. Code r. 335-3-104(1)
25. Title VI Requirements (Refrigerants)	
Any facility having appliances or refrigeration equipment, including air conditioning equipment, which use Class I or Class II ozone-depleting substances as listed in 40 CFR Part 82, Subpart A, Appendices A and B, shall service, repair, and maintain such equipment according to the work practices, personnel certification requirements, and certified recycling and recovery equipment specified in 40 CFR Part 82, Subpart F.	ADEM Admin. Code r. 335-3-1605(a)
No person shall knowingly vent or otherwise release any Class I or Class II substance into the environment during the repair, servicing, maintenance, or disposal of any device except as provided in 40 CFR Part 82, Subpart F.	
The responsible official shall comply with all reporting and recordkeeping requirements of 40 CFR §82.166. Reports shall be submitted to the US EPA and the Department as required.	
26. Chemical Accidental Prevention Provisions	
If a chemical listed in Table 1 of 40 CFR §68.130 is present in a process in quantities greater than the threshold quantity listed in Table 1, then:	40 CFR Part 68
(a) The owner or operator shall comply with the provisions in 40 CFR Part 68.	
(b) The owner or operator shall submit one of the following:	

Genera	al Perr	nit Pı	rovisos

Federally Enforceable Provisos	Regulations
(1) A compliance schedule for meeting the requirements of 40 CFR Part 68 by the date provided in 40 CFR §68.10(a) or,	
(2) A certification statement that the source is in compliance with all requirements of 40 CFR Part 68, including the registration and submission of the Risk Management Plan.	
27. Display of Permit	
This permit shall be kept under file or on display at all times at the site where the facility for which the permit is issued is located and will make the permit readily available for inspection by any or all persons who may request to see it.	ADEM Admin. Code r. 335-3-1602(2)
28. Circumvention	
No person shall cause or permit the installation or use of any device or any means which, without resulting in the reduction in the total amount of air contaminant emitted, conceals or dilutes any emission of air contaminant which would otherwise violate the Division 3 rules and regulations.	ADEM Admin. Code r. 335-3-110
29. Visible Emissions	
Unless otherwise specified in the Unit Specific provisos of this permit, any source of particulate emissions shall not discharge more than one 6-minute average opacity greater than 20% in any 60-minute period. At no time shall any source discharge a 6-minute average opacity of particulate emissions greater than 40%. Opacity will be determined by 40 CFR Part 60, Appendix A, Method 9, unless otherwise specified in the Unit Specific provisos of this permit.	ADEM Admin. Code r. 335-3-401(1)
30. Fuel-Burning Equipment	
Unless otherwise specified in the Unit Specific provisos of this permit, no fuel-burning equipment may discharge particulate emissions in excess of the emissions specified in ADEM Admin. Code r. 335-3-403.	ADEM Admin. Code r. 335-3-403
Unless otherwise specified in the Unit Specific provisos of this permit, no fuel-burning equipment may discharge sulfur dioxide emissions in excess of the emissions specified in ADEM Admin. Code r. 335-3-501.	ADEM Admin. Code r. 335-3-501
31. Process Industries - General	
Unless otherwise specified in the Unit Specific provisos of this permit, no process may discharge particulate emissions in excess of the emissions specified in ADEM Admin. Code r. 335-3-404.	ADEM Admin. Code r. 335-3-404

Federally Enforceable Provisos	Regulations
32. Averaging Time for Emission Limits	
Unless otherwise specified in the permit, the averaging time for the emission limits listed in this permit shall be the nominal time required by the specific test method.	ADEM Admin. Code r. 335-3-105
33. Open Burning	
Precautions should be taken to ensure that no person shall ignite, cause to ignite, permit to be ignited, or maintain any open fire in such a manner as to cause the Department's rules and regulations applicable to open burning to be violated.	ADEM Admin. Code r. 335-3-301

Emission Unit Nos. 001-003 and 005-007 (Mainline Unit Nos. 1-3 and 5-7) Summary Page

Description: Six (6) 2,500 hp Cooper GMW-10, 2-Stroke, Lean Burn, Natural Gas-fired Reciprocating Engines

Permitted Operating Schedule:
$$\frac{24 \text{ Hours}}{\text{Day}} \times \frac{365 \text{ Days}}{\text{Year}} = \frac{8760 \text{ Hours}}{\text{Year}}$$

Emission Point Nos.	Description	Pollutant	Emission limit	Regulation
MLU-1	Six (6) 2,500 hp Cooper GMW-	NO_{x}	N/A	N/A
MLU-2	10, 2-Stroke, Lean Burn, Natural Gas-fired Reciprocating Engines	СО	N/A	N/A
MLU-3		***	~~ / ^	
MLU-5		VOC	N/A	N/A
MLU-6		SO_2	N/A	N/A
MLU-7		PM	N/A	N/A
		НАР	N/A	N/A

Emission Unit Nos. 001-003 and 005-007 (Mainline Unit Nos. 1-3 and 5-7) Unit Specific Provisos

	Federally Enforceable Provisos	Regulations		
1.	Applicability			
	(a) These units are subject to the applicable requirements of ADEM Admin. Code r. 335-3-1603, "Major Source Operating Permits."	ADEM Admin. Code r. 335-3-1603		
	(b) These units are affected sources under 40 CFR Part 63, Subpart ZZZZ, the National Emission Standards for Hazardous Air Pollutants for Stationary Reciprocating Internal Combustion Engines.	ADEM Admin. Code r. 335-3-1106(103)		
2.	Emission Standards			
	The permittee shall not discharge more than one six-minute average opacity greater than 20% in any 60-minute period from these units. At no time shall the permittee discharge a six-minute average opacity of particulate emissions greater than 40% from these units.	ADEM Admin. Code r. 335-3-401(1)		
3.	Compliance and Performance Test Methods and Procedures			
	If testing is required, opacity shall be determined by 40 CFR Part 60, Appendix A, Method 9.	ADEM Admin. Code r. 335-3-105		
4.	Emission Monitoring			
	The permittee shall only fire natural gas in these units.	ADEM Admin. Code r. 335-3-1605(c)		
5.	Recordkeeping and Reporting Requirements			
	The permittee shall submit a Semiannual Monitoring Report, as required by General Permit Proviso No. 21(a), no later than 60 days after the end of each semiannual period (January 1st-June 30th and July 1st-December 31st). The report shall include a statement addressing whether only natural gas was fired in these units during the reporting period.	ADEM Admin. Code r. 335-3-1605(c)		

Emission Unit No. 004 (Mainline Unit No. 4) Summary Page

Description: 2,500 hp Cooper GMW-10, 2-Stroke, Lean Burn, Natural Gas-fired Reciprocating Engine

Permitted Operating Schedule: $\frac{24 \text{ Hours}}{\text{Day}} \times \frac{365 \text{ Days}}{\text{Year}} = \frac{8760 \text{ Hours}}{\text{Year}}$

Emission Point No.	Description	Pollutant	Emission limit	Regulation
MLU-4	MLU-4 2,500 hp Cooper GMW-10, 2- Stroke, Lean Burn, Natural Gas-fired Reciprocating Engine	NO_{x}	36.0 lb/hr	ADEM Admin. Code r. 335-3-1404
		СО	14.5 lb/hr	ADEM Admin. Code r. 335-3-1404
		VOC	N/A	N/A
		SO_2	N/A	N/A
		PM	N/A	N/A
		НАР	N/A	N/A

Emission Unit No. 004 (Mainline Unit No. 4)

		Federally Enforceable Provisos	Regulations
1.	Ap	plicability	
	(a)	This unit is subject to the applicable requirements of ADEM Admin. Code r. 335-3-1603, "Major Source Operating Permits."	ADEM Admin. Code r. 335-3-1603
	(b)	This unit is an affected source under 40 CFR Part 63, Subpart ZZZZ, the National Emission Standards for Hazardous Air Pollutants for Stationary Reciprocating Internal Combustion Engines.	ADEM Admin. Code r. 335-3-1106(103)
	(c)	This unit is subject to a synthetic minor source emission limit to restrict its potential to emit below the applicability threshold established at ADEM Admin. Code r. 335-3-1404, Air Permits Authorizing Construction in Clean Areas [Prevention of Significant Deterioration (PSD)].	ADEM Admin. Code r. 335-3-1404
2.	Em	aission Standards	
	(a)	The permittee shall not cause or allow emissions of nitrogen oxides (NO $_x$) from this unit in excess of 36.0 lb/hr.	ADEM Admin. Code r. 335-3-1404
	(b)	The permittee shall not cause or allow emissions of carbon monoxide (CO) from this unit in excess of 14.5 lb/hr.	ADEM Admin. Code r. 335-3-1404
	(c)	The permittee shall not discharge more than one six-minute average opacity greater than 20% in any 60-minute period from this unit. At no time shall the permittee discharge a six-minute average opacity of particulate emissions greater than 40% from this unit.	ADEM Admin. Code r. 335-3-401(1)
3.	Co	mpliance and Performance Test Methods and Procedures	
	(a)	Compliance with the nitrogen oxides (NO _x) emission rate of this unit shall be determined by EPA Reference Methods 1, 2, 3 and 4 or 19, and EPA Reference Method 7E in Appendix A of 40 CFR Part 60. Alternate test methods may be used provided prior approval by the Air Division is granted.	ADEM Admin. Code r. 335-3-105
	(b)	Compliance with the carbon monoxide (CO) emission rate of this unit shall be determined by EPA Reference Methods 1, 2, 3 and 4 or 19, and EPA Reference Method 10 in Appendix A of 40 CFR Part 60. Alternate test methods may be used provided prior approval by the Air Division is granted.	ADEM Admin. Code r. 335-3-105
	(c)	If testing is required, opacity shall be determined by 40 CFR Part 60, Appendix A, Method 9.	ADEM Admin. Code r. 335-3-105

Federally	Enforceable	Provisos
-----------	-------------	-----------------

Regulations

4. Emission Monitoring

(a) Emission testing shall be conducted semiannually to determine compliance with the applicable emission standard(s). Testing shall be conducted twice per calendar year at a frequency of once per semiannual period (Jan 1st - Jun 30th and Jul 1st - Dec 31st), with a minimum of three (3) calendar months elapsing between tests. The first emission testing conducted following the effective date of this permit shall be conducted in accordance with an approved EPA Reference Method for that pollutant. All subsequent emission testing during the permit term may be conducted using either an approved EPA Reference Method for that pollutant or utilizing a portable analyzer in accordance with a protocol/method approved in advance by the Air Division.

ADEM Admin. Code r. 335-3-16-.05(c)

- (i) If emission results from the above referenced performance test are less than or equal to 75% of the emission limit, then the frequency of subsequent performance tests may be reduced from a semiannual to an annual basis.
- (ii) If the results of any subsequent performance test exceed 75% of the emission limit, then semiannual performance testing shall resume until the unit demonstrates compliance for two (2) consecutive testing events demonstrating emissions are less than or equal to 75% of the emission limit, at which time annual testing may resume.
- (iii) After the first performance test conducted following the issuance of this renewal permit, no periodic monitoring will be required if these units do not operate for production purposes during the respective semiannual or annual testing period, whichever applies.
- **(b)** The permittee shall only fire natural gas in this unit.

ADEM Admin. Code r. 335-3-16-.05(c)

5. Recordkeeping and Reporting Requirements

(a) The permittee shall submit a Semiannual Monitoring Report, as required by General Permit Proviso No. 21(a), no later than 60 days after the end of each semiannual period (January 1st-June 30th and July 1st-December 31st). The report shall include a statement addressing whether only natural gas was fired in this unit and all emission monitoring was conducted as required during the reporting period. If all emission monitoring was not conducted, the report shall explain the reason(s) why it was not performed. The report shall also include a statement addressing whether this unit was operated for production purposes during each respective reporting period.

ADEM Admin. Code r. 335-3-16-.05(c)

Federally Enforceable Provisos	Regulations
(b) The permittee shall submit the results of all emission tests conducted to the Air Division within 30 days of the actual completion of the test unless the Air Division specifically approves an extension of time.	335-3-1605(c)

Emission Unit Nos. 008 and 009 (Mainline Unit Nos. 8 and 9) Summary Page

Description: Two (2) 2,625 hp Cooper GMWA-10, 2-Stroke, Lean Burn, Natural Gas-fired Reciprocating Engines

Permitted Operating Schedule:
$$\frac{24 \text{ Hours}}{\text{Day}} \times \frac{365 \text{ Days}}{\text{Year}} = \frac{8760 \text{ Hours}}{\text{Year}}$$

Emission Point Nos.	Description	Pollutant	Emission limit	Regulation
MLU-8	Two (2) 2,625 hp Cooper GMWA-	NO_x	N/A	N/A
MLU-9	MLU-9 10, 2-Stroke, Lean Burn, Natural Gas-fired Reciprocating Engines	СО	N/A	N/A
		VOC	N/A	N/A
		SO ₂	N/A	N/A
		PM	N/A	N/A
		НАР	N/A	N/A

Emission Unit Nos. 008 and 009 (Mainline Unit Nos. 8 and 9)

	Federally Enforceable Provisos	Regulations
1.	Applicability	
	(a) These units are subject to the applicable requirements of ADEM Admin. Code r. 335-3-1603, "Major Source Operating Permits."	ADEM Admin. Code r. 335-3-1603
	(b) These units are affected sources under 40 CFR Part 63, Subpart ZZZZ, the National Emission Standards for Hazardous Air Pollutants for Stationary Reciprocating Internal Combustion Engines.	ADEM Admin. Code r. 335-3-1106(103)
2.	Emission Standards	
	The permittee shall not discharge more than one six-minute average opacity greater than 20% in any 60-minute period from these units. At no time shall the permittee discharge a six-minute average opacity of particulate emissions greater than 40% from these units.	ADEM Admin. Code r. 335-3-401(1)
3.	Compliance and Performance Test Methods and Procedures	
	If testing is required, opacity shall be determined by 40 CFR Part 60, Appendix A, Method 9.	ADEM Admin. Code r. 335-3-105
4.	Emission Monitoring	
	The permittee shall only fire natural gas in these units.	ADEM Admin. Code r. 335-3-1605(c)
5.	Recordkeeping and Reporting Requirements	
	The permittee shall submit a Semiannual Monitoring Report, as required by General Permit Proviso No. 21(a), no later than 60 days after the end of each semiannual period (January 1st-June 30th and July 1st-December 31st). The report shall include a statement addressing whether only natural gas was fired in these units during the reporting period.	ADEM Admin. Code r. 335-3-1605(c)

Emission Unit Nos. 010 and 011 (Mainline Unit Nos. 10 and 11) Summary Page

Description: Two (2) 3,400 hp Cooper GMWC-10, 2-Stroke, Lean Burn, Natural Gas-fired Reciprocating Engines

Permitted Operating Schedule:
$$\frac{24 \text{ Hours}}{\text{Day}} \times \frac{365 \text{ Days}}{\text{Year}} = \frac{8760 \text{ Hours}}{\text{Year}}$$

Emission Point Nos.	Description	Pollutant	Emission limit	Regulation
MLU-10	Two (2) 3,400 hp Cooper GMWC-	NO_{x}	N/A	N/A
MLU-11	MLU-11 10, 2-Stroke, Lean Burn, Natural Gas-fired Reciprocating Engines	СО	N/A	N/A
		VOC	N/A	N/A
		SO_2	N/A	N/A
		PM	N/A	N/A
		НАР	N/A	N/A

Emission Unit Nos. 010 and 011 (Mainline Unit Nos. 10 and 11)

	Federally Enforceable Provisos	Regulations
1.	Applicability	
	(a) These units are subject to the applicable requirements of ADEM Admin. Code r. 335-3-1603, "Major Source Operating Permits."	ADEM Admin. Code r. 335-3-1603
	(b) These units are affected sources under 40 CFR Part 63, Subpart ZZZZ, the National Emission Standards for Hazardous Air Pollutants for Stationary Reciprocating Internal Combustion Engines.	ADEM Admin. Code r. 335-3-1106(103)
2.	Emission Standards	
	The permittee shall not discharge more than one six-minute average opacity greater than 20% in any 60-minute period from these units. At no time shall the permittee discharge a six-minute average opacity of particulate emissions greater than 40% from these units	ADEM Admin. Code r. 335-3-401(1)
3.	Compliance and Performance Test Methods and Procedures	
	If testing is required, opacity shall be determined by 40 CFR Part 60, Appendix A, Method 9.	ADEM Admin. Code r. 335-3-105
4.	Emission Monitoring	
	The permittee shall only fire natural gas in these units.	ADEM Admin. Code r. 335-3-1605(c)
5.	Recordkeeping and Reporting Requirements	
	The permittee shall submit a Semiannual Monitoring Report, as required by General Permit Proviso No. 21(a), no later than 60 days after the end of each semiannual period (January $1^{\rm st}$ -June $30^{\rm th}$ and July $1^{\rm st}$ -December $31^{\rm st}$). The report shall include a statement addressing whether only natural gas was fired in these units during the reporting period.	ADEM Admin. Code r. 335-3-1605(c)

Emission Unit Nos. 012 and 013 (Mainline Unit Nos. 12 and 13) Summary Page

Description: Two (2) 3,400 hp Cooper 10V-250, 2-Stroke, Lean Burn, Natural Gas-fired

Reciprocating Engines

Permitted Operating Schedule: $\frac{24 \text{ Hours}}{\text{Day}} \times \frac{365 \text{ Days}}{\text{Year}} = \frac{8760 \text{ Hours}}{\text{Year}}$

Emission Point Nos.	Description	Pollutant	Emission limit	Regulation
MLU-12 MLU-13	Two (2) 3,400 hp Cooper 10V-250, 2-Stroke, Lean	NO_{x}	45.0 lb/hr, each	ADEM Admin. Code r. 335-3-1404
	Burn, Natural Gas-fired Reciprocating Engines	СО	7.5 lb/hr, each	ADEM Admin. Code r. 335-3-1404
		VOC	5.1 lb/hr, each	ADEM Admin. Code r. 335-3-1404
		SO_2	N/A	N/A
		PM	N/A	N/A
		НАР	N/A	N/A

Emission Unit Nos. 012 and 013 (Mainline Unit Nos. 12 and 13)

		Federally Enforceable Provisos	Regulations
1.	<u>Ap</u>	<u>plicability</u>	
	(a)	These units are subject to the applicable requirements of ADEM Admin. Code r. 335-3-1603, "Major Source Operating Permits."	ADEM Admin. Code r. 335-3-1603
	(b)	These units are affected sources under 40 CFR Part 63, Subpart ZZZZ, the National Emission Standards for Hazardous Air Pollutants for Stationary Reciprocating Internal Combustion Engines.	ADEM Admin. Code r. 335-3-1106(103)
	(c)	These units are subject to a synthetic minor source emission limit to restrict their potential to emit below the applicability threshold established at ADEM Admin. Code r. 335-3-1404, Air Permits Authorizing Construction in Clean Areas [Prevention of Significant Deterioration (PSD)].	ADEM Admin. Code r. 335-3-1404
2.	Em	uission Standards	
	(a)	The permittee shall not cause or allow emissions of nitrogen oxides (NO $_{x}$) from each unit in excess of 45.0 lb/hr.	ADEM Admin. Code r. 335-3-1404
	(b)	The permittee shall not cause or allow emissions of carbon monoxide (CO) from each unit in excess of 7.5 lb/hr.	ADEM Admin. Code r. 335-3-1404
	(c)	The permittee shall not cause or allow emissions of volatile organic compounds (VOC) from each unit in excess of 5.1 lb/hr.	ADEM Admin. Code r. 335-3-1404
	(d)	The permittee shall not discharge more than one six-minute average opacity greater than 20% in any 60-minute period from these units. At no time shall the permittee discharge a six-minute average opacity of particulate emissions greater than 40% from these units.	ADEM Admin. Code r. 335-3-401(1)
3.	Co	mpliance and Performance Test Methods and Procedures	
	(a)	Compliance with the nitrogen oxides (NO_x) emission rate of each unit shall be determined by EPA Reference Methods 1, 2, 3 and 4 or 19, and EPA Reference Method 7E in Appendix A of 40 CFR Part 60. Alternate test methods may be used provided prior approval by the Air Division is granted.	ADEM Admin. Code r. 335-3-105
	(b)	Compliance with the carbon monoxide (CO) emission rate of each unit shall be determined by EPA Reference Methods 1, 2, 3 and 4 or 19, and EPA Reference Method 10 in Appendix A of 40 CFR Part 60. Alternate test methods may be used provided prior approval by the Air Division is granted.	ADEM Admin. Code r. 335-3-105

	Federally Enforceable Provisos	Regulations
(c)	Compliance with the volatile organic compound (VOC) emission rate of each unit shall be determined by EPA Reference Methods 1, 2, 3 and 4 or 19, and EPA Reference Methods 25A and/or 18 in Appendix A of 40 CFR Part 60. Alternate test methods may be used provided prior approval by the Air Division is granted.	ADEM Admin. Code r. 335-3-105
(d)	If testing is required, opacity shall be determined by 40 CFR Part 60, Appendix A, Method 9.	ADEM Admin. Code r. 335-3-105
. <u>Em</u>	ission Monitoring	
(a)	Emission testing shall be conducted semiannually to determine compliance with the applicable emission standard(s). Testing shall be conducted twice per calendar year at a frequency of once per semiannual period (Jan 1st - Jun 30th and Jul 1st - Dec 31st), with a minimum of three (3) calendar months elapsing between tests. The first emission testing conducted following the effective date of this permit shall be conducted in accordance with an approved EPA Reference Method for that pollutant. All subsequent emission testing during the permit term may be conducted using either an approved EPA Reference Method for that pollutant or utilizing a portable analyzer in accordance with a protocol/method approved in advance by the Air Division.	ADEM Admin. Code r. 335-3-1605(c)
	(i) If emission results from the above referenced performance test are less than or equal to 75% of the emission limit, then the frequency of subsequent performance tests may be reduced from a semiannual to an annual basis.	
	(ii) If the results of any subsequent performance test exceed 75% of the emission limit, then semiannual performance testing shall resume until the unit demonstrates compliance for two (2) consecutive testing events demonstrating emissions are less than or equal to 75% of the emission limit, at which time annual testing may resume.	
	(iii) After the first performance test conducted following the issuance of this renewal permit, no periodic monitoring will be required if these units do not operate for production purposes during the respective semiannual or annual testing period, whichever applies.	
(b)	The permittee shall only fire natural gas in these units.	ADEM Admin. Code r. 335-3-1605(c)

	Federally Enforceable Provisos	Regulations
5.	Recordkeeping and Reporting Requirements	
	(a) The permittee shall submit a Semiannual Monitoring Report, as required by General Permit Proviso No. 21(a), no later than 60 days after the end of each semiannual period (January 1 st-June 30th and July 1 st-December 31st). The report shall include a statement addressing whether only natural gas was fired in these units and all emission monitoring was conducted as required during the reporting period. If all emission monitoring was not conducted, the report shall explain the reason(s) why it was not performed. The report shall also include a statement addressing whether these units were operated for production purposes during each respective reporting period.	ADEM Admin. Code r. 335-3-1605(c)
	(b) The permittee shall submit the results of all emission tests conducted to the Air Division within 30 days of the actual completion of the test unless the Air Division specifically approves an extension of time.	ADEM Admin. Code r. 335-3-1605(c)

Emission Unit No. 014 (Mainline Unit No. 14) Summary Page

Description: 3,400 hp Cooper 10V-250, 2-Stroke, Lean Burn, Natural Gas-fired Reciprocating Engine

Permitted Operating Schedule: $\frac{24 \text{ Hours}}{\text{Day}} \times \frac{365 \text{ Days}}{\text{Year}} = \frac{8760 \text{ Hours}}{\text{Year}}$

Emission Point No.	Description	Pollutant	Emission limit	Regulation
MLU-14	3,400 hp Cooper 10V-250, 2- Stroke, Lean Burn, Natural Gas-	NO_{x}	N/A	N/A
	fired Reciprocating Engine	СО	N/A	N/A
		VOC	N/A	N/A
		SO_2	N/A	N/A
		PM	N/A	N/A
		НАР	N/A	N/A

Emission Unit No. 014 (Mainline Unit No. 14)

	Federally Enforceable Provisos	Regulations
1.	Applicability	
	(a) This unit is subject to the applicable requirements of ADEM Admin. Code r. 335-3-1603, "Major Source Operating Permits."	ADEM Admin. Code r. 335-3-1603
	(b) This unit is an affected source under 40 CFR Part 63, Subpart ZZZZ, the National Emission Standards for Hazardous Air Pollutants for Stationary Reciprocating Internal Combustion Engines.	ADEM Admin. Code r. 335-3-1106(103)
2.	Emission Standards	
	The permittee shall not discharge more than one six-minute average opacity greater than 20% in any 60-minute period from this unit. At no time shall the permittee discharge a six-minute average opacity of particulate emissions greater than 40% from this unit.	ADEM Admin. Code r. 335-3-401(1)
3.	Compliance and Performance Test Methods and Procedures	
	If testing is required, opacity shall be determined by 40 CFR Part 60, Appendix A, Method 9.	ADEM Admin. Code r. 335-3-105
4.	Emission Monitoring	
	The permittee shall only fire natural gas in this unit.	ADEM Admin. Code r. 335-3-1605(c)
5.	Recordkeeping and Reporting Requirements	
	The permittee shall submit a Semiannual Monitoring Report, as required by General Permit Proviso No. 21(a), no later than 60 days after the end of each semiannual period (January 1st-June 30th and July 1st-December 31st). The report shall include a statement addressing whether only natural gas was fired in this unit during the reporting period.	ADEM Admin. Code r. 335-3-1605(c)

Emission Unit No. 015 (Mainline Unit No. 15) **Summary Page**

Description: 5,500 hp Cooper 16V-250, 2-Stroke, Lean Burn, Natural Gas-fired

Reciprocating Engine

Permitted Operating Schedule:
$$\frac{24 \text{ Hours}}{\text{Day}} \times \frac{365 \text{ Days}}{\text{Year}} = \frac{8760 \text{ Hours}}{\text{Year}}$$

Emission Point No.	Description	Pollutant	Emission limit	Regulation
MLU-15	5,500 hp Cooper 16V-250, 2- Stroke, Lean Burn, Natural Gas-	NO_{x}	N/A	N/A
	fired Reciprocating Engine	СО	N/A	N/A
		VOC	N/A	N/A
		SO_2	N/A	N/A
		PM	N/A	N/A
		НАР	N/A	N/A

Emission Unit No. 015 (Mainline Unit No. 15)

	Federally Enforceable Provisos	Regulations
1.	Applicability	
	(a) This unit is subject to the applicable requirements of ADEM Admin. Code r. 335-3-1603, "Major Source Operating Permits."	ADEM Admin. Code r. 335-3-1603
	(b) This unit is an affected source under 40 CFR Part 63, Subpart ZZZZ, the National Emission Standards for Hazardous Air Pollutants for Stationary Reciprocating Internal Combustion Engines.	ADEM Admin. Code r. 335-3-1106(103)
2.	Emission Standards	
	The permittee shall not discharge more than one six-minute average opacity greater than 20% in any 60-minute period from this unit. At no time shall the permittee discharge a six-minute average opacity of particulate emissions greater than 40% from this unit.	ADEM Admin. Code r. 335-3-401(1)
3.	Compliance and Performance Test Methods and Procedures	
	If testing is required, opacity shall be determined by 40 CFR Part 60, Appendix A, Method 9.	ADEM Admin. Code r. 335-3-105
4.	Emission Monitoring	
	The permittee shall only fire natural gas in this unit.	ADEM Admin. Code r. 335-3-1605(c)
5.	Recordkeeping and Reporting Requirements	
	The permittee shall submit a Semiannual Monitoring Report, as required by General Permit Proviso No. 21(a), no later than 60 days after the end of each semiannual period (January 1st-June 30th and July 1st-December 31st). The report shall include a statement addressing whether only natural gas was fired in this unit during the reporting period.	ADEM Admin. Code r. 335-3-1605(c)

Emission Unit No. 016 (Mainline Unit No. 16) Summary Page

Description: 4,220 hp Solar Centaur Natural Gas-fired Combustion Turbine

Permitted Operating Schedule:
$$\frac{24 \text{ Hours}}{\text{Day}} \times \frac{365 \text{ Days}}{\text{Year}} = \frac{8760 \text{ Hours}}{\text{Year}}$$

Emission Point No.	Description	Pollutant	Emission limit	Regulation
MLU-16	4,220 hp Solar Centaur Natural Gas-fired Combustion Turbine	NOx	18.16 lb/hr	ADEM Admin. Code r. 335-3-1404
			168 ppmvd @15% O2	ADEM Admin. Code r. 335-3-1002(33) 40 CFR 60, Subpart GG (NSPS)
		СО	N/A	N/A
		VOC	N/A	N/A
		SO ₂	Fuel meets definition of natural gas	ADEM Admin. Code r. 335-3-1002(33) 40 CFR 60, Subpart GG (NSPS)
		PM	N/A	N/A
		НАР	N/A	N/A

Emission Unit No. 016 (Mainline Unit No. 16)

	Federally Enforceable Provisos	Regulations
1.	<u>Applicability</u>	
	(a) This unit is subject to the applicable requirements of ADEM Admin. Code r. 335-3-1603, "Major Source Operating Permits."	
	(b) This unit is subject to the applicable requirements of 40 CFR Part 60, Subpart GG, the Standards of Performance for Stationary Gas Turbines.	
	(c) This unit is an affected source under 40 CFR Part 63, Subpart YYYY, the National Emission Standards for Hazardous Air Pollutants for Stationary Combustion Turbines.	
	(d) This unit is subject to a synthetic minor source emission limit to restrict its potential to emit below the applicability threshold established at ADEM Admin. Code r. 335-3-1404, Air Permits Authorizing Construction in Clean Areas [Prevention of Significant Deterioration (PSD)].	335-3-1404
2.	Emission Standards	
	(a) The permittee shall not cause or allow emissions of nitrogen oxides (NO _x) from this unit in excess of 18.16 lb/hr.	ADEM Admin. Code r. 335-3-1404
	(b) This unit is subject to the applicable emission standards of 40 CFR $\S60.332$. The permittee shall not cause or allow emissions of nitrogen oxides (NO _x) from this unit in excess of 168 ppmvd @ 15% O ₂ .	335-3-1002(33)
	(c) This unit is subject to the applicable emission standards of 40 CFR $\S60.333$. The permittee shall not cause or allow emissions of sulfur dioxide (SO ₂) from this unit in excess of 150 ppmvd @ 15% O ₂ OR, as an alternative, no fuel shall be burned in the unit that contains sulfur in excess of 0.8 percent by weight (8,000 ppmw).	335-3-1002(33)
	(d) The permittee shall not discharge more than one six-minute average opacity greater than 20% in any 60-minute period from this unit. At no time shall the permittee discharge a six-minute average opacity of particulate emissions greater than 40% from this unit	, ,
3.	Compliance and Performance Test Methods and Procedures	
	(a) Compliance with the nitrogen oxides (NO _x) emission rate of this unit shall be determined by EPA Reference Methods 1, 2, 3 and 4 or 19, and EPA Reference Method 7E in Appendix A of 40 CFR Part 60. Alternate test methods may be used provided prior approval by the Air Division is granted.	335-3-105

		Federally Enforceable Provisos	Regulations
	(b)	If testing is required, opacity shall be determined by 40 CFR Part 60, Appendix A, Method 9.	ADEM Admin. Code r. 335-3-105
4.	Em	ission Monitoring	
	(a)	Emission testing shall be conducted semiannually to determine compliance with the applicable emission standard(s). Testing shall be conducted twice per calendar year at a frequency of once per semiannual period (Jan 1st - Jun 30th and Jul 1st - Dec 31st), with a minimum of three (3) calendar months elapsing between tests. The first emission testing conducted following the effective date of this permit shall be conducted in accordance with an approved EPA Reference Method for that pollutant. All subsequent emission testing during the permit term may be conducted using either an approved EPA Reference Method for that pollutant or utilizing a portable analyzer in accordance with a protocol/method approved in advance by the Air Division.	ADEM Admin. Code r. 335-3-1605(c)
		(i) If emission results from the above referenced performance test are less than or equal to 75% of the emission limit, then the frequency of subsequent performance tests may be reduced from a semiannual to an annual basis.	
		(ii) If the results of any subsequent performance test exceed 75% of the emission limit, then semiannual performance testing shall resume until the unit demonstrates compliance for two (2) consecutive testing events demonstrating emissions are less than or equal to 75% of the emission limit, at which time annual testing may resume.	
		(iii) After the first performance test conducted following the issuance of this renewal permit, no periodic monitoring will be required if these units do not operate for production purposes during the respective semiannual or annual testing period, whichever applies.	
	(b)	The permittee shall only fire natural gas in this unit.	ADEM Admin. Code r. 335-3-1605(c)
	(c)	This unit is subject to the applicable monitoring requirements of 40 CFR §60.334(h)(3), which include demonstrating the fuel meets the definition of natural gas in 40 CFR §60.331(u) by maintaining a current tariff sheet specifying that the maximum total sulfur content of the fuel is 20.0 grains/100 scf or less.	ADEM Admin. Code r. 335-3-1002(33)
5.	Re	cordkeeping and Reporting Requirements	
	(a)	The permittee shall maintain records of the most current fuel tariff sheet as required by 40 CFR §60.334(h)(3)(i), on-site in a permanent form suitable for inspection for at least five (5) years (2 years on-site and 3 years off-site) from the date of generation of each record.	ADEM Admin. Code r. 335-3-1605(c)

Federally Enforceable Provisos	Regulations
(b) The permittee shall submit the results of all emission tests conducted to the Air Division within 30 days of the actual completion of the test unless the Air Division specifically approves an extension of time.	ADEM Admin. Code r. 335-3-1605(c)
(c) The permittee shall submit a Semiannual Monitoring Report, as required by General Permit Proviso No. 21(a), no later than 60 days after the end of each semiannual period (January 1st-June 30th and July 1st-December 31st). The report shall include a statement addressing whether only natural gas was fired in this unit and all emission monitoring was conducted as required during the reporting period. If all emission monitoring was not conducted, the report shall explain the reason(s) why it was not performed. The report shall also include a statement addressing whether this unit was operated for production purposes during each respective reporting period.	ADEM Admin. Code r. 335-3-1605(c)

Emission Unit No. 018 (Mainline Unit No. 18) Summary Page

Description: 16,793 hp Solar Mars T15000S Natural Gas-fired Combustion Turbine

Permitted Operating Schedule:
$$\frac{24 \text{ Hours}}{\text{Day}} \times \frac{365 \text{ Days}}{\text{Year}} = \frac{8760 \text{ Hours}}{\text{Year}}$$

Emission Point No.	Description	Pollutant	Emission limit	Regulation
MLU-18	16,793 hp Solar Mars T15000S Natural Gas-fired Combustion Turbine	15.0 lb/hr NO _x 206 ppmvd @15% O ₂ CO 15.2 lb/hr	15.0 lb/hr	ADEM Admin. Code r. 335-3-1404
	Combustion Furbille		ADEM Admin Code r. 335-3-1002(33) 40 CFR 60, Subpart GG (NSPS)	
		СО	15.2 lb/hr	ADEM Admin. Code r. 335-3-1404
		VOC	N/A	N/A
		SO ₂	Fuel meets definition of natural gas	ADEM Admin Code r. 335-3-1002(33) 40 CFR 60, Subpart GG (NSPS)
		PM	N/A	N/A
		HAP	N/A	N/A

Emission Unit No. 018 (Mainline Unit No. 18)

		Federally Enforceable Provisos	Regulations
1.	<u>Ap</u>	plicability	
	(a)	This unit is subject to the applicable requirements of ADEM Admin. Code r. 335-3-1603, "Major Source Operating Permits."	ADEM Admin. Code r. 335-3-1603
	(b)	This unit is subject to the applicable requirements of 40 CFR Part 60, Subpart GG, the Standards of Performance for Stationary Gas Turbines.	ADEM Admin. Code r. 335-3-1002(33)
	(c)	This unit is an affected source under 40 CFR Part 63, Subpart YYYY, the National Emission Standards for Hazardous Air Pollutants for Stationary Combustion Turbines.	ADEM Admin. Code r. 335-3-1106(102)
	(d) This unit is subject to a synthetic minor source emission limit to restrict its potential to emit below the applicability threshold established at ADEM Admin. Code r. 335-3-1404, Air Permits Authorizing Construction in Clean Areas [Prevention of Significant Deterioration (PSD)].		ADEM Admin. Code r. 335-3-1404
2.	Em	aission Standards	
	(a)	The permittee shall not cause or allow emissions of nitrogen oxides (NO $_x$) from this unit in excess of 15.0 lb/hr.	ADEM Admin. Code r. 335-3-1404
	(b)	The permittee shall not cause or allow emissions of carbon monoxide (CO) from this unit in excess of 15.2 lb/hr.	ADEM Admin. Code r. 335-3-1404
	(c)	This unit is subject to the applicable emission standards of 40 CFR §60.332. The permittee shall not cause or allow the emission of nitrogen oxides (NO $_x$) from this unit in excess of 206 ppmvd @ 15% O $_2$.	ADEM Admin. Code r. 335-3-1002(33)
	(d) This unit is subject to the applicable emission standards of 40 CFR §60.333. The permittee shall not cause or allow the emission of sulfur dioxide (SO ₂) from this unit in excess of 150 ppmvd @ 15% O ₂ OR, as an alternative, no fuel shall be burned in the unit that contains sulfur in excess of 0.8 percent by weight (8,000 ppmw).		ADEM Admin. Code r. 335-3-1002(33)
	(e)	The permittee shall not discharge more than one six-minute average opacity greater than 20% in any 60-minute period from this unit. At no time shall the permittee discharge a six-minute average opacity of particulate emissions greater than 40% from this unit.	ADEM Admin. Code r. 335-3-401(1)

	Federally Enforceable Provisos	Regulations
3.	Compliance and Performance Test Methods and Procedures	
	(a) Compliance with the nitrogen oxides (NO_x) emission rate of this unit shall be determined by EPA Reference Methods 1, 2, 3 and 4 or 19, and EPA Reference Method 7E in Appendix A of 40 CFR Part 60. Alternate test methods may be used provided prior approval by the Air Division is granted.	ADEM Admin. Code r. 335-3-105
	(b) Compliance with the carbon monoxide (CO) emission rate of this unit shall be determined by EPA Reference Methods 1, 2, 3 and 4 or 19, and EPA Reference Method 10 in Appendix A of 40 CFR Part 60. Alternate test methods may be used provided prior approval by the Air Division is granted.	ADEM Admin. Code r. 335-3-105
	(c) If testing is required, opacity shall be determined by 40 CFR Part 60, Appendix A, Method 9.	ADEM Admin. Code r. 335-3-105
4.	Emission Monitoring	
	(a) Emission testing shall be conducted semiannually to determine compliance with the applicable emission standard(s). Testing shall be conducted twice per calendar year at a frequency of once per semiannual period (Jan 1st - Jun 30th and Jul 1st - Dec 31st), with a minimum of three (3) calendar months elapsing between tests. The first emission testing conducted following the effective date of this permit shall be conducted in accordance with an approved EPA Reference Method for that pollutant. All subsequent emission testing during the permit term may be conducted using either an approved EPA Reference Method for that pollutant or utilizing a portable analyzer in accordance with a protocol/method approved in advance by the Air Division.	ADEM Admin. Code r. 335-3-1605(c)
	(i) If emission results from the above referenced performance test are less than or equal to 75% of the emission limit, then the frequency of subsequent performance tests may be reduced from a semiannual to an annual basis.	
	(ii) If the results of any subsequent performance test exceed 75% of the emission limit, then semiannual performance testing shall resume until the unit demonstrates compliance for two (2) consecutive testing events demonstrating emissions are less than or equal to 75% of the emission limit, at which time annual testing may resume.	
	(iii) After the first performance test conducted following the issuance of this renewal permit, no periodic monitoring will be required if these units do not operate for production purposes during the respective semiannual or annual testing period, whichever applies.	
	(b) The permittee shall only fire natural gas in this unit.	ADEM Admin. Code r. 335-3-1605(c)

		Federally Enforceable Provisos	Regulations
	(c)	This unit is subject to the applicable monitoring requirements of 40 CFR §60.334(h)(3), which include demonstrating the fuel meets the definition of natural gas in 40 CFR §60.331(u) by maintaining a current tariff sheet specifying that the maximum total sulfur content of the fuel is 20.0 grains/100 scf or less.	ADEM Admin. Code r. 335-3-1002(33)
5.	Re	cordkeeping and Reporting Requirements	
	(a)	The permittee shall maintain records of the most current fuel tariff sheet as required by 40 CFR §60.334(h)(3)(i), on-site in a permanent form suitable for inspection for at least five (5) years (2 years on-site and 3 years off-site) from the date of generation of each record.	ADEM Admin. Code r. 335-3-1605(c)
	(b)	The permittee shall submit the results of all emission tests conducted to the Air Division within 30 days of the actual completion of the test unless the Air Division specifically approves an extension of time.	ADEM Admin. Code r. 335-3-1605(c)
	(c)	The permittee shall submit a Semiannual Monitoring Report, as required by General Permit Proviso No. 21(a), no later than 60 days after the end of each semiannual period (January 1st-June 30th and July 1st-December 31st). The report shall include a statement addressing whether only natural gas was fired in this unit and all emission monitoring was conducted as required during the reporting period. If all emission monitoring was not conducted, the report shall explain the reason(s) why it was not performed. The report shall also include a statement addressing whether this unit was operated for production purposes during each respective reporting period.	ADEM Admin. Code r. 335-3-1605(c)

Emission Unit Nos. 019-021 (Emergency Unit Nos. 1-3) Summary Page

Description: Three (3) 375 hp Cooper JS-5G, 4-Stroke, Rich Burn, Natural Gas-fired Reciprocating Engines for Emergency Power

Permitted Operating Schedule: $\frac{24 \text{ Hours}}{\text{Day}} \times \frac{365 \text{ Days}}{\text{Year}} = \frac{8760 \text{ Hours}}{\text{Year}}$

Emission Point Nos.	Description	Pollutant	Emission limit	Regulation
AUX-1	Three (3) 375 hp Cooper JS- 5G, 4-Stroke, Rich Burn, Natural Gas-fired Reciprocating Engines	NO_{x}	N/A	
AUX-2		СО	N/A	
AUX-3		VOC	N/A	ADEM Admin. Code r. 335-3-1106(103)
		SO ₂	N/A	40 CFR Part 63, Subpart ZZZZ
		PM	N/A	
		НАР	N/A	

Emission Unit Nos. 019-021 (Emergency Unit Nos. 1-3)

		Federally Enforceable Provisos	Regulations
1.	<u>Appli</u>	<u>cability</u>	
	A	nese units are subject to the applicable requirements of ADEM dmin. Code r. 335-3-1603, "Major Source Operating ermits."	ADEM Admin. Code r. 335-3-1603
	C fo In fo §6	nese units are subject to the applicable requirements of 40 FR Part 63, Subpart ZZZZ, the National Emission Standards r Hazardous Air Pollutants for Stationary Reciprocating sternal Combustion Engines (RICE), and meet the definition r an emergency stationary RICE as provided by 40 CFR 63.6640(f). The permittee shall only operate these units as mergency stationary RICE as defined in this standard.	ADEM Admin. Code r. 335-3-1106(103)
2.	<u>Emis</u>	sion Standards	
	40	ne permittee shall comply with the applicable requirements of OCFR §63.6602 and Table 2c to Subpart ZZZZ, which clude, but may not be limited to:	40 CFR §63.6602
	(i)	Meet the following work practice requirements, except during periods of startup:	
		A. Change oil and filter every 500 hours of operation or annually, whichever comes first; <i>or</i> participate in the oil analysis program per 40 CFR §63.6625(j);	
		B. Inspect spark plugs every 1,000 hours of operation or annually, whichever comes first, and replace as necessary; and	
		C. Inspect all hoses and belts every 500 hours of operation or annually, whichever comes first, and replace as necessary.	
	(ii	During periods of startup, minimize the engine's time spent at idle and minimize the engine's startup time at startup to a period needed for appropriate and safe loading of the engine, not to exceed 30 minutes, after which time the non-startup emission limitations apply.	

	Federally Enforceable Provisos	Regulations
	(iii) If a unit is operating during an emergency and it is not possible to shut down the engine in order to perform the work practice requirements on the schedule required, or if performing the work practice on the required schedule would otherwise pose an unacceptable risk under Federal, State, or local law, the work practice can be delayed until the emergency is over or the unacceptable risk under Federal, State, or local law has abated. The work practice should be performed as soon as practicable after the emergency has ended or the unacceptable risk under Federal, State, or local law has abated.	
	(b) The permittee shall not operate these units except as provided in 40 CFR §63.6640(f)(1) through (f)(4), which include but may not be limited to:	40 CFR §63.6640
	(i) Emergency Situations;	
	(ii) Operate the emergency stationary RICE for the purpose of maintenance checks and readiness testing, provided that the test are recommended by Federal, State or local government, the manufacturer, the vendor, or the insurance company associated with the engines. Maintenance checks and readiness testing of the units are limited to 100 hours per year; and	
	(iii) Operate the emergency stationary RICE up to 50 hours per year in non-emergency situations, but those 50 hours are counted toward the 100 hours per year provided for maintenance and testing. The 50 hours per year for non-emergency situations cannot be used for peak shaving or to generate income for a facility to supply power to an electric grid or otherwise supply power as part of a financial arrangement with another entity.	
	(c) The permittee shall not discharge more than one six-minute average opacity greater than 20% during any 60-minute period from these units. At no time shall the permittee discharge a six-minute average opacity of particulate emissions greater than 40% from these units.	ADEM Admin. Code r. 335-3-401(1)
3.	Compliance and Performance Test Methods and Procedures	
	If testing is required, opacity shall be determined by 40 CFR Part 60, Appendix A, Reference Method 9.	ADEM Admin. Code r. 335-3-105
4.	Emission Monitoring	
	(a) The permittee shall operate and maintain these units according to the manufacturer's emission-related written instructions or develop a maintenance plan that provides for, to the extent practicable, the maintenance and operation of the engine in a manner consistent with good air pollution control practice for minimizing emissions.	40 CFR §63.6625(e) & 40 CFR §63.6640(a)

	Federally Enforceable Provisos	Regulations
(b)	The permittee shall install a non-resettable hour meter if one is not already installed.	40 CFR §63.6625(f)
(c)	The permittee shall only fire natural gas in these units.	ADEM Admin. Code r. 335-3-1605(c)
(d)	Within 15 days of the end of the month, the permittee shall calculate the hours of operation for these units for the previous calendar month and the previous 12-month period.	ADEM Admin. Code r. 335-3-1605(c)
5. <u>Re</u>	cordkeeping and Reporting Requirements	
(a)	The permittee shall keep records of the operation and maintenance of each unit in accordance with 40 CFR §63.6655. At a minimum, these records shall include:	ADEM Admin. Code r. 335-3-1605(c) and 40 CFR §63.6655
	(i) For each period of operation, the length of operation and the reason the engine was in operation during that time. For periods of operation designated as "emergency operation," the records shall reflect what classified the operation as emergency;	
	(ii) The total number of hours the engine was operated during a calendar year subtotaled by the reason the engine was in operation;	
	(iii) The dates of each oil and filter change with the corresponding hour on the hour meter; <i>or</i> the dates of each oil analysis with the parameters that are analyzed as part of the program, the results of the analysis, and the oil changes for the engine;	
	(iv) The dates of each inspection and replacement of air cleaners, hoses, and belts with the corresponding hour on the hour meter; and	
	(v) The dates and nature of other emission-related repairs and maintenance performed.	
(b)	The permittee shall maintain on-site for the life of each unit either a copy of the manufacturer's emission-related operation and maintenance instructions for the unit or the maintenance plan developed in accordance with 40 CFR §63.6625(e) for each unit.	ADEM Admin. Code r. 335-3-1605(c)
(c)	The permittee shall maintain files of all information (including all reports and notifications) required by 40 CFR Part 63, Subparts A and ZZZZ for these units recorded in a form suitable and readily available for expeditious inspection and review. The files shall be retained for at least 5 years following the date of each occurrence, measurement, maintenance, corrective action, report, or record. At a minimum, the most recent 2 years of data shall be retained on-site. The remaining 3 years of data may be retained off-site.	ADEM Admin. Code r. 335-3-1605(c), 40 CFR §63.6660, and 40 CFR §63.10(b)(1)

	Federally Enforceable Provisos	Regulations
(d)	The permittee shall report to the Air Division any failure to perform a work practice on the schedule required, including instances when the work practice standard was not performed due to emergency operation or unacceptable risk under a federal, state, or local law. The permittee shall submit the report within two working days of the deviation and shall provide an explanation as to why the work practice requirement was not performed.	ADEM Admin. Code r. 335-3-1605(c) and 40 CFR §63.6640(b)
(e)	The permittee shall submit a Semiannual Monitoring Report, as required by General Permit Proviso No. 21(a), no later than 60 days after the end of each semiannual period (January 1st-June 30th and July 1st-December 31st). The report shall include a statement addressing whether only natural gas was fired in these units and all emission monitoring was conducted as required during the reporting period. If all emission monitoring was not conducted, the report shall explain the reason(s) why it was not performed.	ADEM Admin. Code r. 335-3-1605(c)

Emission Unit No. 024 (Emergency Air Compressor Unit No. 5) Summary Page

Description: 135 hp Waukesha VSG, 4-Stroke, Rich Burn, Natural Gas-fired Air Reciprocating Engine/Air Compressor for Emergency Use

Permitted Operating Schedule:
$$\frac{24 \text{ Hours}}{\text{Day}} \times \frac{365 \text{ Days}}{\text{Year}} = \frac{8760 \text{ Hours}}{\text{Year}}$$

Emission Point No.	Description	Pollutant	Emission limit	Regulation
AC-5	135 hp Waukesha VSG, 4- Stroke, Rich Burn, Natural	NOx	N/A	
	Gas-fired Air Reciprocating Engine/Air Compressor	СО	N/A	
	Eligine/Ali Compressor	VOC	N/A	ADEM Admin. Code r. 335-3-1106(103)
		SO ₂	N/A	40 CFR Part 63, Subpart ZZZZ
		PM	N/A	
		НАР	N/A	

Emission Unit No. 024 (Emergency Air Compressor Unit No. 5)

			Federally Enforceable Provisos	Regulations
1.	<u>Ap</u>	olica	ability	
	(a)	Adı	s unit is subject to the applicable requirements of ADEM nin. Code r. 335-3-1603, "Major Source Operating mits."	ADEM Admin. Code r. 335-3-1603
	(b)	Par Haz Cor eme	s unit is subject to the applicable requirements of 40 CFR t 63, Subpart ZZZZ, the National Emission Standards for cardous Air Pollutants for Stationary Reciprocating Internal inbustion Engines (RICE), and meets the definition for an ergency stationary RICE as provided by 40 CFR §63.6640(f). It permittee shall only operate this unit as an emergency tionary RICE as defined in this standard.	ADEM Admin. Code r. 335-3-1106(103)
2.	<u>Em</u>	<u>issi</u>	on Standards	
	(a)	40	permittee shall comply with the applicable requirements of CFR §63.6602 and Table 2c to Subpart ZZZZ, which ude, but may not be limited to:	40 CFR §63.6602
			Meet the following work practice requirements, except during periods of startup:	
			A. Change oil and filter every 500 hours of operation or annually, whichever comes first; <i>or</i> participate in the oil analysis program per 40 CFR §63.6625(j);	
			B. Inspect spark plugs every 1,000 hours of operation or annually, whichever comes first, and replace as necessary; and	
			C. Inspect all hoses and belts every 500 hours of operation or annually, whichever comes first, and replace as necessary.	
		(ii)	During periods of startup, minimize the engine's time spent at idle and minimize the engine's startup time at startup to a period needed for appropriate and safe loading of the engine, not to exceed 30 minutes, after which time the non-startup emission limitations apply.	

	Federally Enforceable Provisos	Regulations
	(iii) If a unit is operating during an emergency and it is not possible to shut down the engine in order to perform the work practice requirements on the schedule required, or it performing the work practice on the required schedule would otherwise pose an unacceptable risk under Federal State, or local law, the work practice can be delayed untite the emergency is over or the unacceptable risk under Federal, State, or local law has abated. The work practice should be performed as soon as practicable after the emergency has ended or the unacceptable risk under Federal, State, or local law has abated.	
	(b) The permittee shall not operate this unit except as provided in 40 CFR §63.6640(f)(1) through (f)(4), which include but may not be limited to:	
	(i) Emergency Situations;	
	(ii) Operate the emergency stationary RICE for the purpose of maintenance checks and readiness testing, provided that the test are recommended by Federal, State or local government, the manufacturer, the vendor, or the insurance company associated with the engines Maintenance checks and readiness testing of the unit is limited to 100 hours per year; and	
	(iii) Operate the emergency stationary RICE up to 50 hours per year in non-emergency situations, but those 50 hours are counted toward the 100 hours per year provided for maintenance and testing. The 50 hours per year for non-emergency situations cannot be used for peak shaving or to generate income for a facility to supply power to an electric grid or otherwise supply power as part of a financial arrangement with another entity.	
	(c) The permittee shall not discharge more than one six-minute average opacity greater than 20% during any 60-minute period from this unit. At no time shall the permittee discharge a six minute average opacity of particulate emissions greater than 40% from this unit.	ADEM Admin. Code r. 335-3-401(1)
3.	Compliance and Performance Test Methods and Procedures	
	If testing is required, opacity shall be determined by 40 CFR Part 60, Appendix A, Reference Method 9.	ADEM Admin. Code r. 335-3-105
4.	Emission Monitoring	
	(a) The permittee shall operate and maintain this unit according to the manufacturer's emission-related written instructions of develop a maintenance plan that provides for, to the extension practicable, the maintenance and operation of the engine in a manner consistent with good air pollution control practice for minimizing emissions.	40 CFR §63.6640(a)

	Federally Enforceable Provisos	Regulations
(b)	The permittee shall install a non-resettable hour meter if one is not already installed.	40 CFR §63.6625(f)
(c)	The permittee shall only fire natural gas in this unit.	ADEM Admin. Code r. 335-3-1605(c)
(d)	Within 15 days of the end of the month, the permittee shall calculate the hours of operation for this unit for the previous calendar month and the previous 12-month period.	ADEM Admin. Code r. 335-3-1605(c)
5. <u>Re</u>	cordkeeping and Reporting Requirements	
(a)	The permittee shall keep records of the operation and maintenance of this unit in accordance with 40 CFR §63.6655. At a minimum, these records shall include:	ADEM Admin. Code r. 335-3-1605(c) and 40 CFR §63.6655
	(i) For each period of operation, the length of operation and the reason the engine was in operation during that time. For periods of operation designated as "emergency operation," the records shall reflect what classified the operation as emergency;	
	(ii) The total number of hours the engine was operated during a calendar year subtotaled by the reason the engine was in operation;	
	(iii) The dates of each oil and filter change with the corresponding hour on the hour meter; <i>or</i> the dates of each oil analysis with the parameters that are analyzed as part of the program, the results of the analysis, and the oil changes for the engine;	
	(iv) The dates of each inspection and replacement of air cleaners, hoses, and belts with the corresponding hour on the hour meter; and	
	(v) The dates and nature of other emission-related repairs and maintenance performed.	
(b)	The permittee shall maintain on-site for the life of this unit either a copy of the manufacturer's emission-related operation and maintenance instructions for the unit or the maintenance plan developed in accordance with 40 CFR §63.6625(e) for the unit.	ADEM Admin. Code r. 335-3-1605(c)
(c)	The permittee shall maintain files of all information (including all reports and notifications) required by 40 CFR Part 63, Subparts A and ZZZZ for this unit recorded in a form suitable and readily available for expeditious inspection and review. The files shall be retained for at least 5 years following the date of each occurrence, measurement, maintenance, corrective action, report, or record. At a minimum, the most recent 2 years of data shall be retained on-site. The remaining 3 years of data may be retained off-site.	ADEM Admin. Code r. 335-3-1605(c), 40 CFR §63.6660, and 40 CFR §63.10(b)(1)

	Federally Enforceable Provisos	Regulations
(d)	The permittee shall report to the Air Division any failure to perform a work practice on the schedule required, including instances when the work practice standard was not performed due to emergency operation or unacceptable risk under a federal, state, or local law. The permittee shall submit the report within two working days of the deviation and shall provide an explanation as to why the work practice requirement was not performed.	ADEM Admin. Code r. 335-3-1605(c) and 40 CFR §63.6640(b)
(e)	The permittee shall submit a Semiannual Monitoring Report, as required by General Permit Proviso No. 21(a), no later than 60 days after the end of each semiannual period (January 1st-June 30th and July 1st-December 31st). The report shall include a statement addressing whether only natural gas was fired in this unit and all emission monitoring was conducted as required during the reporting period. If all emission monitoring was not conducted, the report shall explain the reason(s) why it was not performed.	ADEM Admin. Code r. 335-3-1605(c)

Emission Unit No. 025 (Mainline Unit No. 17) Summary Page

Description: 17,239 hp Solar Mars 100-16000S, Natural Gas-fired Combustion Turbine equipped with a Dry Low NOx Combustor

Permitted Operating Schedule:
$$\frac{24 \text{ Hours}}{\text{Day}} \times \frac{365 \text{ Days}}{\text{Year}} = \frac{8760 \text{ Hours}}{\text{Year}}$$

Emission Point No.	Description	Pollutant	Emission limit	Regulation
MLU-17	MLU-17 17,239 hp Solar Mars Natural Gas-fired Combustion Turbine	NO_x	42 ppmvd @15% O ₂	ADEM Admin Code r. 335-3-1002(89) 40 CFR 60, Subpart KKKK (NSPS)
		СО	N/A	N/A
		VOC	N/A	N/A
		SO ₂	26 ng SO ₂ /J (0.060 lb SO ₂ /MMBtu) OR Fuel Sulfur Content < 20 grains per 100 standard cubic feet	ADEM Admin Code r. 335-3-1002(89) 40 CFR 60, Subpart KKKK (NSPS)
		PM	N/A	N/A
		HAP	N/A	N/A

Emission Unit No. 025 (Mainline Unit No. 17)

	Federally Enforceable Provisos	Regulations
1.	Applicability	
	(a) This unit is subject to the applicable requirements of ADEN Admin. Code r. 335-3-1603, "Major Source Operatin Permits."	
	(b) This unit is subject to the applicable requirements of 40 CFI Part 60, Subpart KKKK, the Standards of Performance for Stationary Combustion Turbines.	
	(c) This unit is an affected source under 40 CFR Part 63, Subpar YYYY, the National Emission Standards for Hazardous Air Pollutants for Stationary Combustion Turbines.	
2.	Emission Standards	
	(a) This unit is subject to the applicable emission standards of 40 CFR $\S60.4320$. The permittee shall not cause or allow emissions of nitrogen oxides (NO _x) from this unit in excess of 42 ppmvd @ 15% O ₂ .	335-3-1002(89)
	(b) This unit is subject to the applicable emission standards of 40 CFR $\S60.4330$. The permittee shall not cause or allow emissions of sulfur dioxide (SO ₂) from this unit in excess of 20 ng SO ₂ /J (0.060 lb SO ₂ /MMBtu) heat input OR, as at alternative, no fuel shall be burned in the unit that contain sulfur in excess of 20 grains per 100 standard cubic feet.	7 335-3-1002(89) 5 1
	(c) The permittee shall not discharge more than one six-minut average opacity greater than 20% in any 60-minute period from this unit. At no time shall the permittee discharge a six-minute average opacity of particulate emissions greater than 40% from this unit.	335-3-401(1)
3.	Compliance and Performance Test Methods and Procedures	
	(a) Compliance with the nitrogen oxides (NO _x) emission rate of this unit shall be determined by EPA Reference Methods 1, 2, 3 and 4 or 19, and EPA Reference Method 7E in Appendix A of 40 CFI Part 60. Alternate test methods may be used provided prior approval by the Air Division is granted.	1 335-3-105 2
	(b) This unit is subject to the applicable testing and procedur requirements of 40 CFR §60.4365, which include determining the sulfur content of the fuel burned in the turbine is accordance with one of the methods described in 40 CFI §60.4365(a).	g 335-3-1002(89)
	(c) If testing is required, opacity shall be determined by 40 CFI Part 60, Appendix A, Method 9.	ADEM Admin. Code r. 335-3-105

		Federally Enforceable Provisos	Regulations
4.	En	nission Monitoring	
	(a)	Emission testing shall be conducted annually to determine compliance with the applicable emission standard. Testing shall be conducted once per calendar year, with no more than fourteen (14) calendar months elapsing between tests. In accordance with 40 CFR 60.4340(a), if the NOx emissions results from the initial performance test is less than 75 percent of the NOx emission limit for the turbine, the frequency of subsequent performance tests may be reduced to once every two (2) years (no more than 26 calendar months following the previous performance test). If the results of any subsequent performance test exceeds 75 percent of the NOx emission limits for the turbine, annual performance tests must be resumed.	ADEM Admin. Code r. 335-3-1002(89)
	(b)	The permitee shall perform subsequent emission testing once per calendar year during which the unit operates for the purposes of production. The subsequent annual emission testing may be conducted using either an approved EPA Reference Method or with a portable analyzer. Periodic monitoring may be conducted concurrently with the annual or biennial EPA Reference Method test that is required by 40 CFR Part 60, Subpart KKKK. No periodic monitoring will be required if the unit does not operate for production purposes during the annual testing period.	ADEM Admin. Code r. 335-3-1605(c)
	(c)	The permittee shall only fire natural gas in this unit.	ADEM Admin. Code r. 335-3-1605(c)
	(d)	This unit is subject to the applicable monitoring requirements of 40 CFR $\$60.4365$, which include monitoring the total sulfur content of the fuel being fired in the unit. The permittee may demonstrate compliance with the applicable SO_2 emission standard by the use of the fuel quality characteristics in a current, valid purchase contract, tariff sheet or transportation contract for the fuel which specifies that the total sulfur content is 20 grains of sulfur or less per 100 standard cubic feet.	ADEM Admin. Code r. 335-3-1002(89)
5.	Re	cordkeeping and Reporting Requirements	
	(a)	The permittee shall maintain records of the most current fuel tariff sheet as required by 40 CFR §60.4365, on-site in a permanent form suitable for inspection for at least five (5) years (2 years on-site and 3 years off-site) from the date of generation of each record.	ADEM Admin. Code r. 335-3-1605(c)
	(b)	The permittee shall submit the results of all emission tests conducted to the Air Division within 60 days of the actual completion of the test unless the Air Division specifically approves an extension of time.	ADEM Admin. Code r. 335-3-1002(89)

Federally Enforceable Provisos	Regulations
(c) The permittee shall submit a Semiannual Monitoring Report, as required by General Permit Proviso No. 21(a), no later than 60 days after the end of each semiannual period (January 1 st -June 30 th and July 1 st -December 31 st). The report shall include a statement addressing whether only natural gas was fired in this unit and all emission monitoring was conducted as required during the reporting period. If all emission monitoring was not conducted, the report shall explain the reason(s) why it was not performed.	ADEM Admin. Code r. 335-3-1605(c)