

Final Report: 2020 Per- and Polyfluoroalkyl Substances (PFAS) Sampling Program

In May 2016, the US Environmental Protection Agency (EPA) issued long-term health advisories for two per- and polyfluoroalkyl substances (PFAS) known as PFOA and PFOS. As a result of data collected in 2013-2015 during EPA's Unregulated Contaminant Monitoring Rule 3 (UCMR3), several water systems in Alabama were identified that exceeded the health advisory levels. The Department worked with the Alabama Department of Public Health to monitor and ensure that these water systems took appropriate action to notify their customers, and if needed, switch to alternate sources or install treatment.

EPA has not yet established regulatory standards for PFAS in drinking water. The lifetime health advisory level for PFOA and PFOS is a combined 70 parts per trillion, or 0.00007 mg/L. Currently, EPA has not developed advisory levels for any other PFAS.

UCMR3 required all large systems and a representative sample of small systems to monitor for several PFAS compounds. However, once UCMR3 was complete there remained a significant number of drinking water sources in the state that had never been sampled for the presence of PFAS compounds. In 2019, the Department amended its Division 7 rules to allow for sampling of these sources so that consumers would have more complete information about their drinking water, and to determine if there are any contaminant sources that warrant further investigation.

In accordance with ADEM Admin. Code r. 335-7-2-.10, the Department instructed water systems to carry out PFAS monitoring at all sources not previously sampled during UCMR3. The prescribed method was the latest EPA Method (537.1), which measures 18 PFAS compounds. Ground sources (wells) were required to sample once January 1 – June 30, 2020, and once July 1 – December 31, 2020. Surface water sources were required to sample once per quarter. As data was received, the Department posted quarterly updates on its website for any detections above the method reporting limit. A total of 290 water systems submitted PFAS data during the year.

The results of this sampling effort are encouraging. The only results above the lifetime health advisory level for PFOA and PFOS were recorded at Centre Water & Sewer Board - which was identified during UCMR3 as a system of concern, and completed construction of treatment to remove PFAS during 2020. Only 57 water systems detected *any* PFAS compound above the method reporting limit.

The next major PFAS in drinking water sampling program will be UCMR5, which will sample for 29 PFAS contaminants in 2023-2025. This will occur at all water systems serving 3,300 or more persons, and a representative sample of water systems serving 25-3,299 persons.

The following pages show the results for PFAS detections and are tabulated alphabetically by water system name. If your water system is not listed in the results, this means they did not have any detections during the 2020 sampling. If you wish to view all PFAS-related documents and monitoring data that has been submitted to the Department for your water system, go to [eFile](#), select Media Area "Water", enter the PWSID number for the Permit Number or the water system name for the facility, and enter "PFC" for the File Name.

All PFAS Results >MRL

Note: The EPA lifetime health advisory for PFOA and PFOS combined is 70 PPT.
EPA has not issued health advisories for the other PFAS compounds.

| <u>System Name</u> | <u>PWSID</u> | <u>Source Name</u> | <u>Analyte Name</u> | <u>Collection Date</u> | <u>PPT</u> |
|-----------------------------|------------------|--|---------------------|------------------------|------------|
| ARDMORE WATER SYSTEM | AL0001420 | | | | |
| | | <i>WELL #1 TREATMENT PLANT</i> | | | |
| | | | PFOS | 2/28/2020 | 12.0 |
| | | | PFOA | 2/28/2020 | 4.7 |
| | | <i>WELL #2 TREATMENT PLANT</i> | | | |
| | | | PFOS | 2/28/2020 | 8.1 |
| | | <i>WELL #3 TENNESSEE TREATMENT PLANT</i> | | | |
| | | | PFOS | 2/28/2020 | 10.0 |
| | | | PFOA | 2/28/2020 | 5.3 |
| | | | PFOS | 8/13/2020 | 6.7 |

| <u>System Name</u> | <u>PWSID</u> | <u>Source Name</u> | <u>Analyte Name</u> | <u>Collection Date</u> | <u>PPT</u> |
|---------------------------|------------------|------------------------------------|---------------------|------------------------|------------|
| ARITON WATER WORKS | AL0000416 | | | | |
| | | <i>WELL #2 + TREATMENT PLANT</i> | | | |
| | | | 11CI-PF3OUdS | 5/7/2020 | 3.8 |
| | | | PFDaA | 5/7/2020 | 4.4 |
| | | | PFTTrDA | 5/7/2020 | 4.3 |
| | | | PFOuA | 5/7/2020 | 3.8 |
| | | <i>WELL #3 + TREATMENT PLANT</i> | | | |
| | | | 11CI-PF3OUdS | 5/7/2020 | 7.0 |
| | | | 9CI-PF3ONS | 5/7/2020 | 4.0 |
| | | | NEtFOSAA | 5/7/2020 | 7.1 |
| | | | NMeFOSAA | 5/7/2020 | 6.3 |
| | | | PFDA | 5/7/2020 | 3.9 |
| | | | PFDaA | 5/7/2020 | 9.5 |
| | | | PFTA | 5/7/2020 | 7.5 |
| | | | PFTTrDA | 5/7/2020 | 8.9 |
| | | | PFOuA | 5/7/2020 | 7.7 |
| ARLEY WATER WORKS | AL0001403 | | | | |
| | | <i>ARLEY WATER TREATMENT PLANT</i> | | | |
| | | | PFOS | 1/22/2020 | 4.9 |

| <u>System Name</u> | <u>PWSID</u> | <u>Source Name</u> | <u>Analyte Name</u> | <u>Collection Date</u> | <u>PPT</u> |
|-------------------------------|------------------|-------------------------------|---------------------|------------------------|------------|
| AUBURN WATER WORKS | AL0000804 | <i>WELL 3 TREATMENT PLANT</i> | | | |
| | | | PFBS | 5/20/2020 | 3.4 |
| | | | PFOS | 5/20/2020 | 3.8 |
| | | | PFOA | 5/20/2020 | 12.0 |
| | | | PFHpA | 5/20/2020 | 4.2 |
| | | | PFHxS | 5/20/2020 | 3.0 |
| | | | PFHxA | 5/20/2020 | 3.5 |
| | | | PFBS | 7/15/2020 | 2.5 |
| | | | PFOS | 7/15/2020 | 2.4 |
| | | | PFOA | 7/15/2020 | 10.0 |
| | | | PFHpA | 7/15/2020 | 3.5 |
| | | | PFHxS | 7/15/2020 | 2.5 |
| | | | PFHxA | 7/15/2020 | 3.1 |
| | | | PFBS | 10/21/2020 | 3.2 |
| | | | PFOS | 10/21/2020 | 2.3 |
| | | | PFOA | 10/21/2020 | 11.0 |
| | | | PFHpA | 10/21/2020 | 4.0 |
| | | | PFHxS | 10/21/2020 | 3.2 |
| | | | PFHxA | 10/21/2020 | 3.6 |
| BELFOREST WATER SYSTEM | AL0000025 | <i>WELL 2 TREATMENT PLANT</i> | | | |
| | | | PFOS | 1/22/2020 | 3.8 |
| | | | PFOA | 1/22/2020 | 3.9 |
| | | | PFHxS | 1/22/2020 | 5.6 |

| <u>System Name</u> | <u>PWSID</u> | <u>Source Name</u> | <u>Analyte Name</u> | <u>Collection Date</u> | <u>PPT</u> |
|--|------------------|--|---------------------|------------------------|------------|
| BRIDGEPORT UTILITIES BOARD | AL0000713 | <i>TENNESSEE RIVER + TREATMENT PLANT</i> | | | |
| | | | PFHxA | 8/26/2020 | 1.5 |
| | | | HFPO-DA | 10/21/2020 | 2.0 |
| | | | PFBS | 10/21/2020 | 3.5 |
| | | | PFOS | 10/21/2020 | 2.5 |
| CAA-CTC PLAINVIEW HEAD START PROGRA | AL0000181 | <i>WELL + TREATMENT PLANT</i> | | | |
| | | | PFOS | 2/17/2020 | 20.0 |
| | | | PFOA | 2/17/2020 | 9.8 |
| | | | PFHpA | 2/17/2020 | 2.4 |
| | | | PFHxS | 2/17/2020 | 2.9 |
| | | | PFHxA | 2/17/2020 | 6.5 |
| | | | PFOS | 7/15/2020 | 24.0 |
| | | | PFOA | 7/15/2020 | 11.0 |
| | | | PFHpA | 7/15/2020 | 2.2 |
| | | | PFHxS | 7/15/2020 | 3.6 |
| | | | PFHxA | 7/15/2020 | 6.9 |

System Name

PWSID

Source Name

Analyte Name

Collection Date

PPT

CENTRE WATER & SEWER BOARD

AL0000188

CENTRE WATER PLANT

| | | |
|-------|-----------|------|
| PFBS | 2/28/2020 | 54.0 |
| PFOS | 2/28/2020 | 20.0 |
| PFOA | 2/28/2020 | 13.0 |
| PFHpA | 2/28/2020 | 4.4 |
| PFHxA | 2/28/2020 | 9.4 |
| PFBS | 5/15/2020 | 71.0 |
| PFBS | 5/15/2020 | 71.0 |
| PFBS | 5/15/2020 | 75.0 |
| PFBS | 5/15/2020 | 75.0 |
| PFOS | 5/15/2020 | 38.0 |
| PFOS | 5/15/2020 | 35.0 |
| PFOS | 5/15/2020 | 35.0 |
| PFOS | 5/15/2020 | 38.0 |
| PFOA | 5/15/2020 | 23.0 |
| PFOA | 5/15/2020 | 23.0 |
| PFOA | 5/15/2020 | 22.0 |
| PFOA | 5/15/2020 | 22.0 |
| PFHpA | 5/15/2020 | 7.8 |
| PFHpA | 5/15/2020 | 7.8 |
| PFHpA | 5/15/2020 | 7.8 |
| PFHpA | 5/15/2020 | 7.8 |
| PFHxS | 5/15/2020 | 3.8 |
| PFHxS | 5/15/2020 | 3.9 |

| <u>System Name</u> | <u>PWSID</u> | <u>Source Name</u> | <u>Analyte Name</u> | <u>Collection Date</u> | <u>PPT</u> |
|--------------------|--------------|--------------------|---------------------|------------------------|------------|
| | | | PFHxS | 5/15/2020 | 3.9 |
| | | | PFHxS | 5/15/2020 | 3.8 |
| | | | PFBS | 6/19/2020 | 86.0 |
| | | | PFOS | 6/19/2020 | 29.0 |
| | | | PFOA | 6/19/2020 | 25.0 |
| | | | PFHpA | 6/19/2020 | 8.1 |
| | | | PFBS | 7/10/2020 | 70.0 |
| | | | PFOS | 7/10/2020 | 28.0 |
| | | | PFOA | 7/10/2020 | 22.0 |
| | | | PFDA | 7/10/2020 | 3.1 |
| | | | PFHpA | 7/10/2020 | 7.9 |
| | | | PFHxS | 7/10/2020 | 2.6 |
| | | | PFHxA | 7/10/2020 | 32.0 |
| | | | PFNA | 7/10/2020 | 1.8 |
| | | | PFBS | 8/14/2020 | 37.0 |
| | | | PFOS | 8/14/2020 | 15.0 |
| | | | PFOA | 8/14/2020 | 13.0 |
| | | | PFHpA | 8/14/2020 | 5.3 |
| | | | PFHxA | 8/14/2020 | 23.0 |
| | | | PFBS | 9/4/2020 | 115.0 |
| | | | PFBS | 9/4/2020 | 154.0 |
| | | | PFOS | 9/4/2020 | 44.0 |
| | | | PFOS | 9/4/2020 | 46.0 |
| | | | PFOA | 9/4/2020 | 31.0 |

| <u>System Name</u> | <u>PWSID</u> | <u>Source Name</u> | <u>Analyte Name</u> | <u>Collection Date</u> | <u>PPT</u> |
|--------------------|--------------|--------------------|---------------------|------------------------|------------|
| | | | PFOA | 9/4/2020 | 39.0 |
| | | | PFHpA | 9/4/2020 | 11.0 |
| | | | PFHpA | 9/4/2020 | 14.0 |
| | | | PFHxA | 9/4/2020 | 45.0 |
| | | | PFHxA | 9/4/2020 | 61.0 |
| | | | PFBS | 10/23/2020 | 210.0 |
| | | | PFBS | 10/23/2020 | 191.0 |
| | | | PFOS | 10/23/2020 | 78.0 |
| | | | PFOS | 10/23/2020 | 73.0 |
| | | | PFOA | 10/23/2020 | 39.0 |
| | | | PFOA | 10/23/2020 | 41.0 |
| | | | PFHpA | 10/23/2020 | 16.0 |
| | | | PFHpA | 10/23/2020 | 15.0 |
| | | | PFHxS | 10/23/2020 | 7.0 |
| | | | PFHxS | 10/23/2020 | 6.9 |
| | | | PFHxA | 10/23/2020 | 44.0 |
| | | | PFHxA | 10/23/2020 | 47.0 |
| | | | PFBS | 11/20/2020 | 70.0 |
| | | | PFOS | 11/20/2020 | 25.0 |
| | | | PFOA | 11/20/2020 | 18.0 |
| | | | PFHpA | 11/20/2020 | 7.2 |
| | | | PFHxA | 11/20/2020 | 24.0 |

| <u>System Name</u> | <u>PWSID</u> | <u>Source Name</u> | <u>Analyte Name</u> | <u>Collection Date</u> | <u>PPT</u> |
|---|------------------|-------------------------------------|---------------------|------------------------|------------|
| CHATTAHOOCHEE VALLEY WATER SUPPLY DI | AL0000184 | | | | |
| | | <i>CHATTAHOOCHEE VALLEY WSD WTP</i> | | | |
| | | | PFBS | 3/10/2020 | 2.9 |
| | | | PFOS | 3/10/2020 | 2.4 |
| | | | PFOA | 3/10/2020 | 2.1 |
| | | | PFHxS | 3/10/2020 | 2.1 |
| | | | PFHxA | 3/10/2020 | 2.1 |
| | | | PFBS | 4/14/2020 | 4.3 |
| | | | PFOS | 4/14/2020 | 2.3 |
| | | | PFOA | 4/14/2020 | 2.1 |
| | | | PFHxA | 4/14/2020 | 2.6 |
| | | | PFBS | 7/14/2020 | 5.7 |
| | | | PFBS | 7/14/2020 | 5.7 |
| | | | PFOS | 7/14/2020 | 3.8 |
| | | | PFOS | 7/14/2020 | 3.8 |
| | | | PFOA | 7/14/2020 | 3.3 |
| | | | PFOA | 7/14/2020 | 3.3 |
| | | | PFHxS | 7/14/2020 | 0.2 |
| | | | PFHxS | 7/14/2020 | 2.0 |
| | | | PFHxA | 7/14/2020 | 5.8 |
| | | | PFHxA | 7/14/2020 | 5.8 |
| | | | PFBS | 10/20/2020 | 8.2 |
| | | | PFOS | 10/20/2020 | 4.2 |
| | | | PFOA | 10/20/2020 | 3.4 |
| | | | PFHpA | 10/20/2020 | 2.2 |

| <u>System Name</u> | <u>PWSID</u> | <u>Source Name</u> | <u>Analyte Name</u> | <u>Collection Date</u> | <u>PPT</u> |
|--|------------------|--|---------------------|------------------------|------------|
| | | | PFHxS | 10/20/2020 | 2.3 |
| | | | PFHxA | 10/20/2020 | 6.9 |
| CHEROKEE WATER & GAS DEPARTMENT | AL0000311 | | | | |
| | | <i>TENNESSEE RIVER + TREATMENT PLANT</i> | | | |
| | | | PFBS | 2/4/2020 | 4.5 |
| | | | PFOS | 2/4/2020 | 14.0 |
| | | | PFOA | 2/4/2020 | 7.8 |
| | | | PFBS | 5/5/2020 | 3.7 |
| | | | PFOS | 5/5/2020 | 13.0 |
| | | | PFOA | 5/5/2020 | 6.0 |
| | | | PFOS | 8/6/2020 | 8.8 |

| <u>System Name</u> | <u>PWSID</u> | <u>Source Name</u> | <u>Analyte Name</u> | <u>Collection Date</u> | <u>PPT</u> |
|---|------------------|----------------------------------|---------------------|------------------------|------------|
| CHILDERSBURG WATER & SEWER BOARD | AL0001228 | | | | |
| | | <i>WELL #1 + TREATMENT PLANT</i> | | | |
| | | | PFOS | 9/15/2020 | 2.4 |
| | | <i>WELL #2 + TREATMENT PLANT</i> | | | |
| | | | PFOS | 9/15/2020 | 7.8 |
| | | | PFOA | 9/15/2020 | 1.9 |
| | | | PFHxA | 9/15/2020 | 2.2 |
| | | <i>WELL #3 + TREATMENT PLANT</i> | | | |
| | | | PFOS | 9/15/2020 | 1.8 |
| | | | PFOA | 9/15/2020 | 1.8 |
| | | | PFHxA | 9/15/2020 | 1.8 |
| | | <i>WELL #4 + TREATMENT PLANT</i> | | | |
| | | | PFBS | 9/15/2020 | 2.8 |
| | | | PFOS | 9/15/2020 | 1.6 |
| | | | PFOA | 9/15/2020 | 0.3 |
| | | | PFHpA | 9/15/2020 | 5.1 |
| | | | PFHxS | 9/15/2020 | 6.9 |
| | | | PFHxA | 9/15/2020 | 1.2 |

| <u>System Name</u> | <u>PWSID</u> | <u>Source Name</u> | <u>Analyte Name</u> | <u>Collection Date</u> | <u>PPT</u> |
|---|------------------|------------------------|---------------------|------------------------|------------|
| COOSA VALLEY WATER SUPPLY DISTRICT | AL0001805 | <i>TREATMENT PLANT</i> | | | |
| | | | PFBS | 2/19/2020 | 59.0 |
| | | | PFOS | 2/19/2020 | 15.0 |
| | | | PFOA | 2/19/2020 | 11.0 |
| | | | PFHpA | 2/19/2020 | 4.8 |
| | | | PFHxA | 2/19/2020 | 14.0 |
| | | | PFBS | 3/11/2020 | 34.0 |
| | | | PFOS | 3/11/2020 | 10.0 |
| | | | PFOA | 3/11/2020 | 7.6 |
| | | | PFHxA | 3/11/2020 | 8.9 |
| | | | PFBS | 5/18/2020 | 44.0 |
| | | | PFOS | 5/18/2020 | 21.0 |
| | | | PFOA | 5/18/2020 | 12.0 |
| | | | PFHpA | 5/18/2020 | 4.8 |
| | | | PFBS | 6/10/2020 | 40.0 |
| | | | PFBS | 6/10/2020 | 40.0 |
| | | | PFOS | 6/10/2020 | 20.0 |
| | | | PFOS | 6/10/2020 | 20.0 |
| | | | PFOA | 6/10/2020 | 12.0 |
| | | | PFOA | 6/10/2020 | 12.0 |
| | | | PFHpA | 6/10/2020 | 4.5 |
| | | | PFHpA | 6/10/2020 | 4.5 |
| | | | PFHxA | 6/10/2020 | 11.0 |
| | | | PFBS | 8/17/2020 | 57.0 |

| <u>System Name</u> | <u>PWSID</u> | <u>Source Name</u> | <u>Analyte Name</u> | <u>Collection Date</u> | <u>PPT</u> |
|---|------------------|-------------------------------|---------------------|------------------------|------------|
| | | | PFOS | 8/17/2020 | 29.0 |
| | | | PFOA | 8/17/2020 | 17.0 |
| | | | PFHxA | 8/17/2020 | 28.0 |
| | | | PFBS | 8/28/2020 | 39.0 |
| | | | PFBS | 8/28/2020 | 39.0 |
| | | | PFOS | 8/28/2020 | 19.0 |
| | | | PFOS | 8/28/2020 | 19.0 |
| | | | PFOA | 8/28/2020 | 13.0 |
| | | | PFOA | 8/28/2020 | 13.0 |
| | | | PFHxA | 8/28/2020 | 20.0 |
| | | | PFHxA | 8/28/2020 | 20.0 |
| | | | PFUnA | 8/28/2020 | 91.0 |
| DEER PARK-VINEGAR BEND WATER & FPA | AL0001368 | <i>WELL 1 TREATMENT PLANT</i> | | | |
| | | | PFOS | 9/30/2020 | 5.3 |
| FAIRVIEW WATER SYSTEM (CONECUH) | AL0000339 | <i>WELL + TREATMENT PLANT</i> | | | |
| | | | PFOS | 9/17/2020 | 6.6 |

System Name

PWSID

Source Name

Analyte Name

Collection Date

PPT

FIVE STAR WATER SUPPLY DISTRICT

AL0001780

FIVE STAR TREATMENT PLANT

| | | |
|-------|-----------|------|
| PFBS | 2/19/2020 | 32.0 |
| PFOS | 2/19/2020 | 20.0 |
| PFOA | 2/19/2020 | 14.0 |
| PFDA | 2/19/2020 | 2.3 |
| PFHpA | 2/19/2020 | 4.6 |
| PFHxS | 2/19/2020 | 2.5 |
| PFHxA | 2/19/2020 | 10.0 |
| PFBS | 4/15/2020 | 65.0 |
| PFOS | 4/15/2020 | 22.0 |
| PFOA | 4/15/2020 | 17.0 |
| PFDA | 4/15/2020 | 1.8 |
| PFHpA | 4/15/2020 | 6.0 |
| PFHxS | 4/15/2020 | 2.5 |
| PFHxA | 4/15/2020 | 16.0 |
| PFNA | 4/15/2020 | 1.7 |
| PFBS | 7/15/2020 | 52.0 |
| PFBS | 7/15/2020 | 52.0 |
| PFOS | 7/15/2020 | 23.0 |
| PFOS | 7/15/2020 | 23.0 |
| PFOA | 7/15/2020 | 19.0 |
| PFOA | 7/15/2020 | 19.0 |
| PFDA | 7/15/2020 | 2.5 |
| PFDA | 7/15/2020 | 2.5 |

| <u>System Name</u> | <u>PWSID</u> | <u>Source Name</u> | <u>Analyte Name</u> | <u>Collection Date</u> | <u>PPT</u> |
|---|------------------|------------------------------------|---------------------|------------------------|------------|
| | | | PFHpA | 7/15/2020 | 5.8 |
| | | | PFHpA | 7/15/2020 | 5.8 |
| | | | PFHxS | 7/15/2020 | 3.0 |
| | | | PFHxS | 7/15/2020 | 3.0 |
| | | | PFHxA | 7/15/2020 | 16.0 |
| | | | PFHxA | 7/15/2020 | 16.0 |
| | | | PFNA | 7/15/2020 | 2.0 |
| | | | PFNA | 7/15/2020 | 2.0 |
| | | | PFBS | 10/21/2020 | 54.0 |
| | | | PFOS | 10/21/2020 | 10.0 |
| | | | PFOA | 10/21/2020 | 12.0 |
| | | | PFHpA | 10/21/2020 | 4.6 |
| | | | PFHxS | 10/21/2020 | 1.8 |
| | | | PFHxA | 10/21/2020 | 24.0 |
| FOLEY (UTILITIES BOARD OF THE CITY OF) | AL0000036 | | | | |
| | | <i>MCALILEY TREATMENT PLANT</i> | | | |
| | | | PFOS | 8/3/2020 | 7.1 |
| | | | PFOA | 8/3/2020 | 2.3 |
| | | | PFHxS | 8/3/2020 | 2.8 |
| | | | PFHxA | 8/3/2020 | 2.7 |
| | | <i>SOUTH FOLEY TREATMENT PLANT</i> | | | |
| | | | PFOS | 8/3/2020 | 2.6 |
| | | | PFOA | 8/3/2020 | 2.0 |
| | | | PFHxS | 8/3/2020 | 2.2 |

| <u>System Name</u> | <u>PWSID</u> | <u>Source Name</u> | <u>Analyte Name</u> | <u>Collection Date</u> | <u>PPT</u> |
|------------------------------------|------------------|-------------------------------|---------------------|------------------------|------------|
| FRISCO CITY WATER SYSTEM | AL0001047 | | | | |
| | | <i>WELL 1 TREATMENT PLANT</i> | | | |
| | | | PFBS | 1/27/2020 | 3.9 |
| | | | PFOS | 1/27/2020 | 14.0 |
| | | | PFOA | 1/27/2020 | 3.9 |
| | | | PFHxS | 1/27/2020 | 4.2 |
| | | | PFOS | 8/7/2020 | 13.0 |
| | | <i>WELL 2 TREATMENT PLANT</i> | | | |
| | | | PFOS | 1/27/2020 | 12.0 |
| | | | PFOA | 1/27/2020 | 3.6 |
| | | | PFHxS | 1/27/2020 | 4.1 |
| | | | PFOS | 8/7/2020 | 14.0 |
| GLENCOE WATER WORKS BOARD | AL0000578 | | | | |
| | | <i>WELL 2 TREATMENT PLANT</i> | | | |
| | | | PFOS | 9/15/2020 | 1.9 |
| GRAND BAY WATER WORKS BOARD | AL0000983 | | | | |
| | | <i>WELL 1 TREATMENT PLANT</i> | | | |
| | | | PFOS | 2/3/2020 | 23.0 |
| | | | PFOA | 2/3/2020 | 26.0 |
| | | | PFHpA | 2/3/2020 | 6.7 |
| | | | PFOS | 8/3/2020 | 6.8 |
| | | | PFOA | 8/3/2020 | 8.7 |

| <u>System Name</u> | <u>PWSID</u> | <u>Source Name</u> | <u>Analyte Name</u> | <u>Collection Date</u> | <u>PPT</u> |
|-------------------------------|------------------|-------------------------------|---------------------|------------------------|------------|
| GROVE HILL WATER WORKS | AL0000255 | | | | |
| | | <i>WELL 1 TREATMENT PLANT</i> | | | |
| | | | PFOS | 3/27/2020 | 13.0 |
| | | | PFHxS | 3/27/2020 | 6.8 |
| | | | PFHxA | 3/27/2020 | 4.2 |
| | | | PFOS | 9/29/2020 | 13.0 |
| | | | PFHxS | 9/29/2020 | 6.1 |
| | | | PFHxA | 9/29/2020 | 6.3 |
| | | <i>WELL 2 TREATMENT PLANT</i> | | | |
| | | | PFHxS | 3/27/2020 | 6.1 |
| | | <i>WELL 3 TREATMENT PLANT</i> | | | |
| | | | PFOS | 3/27/2020 | 6.5 |
| | | | PFHxS | 3/27/2020 | 4.9 |
| | | | PFOS | 9/29/2020 | 5.1 |
| | | <i>WELL 4 TREATMENT PLANT</i> | | | |
| | | | PFBS | 3/27/2020 | 5.3 |

| <u>System Name</u> | <u>PWSID</u> | <u>Source Name</u> | <u>Analyte Name</u> | <u>Collection Date</u> | <u>PPT</u> |
|--------------------------------------|------------------|--|---------------------|------------------------|------------|
| GUIN WATER & SEWER BOARD | AL0000924 | <i>GUIN WATER TREATMENT PLANT</i> | | | |
| | | | PFOS | 1/29/2020 | 57.0 |
| | | | PFOA | 1/29/2020 | 4.9 |
| | | | PFHxS | 1/29/2020 | 22.0 |
| | | | PFOS | 2/26/2020 | 48.0 |
| | | | PFHxS | 2/26/2020 | 14.0 |
| | | | PFOS | 6/8/2020 | 45.0 |
| | | | PFOS | 6/8/2020 | 45.0 |
| | | | PFHxS | 6/8/2020 | 14.0 |
| | | | PFHxS | 6/8/2020 | 14.0 |
| | | | PFOS | 9/18/2020 | 56.0 |
| | | | PFHxS | 9/18/2020 | 15.0 |
| | | | PFOS | 10/30/2020 | 58.0 |
| | | | PFHxS | 10/30/2020 | 24.0 |
| | | | PFOS | 12/3/2020 | 36.0 |
| | | | PFHxS | 12/3/2020 | 18.0 |
| HARVEST-MONROVIA WATER SYSTEM | AL0000878 | <i>WELL 1 + TREATMENT PLANT</i> | | | |
| | | | PFBS | 2/28/2020 | 4.3 |
| | | | PFOS | 2/28/2020 | 4.4 |
| HUNTSVILLE UTILITIES | AL0000882 | <i>WILLIAMS WELL + TREATMENT PLANT</i> | | | |
| | | | PFBS | 2/28/2020 | 5.1 |
| | | | PFHxA | 9/3/2020 | 5.2 |

| <u>System Name</u> | <u>PWSID</u> | <u>Source Name</u> | <u>Analyte Name</u> | <u>Collection Date</u> | <u>PPT</u> | |
|--|------------------|---|---------------------------------|------------------------|------------|------|
| IRONDALE WATER SYSTEM | AL0000751 | <i>TREATMENT PLANT FOR WELLS 5, 6 & 7</i> | PFOS | 8/17/2020 | 2.3 | |
| | | | <i>WELL 2 + TREATMENT PLANT</i> | PFOS | 9/29/2020 | 19.0 |
| | | | | PFOA | 9/29/2020 | 2.7 |
| | | | | PFHxS | 9/29/2020 | 2.3 |
| | | | | | | |
| JACKSON WATER WORKS & SEWER BOARD | AL0000256 | <i>JACKSON WATER TREATMENT PLANT</i> | PFOS | 2/14/2020 | 7.2 | |
| | | | PFOS | 5/11/2020 | 8.8 | |
| | | | PFOS | 5/11/2020 | 8.8 | |
| | | | PFOS | 8/10/2020 | 5.7 | |
| | | | PFOS | 11/12/2020 | 14.0 | |
| | | | PFOA | 11/12/2020 | 7.5 | |
| JCG FOODS OF ALABAMA LLC | AL0000502 | <i>WELL 1 MAIN WELL + TREATMENT PLANT</i> | PFOS | 2/4/2020 | 3.6 | |
| | | | PFHxA | 2/4/2020 | 3.5 | |
| | | | PFOS | 10/6/2020 | 2.5 | |
| | | | PFHxA | 10/6/2020 | 22.0 | |
| LEIGHTON (WSB OF THE TOWN OF) | AL0000319 | <i>ELEMENTARY SCHOOL WELL TREATMENT PLAN</i> | PFBS | 4/27/2020 | 4.8 | |

| <u>System Name</u> | <u>PWSID</u> | <u>Source Name</u> | <u>Analyte Name</u> | <u>Collection Date</u> | <u>PPT</u> |
|-----------------------------------|------------------|---------------------------------------|---------------------|------------------------|------------|
| LINCOLN (CITY OF) | AL0001245 | <i>WELL #1 TREATMENT PLANT</i> | | | |
| | | | PFOS | 2/13/2020 | 4.1 |
| LOACHAPOKA WATER AUTHORITY | AL0000814 | <i>SAND SPRINGS + TREATMENT PLANT</i> | | | |
| | | | PFBS | 5/20/2020 | 3.3 |
| | | | PFBS | 5/20/2020 | 3.3 |
| | | | PFOS | 5/20/2020 | 1.7 |
| | | | PFOS | 5/20/2020 | 1.7 |
| | | | PFOA | 5/20/2020 | 10.0 |
| | | | PFOA | 5/20/2020 | 10.0 |
| | | | PFHpA | 5/20/2020 | 4.8 |
| | | | PFHpA | 5/20/2020 | 4.8 |
| | | | PFHxS | 5/20/2020 | 2.9 |
| | | | PFHxS | 5/20/2020 | 2.9 |
| | | | PFHxA | 5/20/2020 | 4.5 |
| | | | PFBS | 7/15/2020 | 2.7 |
| | | | PFOS | 7/15/2020 | 1.9 |
| | | | PFOA | 7/15/2020 | 9.3 |
| | | | PFHpA | 7/15/2020 | 3.7 |
| | | | PFHxS | 7/15/2020 | 2.4 |
| | | | PFHxA | 7/15/2020 | 4.1 |

| <u>System Name</u> | <u>PWSID</u> | <u>Source Name</u> | <u>Analyte Name</u> | <u>Collection Date</u> | <u>PPT</u> |
|--|------------------|-------------------------------|---------------------|------------------------|------------|
| LOXLEY (TOWN OF) | AL0000048 | <i>WELL 1 TREATMENT PLANT</i> | | | |
| | | | PFBS | 6/17/2020 | 4.0 |
| | | | PFBS | 6/17/2020 | 4.0 |
| | | | PFOS | 6/17/2020 | 32.0 |
| | | | PFOS | 6/17/2020 | 32.0 |
| | | | PFOA | 6/17/2020 | 3.8 |
| | | | PFOA | 6/17/2020 | 3.8 |
| | | | PFHxS | 6/17/2020 | 20.0 |
| | | | PFHxS | 6/17/2020 | 20.0 |
| | | | PFHxA | 6/17/2020 | 3.8 |
| | | | PFOS | 9/23/2020 | 14.0 |
| | | | PFHxS | 9/23/2020 | 9.1 |
| MADISON WATER WORKS & SEWER | AL0000885 | <i>QUARRY PLANT</i> | | | |
| | | | PFBS | 7/22/2020 | 1.9 |
| | | | PFOS | 7/22/2020 | 2.0 |
| | | | PFOA | 7/22/2020 | 1.4 |
| | | | PFHxA | 7/22/2020 | 4.1 |
| | | | HFPO-DA | 9/30/2020 | 3.4 |
| | | | PFOS | 9/30/2020 | 2.4 |
| | | | PFHxA | 9/30/2020 | 2.8 |
| | | | PFBS | 11/4/2020 | 2.8 |
| | | | PFOS | 11/4/2020 | 2.0 |
| | | | PFHxA | 11/4/2020 | 1.9 |

| <u>System Name</u> | <u>PWSID</u> | <u>Source Name</u> | <u>Analyte Name</u> | <u>Collection Date</u> | <u>PPT</u> |
|---|------------------|--|---------------------|------------------------|------------|
| MONTEVALLO WATER WORKS & SEWER | AL0001160 | <i>SPRING + TREATMENT PLANT</i> | | | |
| | | | PFOS | 1/29/2020 | 7.9 |
| | | | PFHxS | 1/29/2020 | 4.9 |
| | | | PFOS | 9/15/2020 | 5.4 |
| | | <i>WELL 2 + TREATMENT PLANT</i> | | | |
| | | | PFOS | 1/29/2020 | 12.0 |
| | | | PFHxS | 1/29/2020 | 7.5 |
| | | | PFOS | 9/15/2020 | 13.0 |
| | | | PFHxS | 9/15/2020 | 5.9 |
| MOULTON WATER WORKS BOARD | AL0000798 | <i>MOULTON WATER TREATMENT PLANT</i> | | | |
| | | | PFBS | 2/24/2020 | 4.2 |
| | | | PFBS | 5/29/2020 | 4.0 |
| | | | PFBS | 5/29/2020 | 4.0 |
| | | | PFOS | 11/17/2020 | 5.5 |
| MOUNDVILLE WATER WORKS | AL0000651 | <i>TREATMENT FACILITY</i> | | | |
| | | | ADONA | 7/9/2020 | 4.2 |
| MT. VERNON (TOWN OF) | AL0001006 | <i>MUNICIPAL STREET WELL TREATMENT PLANT</i> | | | |
| | | | PFBS | 4/30/2020 | 4.3 |
| | | | PFOS | 4/30/2020 | 3.8 |

| <u>System Name</u> | <u>PWSID</u> | <u>Source Name</u> | <u>Analyte Name</u> | <u>Collection Date</u> | <u>PPT</u> |
|--------------------------------------|------------------|--------------------------------------|---------------------|------------------------|------------|
| MUNFORD WATER AUTHORITY, INC. | AL0001247 | <i>WELL 1 TREATMENT PLANT</i> | | | |
| | | | NEtFOSAA | 7/14/2020 | 2.1 |
| | | | NMeFOSAA | 7/14/2020 | 1.8 |
| | | | PFOS | 7/14/2020 | 3.9 |
| | | | PFDoA | 7/14/2020 | 2.6 |
| | | | PFTrDA | 7/14/2020 | 2.3 |
| | | | PFOUnA | 7/14/2020 | 1.8 |
| NORTH BALDWIN UTILITIES | AL0000023 | <i>WELL 12 TREATMENT PLANT</i> | | | |
| | | | PFOS | 7/13/2020 | 8.7 |
| | | | PFHxS | 7/13/2020 | 5.9 |
| OPP UTILITIES BOARD | AL0000375 | <i>MONROE WELL + TREATMENT PLANT</i> | | | |
| | | | PFHxS | 5/20/2020 | 2.9 |

System Name

PWSID

Source Name

Analyte Name

Collection Date

PPT

PINE HILL WATER DEPARTMENT

AL0001393

PINE HILL TREATMENT PLANT

| | | |
|-------|------------|------|
| PFBS | 1/21/2020 | 19.0 |
| PFOS | 1/21/2020 | 7.6 |
| PFOA | 1/21/2020 | 6.4 |
| PFHxA | 1/21/2020 | 6.2 |
| PFBS | 4/20/2020 | 45.0 |
| PFOS | 4/20/2020 | 18.0 |
| PFOA | 4/20/2020 | 11.0 |
| PFHpA | 4/20/2020 | 3.9 |
| PFHxA | 4/20/2020 | 12.0 |
| PFBS | 6/18/2020 | 22.0 |
| PFOS | 6/18/2020 | 11.0 |
| PFOA | 6/18/2020 | 6.5 |
| PFBS | 10/19/2020 | 21.0 |
| PFOS | 10/19/2020 | 11.0 |
| PFOA | 10/19/2020 | 7.2 |
| PFHxA | 10/19/2020 | 11.0 |

| <u>System Name</u> | <u>PWSID</u> | <u>Source Name</u> | <u>Analyte Name</u> | <u>Collection Date</u> | <u>PPT</u> |
|--|------------------|------------------------------------|---------------------|------------------------|------------|
| ROGERSVILLE WATER WORKS & SEWER BOA | AL0000789 | | | | |
| | | <i>WELL 1 MAIN TREATMENT PLANT</i> | | | |
| | | | PFBS | 3/11/2020 | 4.0 |
| | | | PFBS | 3/11/2020 | 4.0 |
| | | | PFBS | 7/13/2020 | 5.7 |
| | | | PFOS | 7/13/2020 | 1.8 |
| | | | PFOA | 7/13/2020 | 2.0 |
| | | | PFHxS | 7/13/2020 | 3.2 |
| | | | PFHxA | 7/13/2020 | 2.9 |
| | | <i>WELL 2 OLD TREATMENT PLANT</i> | | | |
| | | | PFBS | 3/11/2020 | 22.0 |
| | | | PFBS | 3/11/2020 | 22.0 |
| | | | PFOS | 3/11/2020 | 12.0 |
| | | | PFOS | 3/11/2020 | 12.0 |
| | | | PFOA | 3/11/2020 | 10.0 |
| | | | PFOA | 3/11/2020 | 10.0 |
| | | | PFHpA | 3/11/2020 | 7.0 |
| | | | PFHpA | 3/11/2020 | 7.0 |
| | | | PFHxS | 3/11/2020 | 7.0 |
| | | | PFHxS | 3/11/2020 | 7.0 |
| | | | PFHxA | 3/11/2020 | 17.0 |

System Name

PWSID

Source Name

Analyte Name

Collection Date

PPT

WELL 3 (IND PARK) TREATMENT PLANT

PFBS 3/11/2020 5.0

PFBS 3/11/2020 5.0

PFBS 7/13/2020 4.6

PFOS 7/13/2020 3.5

PFHxS 7/13/2020 3.0

PFHxA 7/13/2020 2.0

| <u>System Name</u> | <u>PWSID</u> | <u>Source Name</u> | <u>Analyte Name</u> | <u>Collection Date</u> | <u>PPT</u> |
|--|------------------|---------------------------------|---------------------|------------------------|------------|
| SATSUMA WATER WORKS | AL0001022 | <i>TREATMENT PLANT 2</i> | | | |
| | | | 9CI-PF3ONS | 5/26/2020 | 4.3 |
| | | | HFPO-DA | 5/26/2020 | 4.4 |
| | | | NEtFOSAA | 5/26/2020 | 22.0 |
| | | | NMeFOSAA | 5/26/2020 | 9.9 |
| | | | PFBS | 5/26/2020 | 4.5 |
| | | | PFBS | 5/26/2020 | 4.5 |
| | | | PFOS | 5/26/2020 | 23.0 |
| | | | PFOS | 5/26/2020 | 23.0 |
| | | | PFOA | 5/26/2020 | 15.0 |
| | | | PFOA | 5/26/2020 | 15.0 |
| | | | PFDA | 5/26/2020 | 18.0 |
| | | | PFHpA | 5/26/2020 | 13.0 |
| | | | PFHpA | 5/26/2020 | 13.0 |
| | | | PFHxS | 5/26/2020 | 8.1 |
| | | | PFHxS | 5/26/2020 | 8.1 |
| | | | PFHxA | 5/26/2020 | 29.0 |
| | | | PFTTrDA | 5/26/2020 | 5.6 |
| STAR-MINDINGALL WATER AUTHORITY | AL0000865 | <i>WELL 2 + TREATMENT PLANT</i> | | | |
| | | | PFOA | 4/15/2020 | 4.1 |
| STEVENSON (UTIL. BOARD OF THE TOWN OF | AL0000732 | <i>1 MGD TREATMENT PLANT</i> | | | |
| | | | PFOS | 3/12/2020 | 4.7 |

| <u>System Name</u> | <u>PWSID</u> | <u>Source Name</u> | <u>Analyte Name</u> | <u>Collection Date</u> | <u>PPT</u> |
|--|------------------|---|---------------------|------------------------|------------|
| SWAN CREEK COMMUNITY (BSI, LLC) | AL0000831 | <i>WELL 2 WEST + TREATMENT PLANT</i> | | | |
| | | | PFBS | 5/6/2020 | 5.3 |
| | | | PFOS | 5/6/2020 | 12.0 |
| | | | PFOA | 5/6/2020 | 4.4 |
| | | | PFOS | 8/24/2020 | 8.9 |
| SYCAMORE WATER AND SEWER AUTHORITY | AL0001378 | <i>WELL #1 TREATMENT PLANT</i> | | | |
| | | | PFOS | 7/14/2020 | 3.8 |
| TALLADEGA WATER AND SEWER BOARD, CIT | AL0001260 | <i>HARMON PARK WELL TREATMENT PLANT</i> | | | |
| | | | PFOS | 8/11/2020 | 2.1 |
| TATE & LYLE SUCRALOSE, INC. WATER SYSTE | AL0001781 | <i>WELL 1 + TREATMENT PLANT</i> | | | |
| | | | PFHxA | 1/15/2020 | 2.8 |
| | | | PFHxA | 7/7/2020 | 6.1 |

| <u>System Name</u> | <u>PWSID</u> | <u>Source Name</u> | <u>Analyte Name</u> | <u>Collection Date</u> | <u>PPT</u> |
|---|------------------|------------------------------------|---------------------|------------------------|------------|
| THOMASVILLE WATER WORKS & SEWER BO | AL0000262 | <i>THOMASVILLE TREATMENT PLANT</i> | | | |
| | | | PFBS | 1/20/2020 | 31.0 |
| | | | PFOS | 1/20/2020 | 8.3 |
| | | | PFOA | 1/20/2020 | 7.0 |
| | | | PFHxA | 1/20/2020 | 9.0 |
| | | | PFBS | 4/20/2020 | 37.0 |
| | | | PFOS | 4/20/2020 | 14.0 |
| | | | PFOA | 4/20/2020 | 9.6 |
| | | | PFHxA | 4/20/2020 | 11.0 |
| | | | PFBS | 5/21/2020 | 19.0 |
| | | | PFOS | 5/21/2020 | 10.0 |
| | | | PFOA | 5/21/2020 | 5.2 |
| TRUSSVILLE UTILITIES | AL0000761 | <i>J.K. DAVIS FILTER</i> | | | |
| | | <i>WELL #15</i> | | | |
| | | | PFBS | 9/28/2020 | 2.8 |
| | | | PFBS | 9/28/2020 | 2.4 |
| | | | PFOS | 9/28/2020 | 3.5 |
| | | | PFHxS | 9/28/2020 | 4.1 |
| TWIN WATER AUTHORITY | AL0000929 | <i>SPRING TREATMENT PLANT</i> | | | |
| | | | PFHxS | 9/8/2020 | 4.0 |

| <u>System Name</u> | <u>PWSID</u> | <u>Source Name</u> | <u>Analyte Name</u> | <u>Collection Date</u> | <u>PPT</u> |
|--|------------------|---|---------------------|---|------------|
| U.S. AMINES LLC- CELANESE CHEMICALS | AL0001037 | <i>WELL 2(BY ENTRANCE GATE HWY 43) + TREATM</i> | PFOS | 4/15/2020 | 8.5 |
| | | | | | |
| | | <i>WELL PW-1 --BACKUP FOR PW-2 + TREATMENT</i> | PFOS | 4/15/2020 | 7.7 |
| | | | PFOS | 7/30/2020 | 24.9 |
| | | | PFHxS | 7/30/2020 | 7.5 |
| | | | | | |
| | | <i>WELL PW4-- SERVES ADMIN BLDG + TREATMEN</i> | PFOS | 4/15/2020 | 26.0 |
| | | | PFHxS | 4/15/2020 | 9.5 |
| | | | PFOS | 7/30/2020 | 14.6 |
| | | UPPER BEAR CREEK WATER AUTHORITY | AL0000927 | <i>UPPER BEAR CREEK TREATMENT PLANT</i> | PFOS |
| | | | | | |
| WEAVER WATER SYSTEM | AL0000168 | <i>WELL 2 + TREATMENT PLANT</i> | PFBS | 4/7/2020 | 3.8 |
| | | | PFOS | 4/7/2020 | 15.0 |
| | | | PFOA | 4/7/2020 | 4.4 |
| | | | PFHxS | 4/7/2020 | 7.8 |
| | | | PFOS | 8/20/2020 | 5.2 |
| | | <i>WELL 3 + TREATMENT PLANT</i> | PFOS | 4/7/2020 | 14.0 |
| | | | PFHxS | 4/7/2020 | 14.0 |
| | | | PFOS | 8/20/2020 | 5.6 |
| | PFHxS | 8/20/2020 | 5.8 | | |

| <u>System Name</u> | <u>PWSID</u> | <u>Source Name</u> | <u>Analyte Name</u> | <u>Collection Date</u> | <u>PPT</u> |
|--|------------------|-------------------------------------|---------------------|------------------------|------------|
| WEDOWEE WATER, SEWER, & GAS BOARD | AL0001131 | <i>SWANN TREATMENT PLANT</i> | | | |
| | | | PFOS | 4/15/2020 | 1.9 |
| | | | PFOS | 9/23/2020 | 6.6 |
| | | | PFOA | 9/23/2020 | 3.0 |
| | | | PFBS | 10/21/2020 | 2.7 |
| | | | PFOS | 10/21/2020 | 3.4 |
| | | | PFOA | 10/21/2020 | 2.2 |
| WEST ESCAMBIA UTILITIES INC. | AL0000553 | <i>FILLMORE DR. TREATMENT PLANT</i> | | | |
| | | | PFOS | 5/13/2020 | 6.6 |
| | | | PFOS | 5/13/2020 | 6.6 |
| | | | PFHxS | 5/13/2020 | 7.7 |
| | | | PFHxS | 5/13/2020 | 7.7 |
| | | | PFBS | 7/10/2020 | 2.8 |
| | | | PFBS | 7/10/2020 | 2.8 |
| | | | PFOS | 7/10/2020 | 16.0 |
| | | | PFOS | 7/10/2020 | 16.0 |
| | | | PFHxS | 7/10/2020 | 23.0 |
| | | | PFHxS | 7/10/2020 | 23.0 |
| | | | PFHxA | 7/10/2020 | 2.5 |
| | | | PFHxA | 7/10/2020 | 2.5 |

System Name

PWSID

Source Name

Analyte Name

Collection Date

PPT

WILSONVILLE WATER WORKS

AL0001171

WELL 3 + TREATMENT PLANT

PFOS

8/20/2020

6.8

PFHxS

8/20/2020

4.8

| <u>System Name</u> | <u>PWSID</u> | <u>Source Name</u> | <u>Analyte Name</u> | <u>Collection Date</u> | <u>PPT</u> |
|---|------------------|--|---------------------|------------------------|------------|
| WISE METALS GROUP, LLC (CONSTELLIUM) | AL0000366 | <i>TENNESSEE RIVER + TREATMENT PLANT</i> | | | |
| | | | PFBS | 1/14/2020 | 5.2 |
| | | | PFOS | 1/14/2020 | 19.0 |
| | | | PFOA | 1/14/2020 | 9.5 |
| | | | PFHpA | 1/14/2020 | 2.5 |
| | | | PFHxS | 1/14/2020 | 2.2 |
| | | | PFHxA | 1/14/2020 | 3.4 |
| | | | PFBS | 2/18/2020 | 5.1 |
| | | | PFOS | 2/18/2020 | 2.1 |
| | | | PFOA | 2/18/2020 | 1.0 |
| | | | PFHpA | 2/18/2020 | 3.0 |
| | | | PFHxS | 2/18/2020 | 2.5 |
| | | | PFHxA | 2/18/2020 | 4.0 |
| | | | HFPO-DA | 4/14/2020 | 22.0 |
| | | | PFBS | 4/14/2020 | 37.0 |
| | | | PFOS | 4/14/2020 | 13.0 |
| | | | PFOA | 4/14/2020 | 7.4 |
| | | | PFHpA | 4/14/2020 | 21.0 |
| | | | PFHxA | 4/14/2020 | 30.0 |
| | | | HFPO-DA | 7/14/2020 | 2.4 |
| | | | PFBS | 7/14/2020 | 4.2 |
| | | | PFOS | 7/14/2020 | 16.0 |
| | | | PFOA | 7/14/2020 | 7.9 |
| | | | PFHpA | 7/14/2020 | 2.1 |

| <u>System Name</u> | <u>PWSID</u> | <u>Source Name</u> | <u>Analyte Name</u> | <u>Collection Date</u> | <u>PPT</u> |
|--------------------|--------------|--------------------|---------------------|------------------------|------------|
| | | | PFHxS | 7/14/2020 | 2.2 |
| | | | PFHxA | 7/14/2020 | 4.3 |