



MAJOR SOURCE OPERATING PERMIT

PERMITTEE:	SOUTHERN NATURAL GAS COMPANY, LLC
FACILITY NAME:	DEARMANVILLE COMPRESSOR STATION
FACILITY/PERMIT NO.:	301-0033
LOCATION:	ANNISTON, CALHOUN COUNTY, ALABAMA

In accordance with and subject to the provisions of the Alabama Air Pollution Control Act of 1971, <u>Ala. Code</u> §§ 22-28-1 to 22-28-23, as amended, the Alabama Environmental Management Act, <u>Ala. Code</u> §§ 22-22A-1 to 22-22A-17, as amended, and rules and regulations adopted there under, and subject further to the conditions set forth in this permit, the Permittee is hereby authorized to construct, install and use the equipment, device or other article described above

Pursuant to the **Clean Air Act of 1990**, all conditions of this permit are federally enforceable by EPA, the Alabama Department of Environmental Management, and citizens in general. Those provisions which are not required under the **Clean Air Act of 1990** are considered to be state permit provisions and are not federally enforceable by EPA and citizens in general. Those provisions are contained in separate sections of this permit.

Issuance Date: Draft

Effective Date: Draft

Expiration Date: March 9, 2030

Alabama Department of Environmental Management

TABLE OF CONTENTS

GENI	ERAL PERMIT PROVISOS	1
1.	Transfer	. 1
2.	Renewals	. 1
3.	Severability Clause	. 1
4.	Compliance	
5.	Termination for Cause	
6.		
7.		
8.	Economic Incentives, Marketable Permits, and Emissions Trading	. 2
9.	Certification of Truth, Accuracy, and Completeness	. 2
10	0. Inspection and Entry	. 2
	1. Compliance Provisions	
12	2. Compliance Certification	. 3
1.	3. Reopening for Cause	. 4
14	4. Additional Rules and Regulations	. 4
1.	5. Equipment Maintenance or Breakdown	. 4
1	5. Operation of Capture and Control Devices	. 5
1	7. Obnoxious Odors	. 5
18	3. Fugitive Dust	. 5
1	9. Additions and Revisions	. 6
20	0. Recordkeeping Requirements	. 6
2.	1. Reporting Requirements	. 7
	2. Emission Testing Requirements	
2	3. Payment of Emission Fees	. 8
24	4. Other Reporting and Testing Requirements	. 8
2	5. Title VI Requirements (Refrigerants)	. 8
	5. Chemical Accidental Prevention Provisions	
	7. Display of Permit	
	3. Circumvention	
	9. Visible Emissions	
	0. Fuel-Burning Equipment	
	1. Process Industries – General	
	2. Averaging Time for Emission Limits	
	3. Open Burning	
34	4. Permit Shield	10
EMIS	SION UNIT NOS. C001 AND C002 (COMPRESSOR ENGINE NOS. 5 AND 6)	11
St	ımmary Page	11
	nit Specific Provisos	
	1. Applicability	
	2. Emission Standards	12
	3. Compliance and Performance Test Methods and Procedures	
	4. Emission Monitoring	
	5. Recordkeeping and Reporting Requirements	12

EMISSION	N UNIT NOS. C003, C004, AND C005 (COMPRESSOR ENGINE NOS. 7, 8, AN	ND 9)13
Summe	ary Page	13
Unit Sp	pecific Provisos	14
1.	Applicability	14
2.	Emission Standards	
3.	Compliance and Performance Test Methods and Procedures	
4.	Emission Monitoring	
5.	Recordkeeping and Reporting Requirements	14
EMISSION	N UNIT NO. C006 (COMPRESSOR TURBINE NO. 10)	15
Summe	ary Page	15
Unit Sp	pecific Provisos	
1.	Applicability	
2.	Emission Standards	
3.	Compliance and Performance Test Methods and Procedures	17
4.	Emission Monitoring	
5.	Recordkeeping and Reporting Requirements	17
EMISSION	N UNIT NOS. C007 AND C008 (COMPRESSOR ENGINE NOS. 11 AND 12)	19
	ary Page	
	pecific Provisos	
-		
1.	Applicability Emission Standards	
2. 3.	Compliance and Performance Test Methods and Procedures	
3. 4.	Emission Monitoring	
+. 5.	Record keeping and Reporting Requirements	
	N UNIT NOS. G001 (EMERGENCY GENERATOR ENGINE NO. 1)	
Summe	ary Page	
Unit Sp	pecific Provisos	23
1.	Applicability	
2.	Emission Standards	23
3.	Compliance and Performance Test Methods and Procedures	
4.	Emission Monitoring	
5.	Recordkeeping and Reporting Requirements	25
EMISSION	N UNIT NOS. FGH1 (NO. 1 FUEL GAS HEATER)	27
Summe	ary Page	27
Unit Sp	pecific Provisos	
1.	Applicability	
2.	Emission Standards	
3.	Compliance and Performance Test Methods and Procedures	
4.	Emission Monitoring	
5.	Recordkeeping and Reporting Requirements	

General Permit Provisos			
	Federally Enforceable Provisos	Regulations	
1.	Transfer		
	This permit is not transferable, whether by operation of law or otherwise, either from one location to another, from one piece of equipment to another, or from one person to another, except as provided in ADEM Admin. Code r. 335-3-1613(1)(a)5.	ADEM Admin. Code r. 335-3-1602(6)	
2.	Renewals		
	An application for permit renewal shall be submitted at least six (6) months, but not more than eighteen (18) months, before the date of expiration of this permit.	ADEM Admin. Code r. 335-3-1612(2)	
	The source for which this permit is issued shall lose its right to operate upon the expiration of this permit unless a timely and complete renewal application has been submitted within the time constraints listed in the previous paragraph.		
3.	Severability Clause		
	The provisions of this permit are declared to be severable and if any section, paragraph, subparagraph, subdivision, clause, or phrase of this permit shall be adjudged to be invalid or unconstitutional by any court of competent jurisdiction, the judgment shall not affect, impair, or invalidate the remainder of this permit, but shall be confined in its operation to the section, paragraph, subparagraph, subdivisions, clause, or phrase of this permit that shall be directly involved in the controversy in which such judgment shall have been rendered.	ADEM Admin. Code r. 335-3-1605(e)	
4.	<u>Compliance</u>		
	 (a) The permittee shall comply with all conditions of ADEM Admin. Code 335-3. Noncompliance with this permit will constitute a violation of the Clean Air Act of 1990 and ADEM Admin. Code 335-3 and may result in an enforcement action; including but not limited to, permit termination, revocation and reissuance, or modification; or denial of a permit renewal application by the permittee. 	ADEM Admin. Code r. 335-3-1605(f)	
	(b) The permittee shall not use as a defense in an enforcement action that maintaining compliance with conditions of this permit would have required halting or reducing the permitted activity.	ADEM Admin. Code r. 335-3-1605(g)	
5.	Termination for Cause		
	This permit may be modified, revoked, reopened, and reissued, or terminated for cause. The filing of a request by the permittee for a permit modification, revocation and reissuance, or termination, or of a notification of planned changes or anticipated noncompliance will not stay any permit condition.	ADEM Admin. Code r. 335-3-1605(h)	

	Federally Enforceable Provisos	Regulations
6.	Property Rights	
	The issuance of this permit does not convey any property rights of any sort, or any exclusive privilege.	ADEM Admin. Code r. 335-3-1605(i)
7.	Submission of Information	
	The permittee must submit to the Air Division, within 30 days or for such other reasonable time as the Air Division may set, any information that the Air Division may request in writing to determine whether cause exists for modifying, revoking and reissuing, or terminating this permit or to determine compliance with this permit. Upon receiving a specific request, the permittee shall also furnish to the Air Division copies of records required to be kept by this permit.	ADEM Admin. Code r. 335-3-1605(j)
8.	Economic Incentives, Marketable Permits, and Emissions Trading	
	No permit revision shall be required, under any approved economic incentives, marketable permits, emissions trading and other similar programs or processes for changes that are provided for in this permit.	ADEM Admin. Code r. 335-3-1605(k)
9.	Certification of Truth, Accuracy, and Completeness	
	Any application form, report, test data, monitoring data, or compliance certification submitted pursuant to this permit shall contain certification by a responsible official of truth, accuracy, and completeness. This certification shall state that, based on information and belief formed after reasonable inquiry, the statements and information in the document are true, accurate and complete.	ADEM Admin. Code r. 335-3-1607(a)
10	. Inspection and Entry	
	Upon presentation of credentials and other documents as may be required by law, the permittee shall allow authorized representatives of the Alabama Department of Environmental Management and EPA to conduct the following:	ADEM Admin. Code r. 335-3-1607(b)
	 (a) Enter upon the permittee's premises where a source is located or emissions-related activity is conducted, or where records must be kept pursuant to the conditions of this permit; 	
	(b) Review and/or copy, at reasonable times, any records that must be kept pursuant to the conditions of this permit;	
	(c) Inspect, at reasonable times, this facility's equipment (including monitoring equipment and air pollution control equipment), practices, or operations regulated or required pursuant to this permit;	

	Federally Enforceable Provisos	Regulations
F	Sample or monitor, at reasonable times, substances or parameters for the purpose of assuring compliance with this permit or other applicable requirements.	
11. <u>Com</u>	pliance Provisions	
r	The permittee shall continue to comply with the applicable requirements with which the company has certified that it is already in compliance.	ADEM Admin. Code r. 335-3-1607(c)
r	The permittee shall comply in a timely manner with applicable requirements that become effective during the term of this permit.	
12. <u>Com</u>	upliance Certification	
certi	permittee shall submit a complete and accurate compliance fication by May 9 th of each year for each annual reporting od of this permit (March 10 th through March 9 th).	ADEM Admin. Code r. 335-3-1607(e)
(a) 1	The compliance certification shall include the following:	
(1) The identification of each term or condition of this permit that is the basis of the certification;	
(2	2) The compliance status;	
(3) The method(s) used for determining the compliance status of the source, currently and over the reporting period consistent with ADEM Admin. Code r. 335-3-1605(c) (Monitoring and Recordkeeping Requirements);	
(•	4) Whether compliance has been continuous or intermittent;	
(5) Such other facts as the Air Division may require to determine the compliance status of the source;	
(b) 1	The compliance certification shall be submitted to:	
	Alabama Department of Environmental Management Air Division P.O. Box 301463 Montgomery, AL 36130-1463	
	and to:	
	EPA Region 4 via email at EPA_R4_CAA_Reports@epa.gov or through the EPA's Compliance and Emissions Data Reporting Interface (CEDRI)	

General Fermit Frovisos			
Regulations			
ADEM Admin. Code r. 335-3-1613(5)			
§ §22-28-16(d), <u>Code of</u> Alabama 1975, as amended			
ADEM Admin. Code r. 335-3-107(1),(2)			
E			

General P	ermit	Provisos
-----------	-------	----------

Federally Enforceable Provisos	Regulations
(3) The nature and quality of emissions of air contaminants likely to occur during the shutdown period;	
(4) Measures such as the use of off-shift labor and equipment that will be taken to minimize the length of the shutdown period;	
(5) The reasons that it would be impossible or impractical to shut down the sources operation during the maintenance period.	
(b) In the event that there is a breakdown of equipment or upset of process in such a manner as to cause, or is expected to cause, increased emissions of air contaminants which are above an applicable standard, the person responsible for such equipment shall notify the Director within 24 hours or the next working day and provide a statement giving all pertinent facts, including the estimated duration of the breakdown. The Director will be notified when the breakdown has been corrected.	
16. Operation of Capture and Control Devices	
All air pollution control devices and capture systems for which this permit is issued shall be maintained and operated at all times in a manner so as to minimize the emissions of air contaminants. Procedures for ensuring that the above equipment is properly operated and maintained so as to minimize the emission of air contaminants shall be established.	§22-28-16(d), <u>Code of</u> <u>Alabama 1975</u> , as amended
17. <u>Obnoxious Odors</u>	
This permit is issued with the condition that, should obnoxious odors arising from the plant operations be verified by Air Division inspectors, measures to abate the odorous emissions shall be taken upon a determination by the Alabama Department of Environmental Management that these measures are technically and economically feasible.	ADEM Admin. Code r. 335-3-108
18. <u>Fugitive Dust</u>	
(a) Precautions shall be taken to prevent fugitive dust emanating from plant roads, grounds, stockpiles, screens, dryers, hoppers, ductwork, etc.	ADEM Admin. Code r. 335-3-402
(b) Plant or haul roads and grounds will be maintained in the following manner so that dust will not become airborne. A minimum of one, or a combination, of the following methods shall be utilized to minimize airborne dust from plant or haul roads and grounds:	

General P	ermit	Provisos
-----------	-------	----------

	Federally Enforceable Provisos	Regulations
	 By the application of water any time the surface of the road is sufficiently dry to allow the creation of dust emissions by the act of wind or vehicular traffic; 	
	(2) By reducing the speed of vehicular traffic to a point below that at which dust emissions are created;	
	(3) By paving;	
	(4) By the application of binders to the road surface at any time the road surface is found to allow the creation of dust emissions.	
	Should one, or a combination, of the above methods fail to adequately reduce airborne dust from plant or haul roads and grounds, alternative methods shall be employed, either exclusively or in combination with one or all of the above control techniques, so that dust will not become airborne. Alternative methods shall be approved by the Air Division prior to utilization.	
Add	litions and Revisions	
proc	modifications to this source shall comply with the modification cedures in ADEM Admin. Code r. 335-3-1613 or -3-1614.	ADEM Admin. Code 335-3-1613 and 335-3-1614
proc 335	cedures in ADEM Admin. Code r. 335-3-1613 or	335-3-1613 and
prod 335 . <u>Rec</u> (a)	cedures in ADEM Admin. Code r. 335-3-1613 or -3-1614.	335-3-1613 and 335-3-1614
prod 335 . <u>Rec</u> (a)	cedures in ADEM Admin. Code r. 335-3-1613 or -3-1614. cordkeeping Requirements Records of required monitoring information of the source shall	335-3-1613 and 335-3-1614 ADEM Admin. Code
proc 335 . <u>Rec</u> (a)	cedures in ADEM Admin. Code r. 335-3-1613 or -3-1614. cordkeeping Requirements Records of required monitoring information of the source shall include the following:	335-3-1613 and 335-3-1614 ADEM Admin. Code
proc 335 . <u>Rec</u> (a)	 cedures in ADEM Admin. Code r. 335-3-1613 or -3-1614. cordkeeping Requirements Records of required monitoring information of the source shall include the following: (1) The date, place, and time of all sampling or measurements; 	335-3-1613 and 335-3-1614 ADEM Admin. Code
proc 335 . <u>Rec</u> (a)	 cedures in ADEM Admin. Code r. 335-3-1613 or -3-1614. cordkeeping Requirements Records of required monitoring information of the source shall include the following: (1) The date, place, and time of all sampling or measurements; (2) The date analyses were performed; 	335-3-1613 and 335-3-1614 ADEM Admin. Code
proc 335 . <u>Rec</u> (a)	 cedures in ADEM Admin. Code r. 335-3-1613 or -3-1614. cordkeeping Requirements Records of required monitoring information of the source shall include the following: The date, place, and time of all sampling or measurements; The date analyses were performed; The company or entity that performed the analyses; 	335-3-1613 and 335-3-1614 ADEM Admin. Code
proc 335 . <u>Rec</u> (a)	 cedures in ADEM Admin. Code r. 335-3-1613 or -3-1614. cordkeeping Requirements Records of required monitoring information of the source shall include the following: The date, place, and time of all sampling or measurements; The date analyses were performed; The company or entity that performed the analyses; The analytical techniques or methods used; 	335-3-1614 ADEM Admin. Code

Federally Enforceable Provisos	Regulations
21. <u>Reporting Requirements</u>	
(a) Reports to the Air Division of any required monitoring shall be submitted at least every 6 months. All instances of deviations from permit requirements must be clearly identified in said reports. All required reports must be certified by a responsible official consistent with ADEM Admin. Code R. 335-3-1604(9).	ADEM Admin. Code r. 335-3-1605(c)3.
(b) Deviations from permit requirements shall be reported within 48 hours or 2 working days of such deviations, including those attributable to upset conditions as defined in the permit. The report will include the probable cause of said deviations, and any corrective actions or preventive measures that were taken.	
22. Emission Testing Requirements	
Each point of emission which requires testing will be provided with sampling ports, ladders, platforms, and other safety equipment to facilitate testing performed in accordance with procedures established by Part 60 of Title 40 of the Code of Federal Regulations, as the same may be amended or revised.	ADEM Admin. Code r. 335-3-105(3) and 335-3-104(1)
The Air Division must be notified in writing at least 10 days in advance of all emission tests to be conducted and submitted as proof of compliance with the Department's air pollution control rules and regulations.	
To avoid problems concerning testing methods and procedures, the following shall be included with the notification letter:	ADEM Admin. Code r. 335-3-104
(a) The date the test crew is expected to arrive, the date and time anticipated of the start of the first run, how many and which sources are to be tested, and the names of the persons and/or testing company that will conduct the tests.	
(b) A complete description of each sampling train to be used, including type of media used in determining gas stream components, type of probe lining, type of filter media, and probe cleaning method and solvent to be used (if test procedures require probe cleaning).	
(c) A description of the process(es) to be tested including the feed rate, any operating parameters used to control or influence the operations, and the rated capacity.	
(d) A sketch or sketches showing sampling point locations and their relative positions to the nearest upstream and downstream gas flow disturbances.	
A pretest meeting may be held at the request of the source owner or the Air Division. The necessity for such a meeting and the required attendees will be determined on a case-by-case basis.	ADEM Admin. Code r. 335-3-104

Fodorolly Enforceship Provides	Pogulations
Federally Enforceable Provisos	Regulations
All test reports must be submitted to the Air Division within 30 days of the actual completion of the test unless an extension of time is specifically approved by the Air Division.	
23. <u>Payment of Emission Fees</u>	
(a) The permittee shall submit the annual Operating Permit Fees required by ADEM Admin. Code r. 335-1-704 according to the schedule in ADEM Admin. Code r. 335-1-705	ADEM Admin. Code r. 335-1-705
(b) The permittee shall submit its estimates of actual emissions for the previous calendar year according to the schedule in ADEM Admin. Code r. 335-1-705.	ADEM Admin. Code r. 335-1-705
24. Other Reporting and Testing Requirements	
Submission of other reports regarding monitoring records, fuel analyses, operating rates, and equipment malfunctions may be required as authorized in the Department's air pollution control rules and regulations. The Department may require emission testing at any time.	ADEM Admin. Code r. 335-3-104(1)
25. <u>Title VI Requirements (Refrigerants)</u>	
Any facility having appliances or refrigeration equipment, including air conditioning equipment, which use Class I or Class II ozone-depleting substances as listed in 40 CFR Part 82, Subpart A, Appendices A and B, shall service, repair, and maintain such equipment according to the work practices, personnel certification requirements, and certified recycling and recovery equipment specified in 40 CFR Part 82, Subpart F.	ADEM Admin. Code r. 335-3-1605(a)
No person shall knowingly vent or otherwise release any Class I or Class II substance into the environment during the repair, servicing, maintenance, or disposal of any device except as provided in 40 CFR Part 82, Subpart F.	
The responsible official shall comply with all reporting and recordkeeping requirements of 40 CFR §82.166. Reports shall be submitted to the US EPA and the Department as required.	
26. <u>Chemical Accidental Prevention Provisions</u>	
If a chemical listed in Table 1 of 40 CFR Part §68.130 is present in a process in quantities greater than the threshold quantity listed in Table 1, then:	40 CFR Part 68
(a) The owner or operator shall comply with the provisions in 40 CFR Part 68.	
(b) The owner or operator shall submit one of the following:	

General Fernit Flovisos				
Federally Enforceable Provisos	Regulations			
(1) A compliance schedule for meeting the requirements of 40 CFR Part 68 by the date provided in 40 CFR §68.10(a) or,				
(2) A certification statement that the source is in compliance with all requirements of 40 CFR Part 68, including the registration and submission of the Risk Management Plan.				
27. <u>Display of Permit</u>				
This permit shall be kept under file or on display at all times at the site where the facility for which the permit is issued is located and will make the permit readily available for inspection by any or all persons who may request to see it.	ADEM Admin. Code r. 335-3-1602(2)			
28. <u>Circumvention</u>				
No person shall cause or permit the installation or use of any device or any means which, without resulting in the reduction in the total amount of air contaminant emitted, conceals or dilutes any emission of air contaminant which would otherwise violate the Division 3 rules and regulations.	ADEM Admin. Code r. 335-3-110			
29. <u>Visible Emissions</u>				
Unless otherwise specified in the Unit Specific provisos of this permit, any source of particulate emissions shall not discharge more than one 6-minute average opacity greater than 20% in any 60-minute period. At no time shall any source discharge a 6-minute average opacity of particulate emissions greater than 40%. Opacity will be determined by 40 CFR Part 60, Appendix A, Method 9, unless otherwise specified in the Unit Specific provisos of this permit.	ADEM Admin. Code r. 335-3-401(1)			
30. <u>Fuel-Burning Equipment</u>				
Unless otherwise specified in the Unit Specific provisos of this permit, no fuel-burning equipment may discharge particulate emissions in excess of the emissions specified in ADEM Admin. Code r. 335-3-403.	ADEM Admin. Code r. 335-3-403			
Unless otherwise specified in the Unit Specific provisos of this permit, no fuel-burning equipment may discharge sulfur dioxide emissions in excess of the emissions specified in ADEM Admin. Code r. 335-3-501.	ADEM Admin. Code r. 335-3-501			
31. <u>Process Industries – General</u>				
Unless otherwise specified in the Unit Specific provisos of this permit, no process may discharge particulate emissions in excess of the emissions specified in ADEM Admin. Code r. 335-3-404.	ADEM Admin. Code r. 335-3-404			

General Permit Provisos					
Federally Enforceable Provisos	Regulations				
32. Averaging Time for Emission Limits					
Unless otherwise specified in the permit, the averaging time for the emission limits listed in this permit shall be the nominal time required by the specific test method.	ADEM Admin. Code r. 335-3-105				
33. <u>Open Burning</u>					
Precautions should be taken to ensure that no person shall ignite, cause to ignite, permit to be ignited, or maintain any open fire in such a manner as to cause the Department's rules and regulations applicable to open burning to be violated.	ADEM Admin. Code r. 335-3-301				
34. <u>Permit Shield</u>					
A Permit Shield exists under this operating permit in accordance with ADEM Admin. Code r. 335-3-1610 in that compliance with the conditions of this permit shall be deemed compliance with any applicable requirements as of the date of permit issuance, provided that such applicable requirements are included and are specifically identified in this operating permit.	ADEM Admin. Code r. 335-3-1610				

Emission Unit Nos. C001 and C002 (Compressor Engine Nos. 5 and 6) Summary Page

Description: Two 1,000 hp Cooper-Bessemer GMV-10, 2-stroke Lean-burn Natural Gas-fired Reciprocating Internal Combustion Engines

Permitted Operating Schedule:	24 Hours	v	365 Days	_	8760 Hours
	Day	Α -	Year	-	Year

Emission Point Nos.	Description	Pollutant	Emission Limit	Regulation
		NO _x	N/A	N/A
		СО	N/A	N/A
C001	Two 1,000 hp Cooper- Bessemer GMV-10, 2-stroke	VOC N/A	N/A	
C002	Lean-burn Natural Gas-fired Reciprocating Internal Combustion Engines	SO ₂	N/A	N/A
	Combustion Engines	РМ	N/A	N/A
		НАР	N/A	N/A

	Federally Enforceable Provisos	Regulations
1.	Applicability	
	(a) These units are subject to the applicable requirements of ADEM Admin. Code r. 335-3-1603, "Major Source Operating Permits."	ADEM Admin. Code r. 335-3-1603
	(b) These units are affected sources under 40 CFR Part 63, Subpart ZZZZ, National Emission Standards for Hazardous Air Pollutants for Stationary Reciprocating Internal Combustion Engines.	ADEM Admin. Code r. 335-3-1106(103) and 40 CFR Part 63, Subpart ZZZZ
2.	Emission Standards	
	The permittee shall not discharge more than one six-minute average opacity greater than 20% during any 60-minute period from these units. At no time shall the permittee discharge a six- minute average opacity of particulate emissions greater than 40% from these units.	ADEM Admin. Code r. 335-3-401(1)
з.	Compliance and Performance Test Methods and Procedures	
	If testing is required, opacity shall be determined by 40 CFR Part 60, Appendix A, Reference Method 9.	ADEM Admin. Code r. 335-3-105
4.	Emission Monitoring	
	The permittee shall only fire natural gas in these units.	ADEM Admin. Code r. 335-3-1605(c)
5.	Recordkeeping and Reporting Requirements	
	The permittee shall submit a Semiannual Monitoring Report, as required by general Permit Proviso No. 21(a), no later than 60 days after the end of each semiannual reporting period (March 10 th to September 9 th and September 10 th to March 9 th). The report shall include a statement addressing whether only natural gas was fired in these units during the reporting period.	ADEM Admin. Code r. 335-3-1605(c)

Emission Unit Nos. C003, C004, and C005 (Compressor Engine Nos. 7, 8, and 9) Summary Page

Description: Three 1,350 hp Cooper-Bessemer GMV-10-STF, 2-stroke Lean-burn Natural Gas-fired Reciprocating Internal Combustion Engines

Pormitted Operating Schedules	24 Hours	365 Days	_	8760 Hours
Permitted Operating Schedule:	Day	Year	-	Year

Emission Point Nos.	Description	Pollutant	Emission Limit	Regulation
		NO _x	N/A	N/A
		СО	N/A	N/A
C003	Three 1,350 hp Cooper- Bessemer GMV-10-STF, 2- stroke Lean-burn Natural Gas- fired Reciprocating Internal Combustion Engines	VOC	N/A	N/A
C004		SO ₂	N/A	N/A
C005		PM	N/A	N/A
		HAP	N/A	N/A

	Federally Enforceable Provisos	Regulations
1.	Applicability	
	(a) These units are subject to the applicable requirements of ADEM Admin. Code r. 335-3-1603, "Major Source Operating Permits."	ADEM Admin. Code r. 335-3-1603
	(b) These units are affected sources under 40 CFR Part 63, Subpart ZZZZ, National Emission Standards for Hazardous Air Pollutants for Stationary Reciprocating Internal Combustion Engines.	ADEM Admin. Code r. 335-3-1106(103) and 40 CFR Part 63, Subpart ZZZZ
2.	Emission Standards	
	The permittee shall not discharge more than one six-minute average opacity greater than 20% during any 60-minute period from these units. At no time shall the permittee discharge a six- minute average opacity of particulate emissions greater than 40% from these units.	ADEM Admin. Code r. 335-3-401(1)
3.	Compliance and Performance Test Methods and Procedures	
	If testing is required, opacity shall be determined by 40 CFR Part 60, Appendix A, Reference Method 9.	ADEM Admin. Code r. 335-3-105
4.	Emission Monitoring	
	The permittee shall only fire natural gas in these units.	ADEM Admin. Code r. 335-3-1605(c)
5.	Recordkeeping and Reporting Requirements	
	The permittee shall submit a Semiannual Monitoring Report, as required by general Permit Proviso No. 21(a), no later than 60 days after the end of each semiannual reporting period (March 10 th to September 9 th and September 10 th to March 9 th). The report shall include a statement addressing whether only natural gas was fired in these units during the reporting period.	ADEM Admin. Code r. 335-3-1605(c)

Emission Unit No. C006 (Compressor Turbine No. 10) Summary Page

Dormittad Operating Schodula	24 Hours	- x -	365 Days	_	8760 Hours
Permitted Operating Schedule:	Day		Year	_	Year

Emission Point No.	Description	Pollutant	Emission Limit	Regulation
			5.15 lb/hr	ADEM Admin. Code r. 335-3-1404 (SMS)
		NOx	150 ppmvd @15% O2	ADEM Admin. Code r. 335-3-1404 (SMS) ADEM Admin. Code r. 335-3-1002(33) 40 CFR Part 60, Subpart GG (NSPS) N/A N/A ADEM Admin. Code r. 335-3-1002(33) 40 CFR Part 60, Subpart GG (NSPS)
		СО	N/A	N/A
C006	1,262 hp Solar T1300 Natural Gas-fired	VOC	N/A	ADEM Admin. Code r. 335-3-1404 (SMS) ADEM Admin. Code r. 335-3-1002(33) 40 CFR Part 60, Subpart GG (NSPS) N/A N/A ADEM Admin. Code r. 335-3-1002(33) 40 CFR Part 60, Subpart GG (NSPS) 40 CFR Part 60, Subpart GG (NSPS) 40 CFR Part 60, Subpart GG (NSPS) N/A
	Combustion Turbine	SO2	150 ppmvd @15% O2 OR Fuel Sulfur Content Limit of 0.8% by weight (8000 ppmw)	r. 335-3-1002(33) 40 CFR Part 60,
		РМ	N/A	N/A
		HAP	N/A	N/A

Emission Unit No. C006 (Compressor Turbine No. 10)

		Federally Enforceable Provisos	Regulations
1.	<u>Ap</u>	plicability	
	(a)	This unit is subject to the applicable requirements of ADEM Admin. Code r. 335-3-1603, "Major Source Operating Permits."	ADEM Admin. Code 1 335-3-1603
	(b)	This unit is subject to the applicable requirements of 40 CFR Part 60, Subpart GG, the Standards of Performance for Stationary Gas Turbines.	ADEM Admin. Code : 335-3-1002(33) and 40 CFR Part 60, Subpart GG
	(c)	This unit is an affected source under 40 CFR Part 63, Subpart YYYY, the National Emission Standards for Hazardous Air Pollutants for Stationary Combustion Turbines.	ADEM Admin. Code 335-3-1106(102) and 40 CFR Part 63, Subpart YYYY
	(đ)	This unit is subject to a synthetic minor source emission limit to restrict its potential to emit below the applicability threshold established at ADEM Admin. Code r. 335-3-1404, Air Permits Authorizing Construction in Clean Areas [Prevention of Significant Deterioration (PSD)].	ADEM Admin. Code 335-3-1404
2.	Em	ission Standards	
	(a)	The permittee shall not cause or allow the emissions of nitrogen oxides (NO _x) from this unit to exceed 5.15 lb/hr .	ADEM Admin. Code 335-3-1404
	(b)	This unit is subject to the applicable emission standards of 40 CFR §60.332. The permittee shall not cause or allow the emissions of nitrogen oxides (NO _x) from this unit to exceed 150 ppmvd @ 15% O ₂ .	ADEM Admin. Code : 335-3-1002(33)
	(c)	This unit is subject to the applicable emission standards of 40 CFR §60.333. The permittee shall not cause or allow the emissions of sulfur dioxide (SO ₂) from this unit to exceed 150 ppmvd @ 15% O ₂ or, as an alternative, no fuel shall be burned in the unit that contains sulfur in excess of 0.8 percent by weight (8,000 ppmw).	ADEM Admin. Code 335-3-1002(33)
	(d)	The permittee shall not discharge more than one six-minute average opacity greater than 20% during any 60-minute period from this unit. At no time shall the permittee discharge a six- minute average opacity of particulate emissions greater than 40% from this unit.	ADEM Admin. Code : 335-3-401(1)

	Federally Enforceable Provisos	Regulations
3.	Compliance and Performance Test Methods and Procedures	
	(a) Compliance with the nitrogen oxides (NO_x) emission rate of each unit shall be determined by EPA Reference Methods 1, 2, 3 and 4 or 19, and EPA Reference Method 7E in Appendix A of 40 CFR Part 60. NO_x emission data shall be reported in accordance with the requirements specified in 40 CFR Part 60, Subpart GG, the Standards of Performance for Stationary Gas Turbines.	ADEM Admin. Code r. 335-3-105 and ADEM Admin. Code r. 335-3-1002(33)
	(b) If the permittee elects to monitor the sulfur content of the fuel, this unit is subject to the applicable testing and procedure requirements of 40 CFR §60.335, which specifies the methods for determining the sulfur content of the fuel burned in each turbine [40 CFR §60.335(b)(10)(ii)].	ADEM Admin. Code r. 335-3-1002(33)
	(c) If testing is required, opacity shall be determined by 40 CFR Part 60, Appendix A, Reference Method 9.	ADEM Admin. Code r. 335-3-105
4.	Emission Monitoring	
	(a) Emission testing shall be conducted semiannually to determine compliance with the applicable NOx emission standards. Testing shall be conducted twice per calendar year at a frequency of once per semiannual period (Jan 1 st – Jun 30 th and Jul 1 st – Dec 31 st), with a minimum of three (3) calendar months elapsing between tests. The first emission testing conducted following the effective date of this permit shall be conducted in accordance with an approved EPA Reference Method for that pollutant. All subsequent emission testing during the permit term may be conducted using either an approved EPA Reference Method for that pollutant or utilizing a portable analyzer in accordance with a protocol/method approved in advance by the Air Division.	ADEM Admin. Code r. 335-3-1605(c)
	(b) The permittee shall monitor compliance with the applicable SO_2 standard in accordance with at least one of the options specified in 40 CFR §60.334(h))(4).	ADEM Admin. Code r. 335-3-1002(33) and 40 CFR part 60.334
	(c) The permittee shall only fire natural gas in this unit.	ADEM Admin. Code r. 335-3-1605(c)
5.	Recordkeeping and Reporting Requirements	
	(a) The permittee shall submit a semiannual certification that only fuel meeting the definition of "natural gas" as defined at 40 CFR §60.331(u) was fired in this unit. To demonstrate that the fuel met the definition of "natural gas", the certification shall include a copy of the information specified in 40 CFR §60.334(h)(3)(i) or 40 CFR §60.334(h)(4)(i). This certification shall be included as part of the semiannual report required by General Permit Proviso No. 21.	ADEM Admin. Code r. 335-3-1605(c)

Federally Enforceable Provisos	Regulations
(b) The permittee shall submit a Semiannual Monitoring Report, as required by general Permit Proviso No. 21(a), no later than 60 days after the end of each semiannual reporting period (March 10 th to September 9 th and September 10 th to March 9 th). The report shall include a statement addressing whether only natural gas was fired in this unit and all emission monitoring was conducted as required during the reporting period. If all emission monitoring was not conducted, the report shall explain the reason(s) why it was not performed.	ADEM Admin. Code r. 335-3-1605(c)
(c) The permittee shall submit the results of all emission tests conducted to the Air Division within 30 days of the actual completion of the test unless the Air Division specifically approves an extension of time. NO_x emission data shall be reported in accordance with the requirements specified in 40 CFR Part 60, Subpart GG, the Standards of Performance for Stationary Gas Turbines.	ADEM Admin. Code r. 335-3-1605(c)

Emission Unit Nos. C007 and C008 (Compressor Engine Nos. 11 and 12) Summary Page

Description: Two 2,000 hp Cooper-Bessemer GMVS-10, 2-stroke Lean-burn Natural Gasfired Reciprocating Internal Combustion Engines

Permitted Operating Schedule:	24 Hours	365 Days	_	8760 Hours
	Day	Year	_	Year

Emission Point Nos.	Description	Pollutant	Emission Limit	Regulation
		NO _x	72.75 lb/hr, each	ADEM Admin. Code r. 335-3-1404 (BACT)
	Two 2,000 hp Cooper-	СО	N/A	N/A
C007	Bessemer GMVS-10, 2- stroke Lean-burn Natural	VOC	N/A	N/A
C008	Gas-fired Reciprocating Internal Combustion Engines	SO ₂	N/A	N/A
	Englites	РМ	N/A	N/A
		HAP	N/A	N/A

Emission Unit Nos. C007 and C008 (Compressor Engine Nos. 11 and 12)

	Federally Enforceable Provisos	Regulations
1.	Applicability	
	(a) These units are subject to the applicable requirements of ADEM Admin. Code r. 335-3-1603, "Major Source Operating Permits."	ADEM Admin. Code r. 335-3-1603
	(b) These units are affected sources under 40 CFR Part 63, Subpart ZZZZ, National Emission Standards for Hazardous Air Pollutants for Stationary Reciprocating Internal Combustion Engines.	ADEM Admin. Code r. 335-3-1106(103) and 40 CFR Part 63, Subpart ZZZZ
2.	Emission Standards	
	(a) The permittee shall not cause or allow emissions of nitrogen oxides (NO _x) from each unit to exceed 72.75 lb/hr.	ADEM Admin. Code r. 335-3-1404
	(b) The permittee shall not discharge more than one six-minute average opacity greater than 20% during any 60-minute period from these units. At no time shall the permittee discharge a six-minute average opacity of particulate emissions greater than 40% from these units.	ADEM Admin. Code r. 335-3-401(1)
3.	Compliance and Performance Test Methods and Procedures	
	 (a) Compliance with the nitrogen oxides (NO_x) emission rate of these units shall be determined by EPA Reference Methods 1, 2, 3 and 4 or 19, and EPA Reference Method 7E in Appendix A of 40 CFR Part 60. 	ADEM Admin. Code r. 335-3-105
	(b) If testing is required, opacity shall be determined by 40 CFR Part 60, Appendix A, Reference Method 9.	ADEM Admin. Code r. 335-3-105
4.	Emission Monitoring	
	(a) Emission testing shall be conducted semiannually to determine compliance with the applicable emission standard(s). Testing shall be conducted twice per calendar year at a frequency of once per semiannual period (Jan 1 st – Jun 30 th and Jul 1 st – Dec 31 st), with a minimum of three (3) calendar months elapsing between tests. The first emission testing conducted following the effective date of this permit shall be conducted in accordance with an approved EPA Reference Method for that pollutant. All subsequent emission testing during the permit term may be conducted using either an approved EPA Reference Method for that pollutant or utilizing a portable analyzer in accordance with a protocol/method approved in advance by the Air Division.	ADEM Admin. Code r. 335-3-1605(c)
	(b) The permittee shall only fire natural gas in these units.	ADEM Admin. Code r. 335-3-1605(c)

	Federally Enforceable Provisos	Regulations
5.	Recordkeeping and Reporting Requirements	
	(a) The permittee shall submit a Semiannual Monitoring Report, as required by general Permit Proviso No. 21(a), no later than 60 days after the end of each semiannual reporting period (March 10 th to September 9 th and September 10 th to March 9 th). The report shall include a statement addressing whether only natural gas was fired in these units and all emission monitoring was conducted as required during the reporting period. If all emission monitoring was not conducted, the report shall explain the reason(s) why it was not performed.	ADEM Admin. Code r. 335-3-1605(c)
	(b) The permittee shall submit the results of all emission tests conducted to the Air Division within 30 days of the actual completion of the test unless the Air Division specifically approves an extension of time.	ADEM Admin. Code r. 335-3-1605(c)

Emission Unit Nos. G001 (Emergency Generator Engine No. 1) Summary Page

Description: One 500 hp Caterpillar G398A S1, 4-stroke, Lean-burn Natural Gas-fired Emergency Reciprocating Internal Combustion Engine

Permitted Operating Schedule:	24 Hours	X	365 Days	- =	8760 Hours
	Day		Year		Year

Emission Point No.	Description	Pollutant	Emission Limit	Regulation
		NO _x	N/A	N/A
	One 500 hp Caterpillar G398A S1, 4-stroke, Lean- burn Natural Gas-fired Emergency Reciprocating Internal Combustion Engine	СО	N/A	N/A
0.001		VOC	N/A	N/A
G001		SO ₂	N/A	N/A
		РМ	N/A	N/A
		HAP	N/A	N/A

Emission Unit No. G001 (Emergency Generator Nos. 1)

				Regulations	
1.	Ap	plica	abilit	LY	
	(a)			it is subject to the applicable requirements of ADEM Code r. 335-3-1603, "Major Source Operating Permits."	ADEM Admin. Code r. 335-3-1603
	(b)	ZZZ for and defi this	ZZ, N Stati I me ined	it is an affected source under 40 CFR Part 63, Subpart ational Emission Standards for Hazardous Air Pollutants onary Reciprocating Internal Combustion Engines (RICE), ets the definition of an emergency stationary RICE as by 40 CFR §63.6675. The permittee shall only operate t as an emergency stationary RICE as specified by 40 CFR 0(f).	ADEM Admin. Code r. 335-3-1106(103) and 40 CFR Part 63, Subpart ZZZZ
2.	Em	issi	on S	tandards	
	(a)	40	CFR	mittee shall comply with the applicable requirements of §63.6602 and Table 2c to Subpart ZZZZ, which include, not be limited to:	40 CFR §63.6602
		(i)		et the following work practice requirements, except during iods of startup:	
			А.	Change oil and filter every 500 hours of within 1 year plus 30 days of the previous change, whichever comes first, or utilize an oil analysis program;	
			В.	Inspect spark plugs every 1,000 hours of operation or within 1 year plus 30 days of the previous change y, whichever comes first and replace as necessary; and	
			C.	Inspect all hoses and belts every 500 hours of operation or within 1 year plus 30 days of the previous change ly, whichever comes first, and replace as necessary.	
		(ii)	idle nee exce	ng periods of startup, minimize the engine's time spent at and minimize the engine's time at startup to a period ded for appropriate and safe loading of the engine, not to eed 30 minutes, after which time the non-startup ssion limitations apply.	
		(iii)	to s requ wor an wor the aba pra- una	init is operating during an emergency and it is not possible hut down the engine in order to perform the work practice airements on the schedule required, or if performing the k practice on the required schedule would otherwise pose unacceptable risk under Federal, State, or local law, the k practice can be delayed until the emergency is over or unacceptable risk under federal, state, or local law has ted. The work practice should be performed as soon as cticable after the emergency has ended or the acceptable risk under federal, state, or local law has ted.	

		Regulations	
(b)	CFF	permittee shall not operate this unit except as provided in 40 $(f)(4)$, which include but may not be ted to:	40 CFR §63.6640
	(i)	Emergency Situations;	
	(ii)	Operate the emergency stationary RICE for the purpose of maintenance checks and readiness testing, provided that the test are recommended by Federal, State or local government, the manufacturer, the vendor, or the insurance company associated with the engine. Maintenance checks and rediness testing of the unit is limited to 100 hours per year; and	
	(iii)	Operate the emergency stationary RICE up to 50 hours per year in non-emergency situations, but those 50 hours are counted toward the 100 hours per year provided for maintenance and testing. The 50 hours per year for non- emergency situations cannot be used for peak shaving or to generate income for a facility to suppy power to an electric grid or otherwise supply power as part of a financial arrangement with another entity.	
(c)	aver from min	permittee shall not discharge more than one six-minute rage opacity greater than 20% during any 60-minute period in this unit. At no time shall the permittee discharge a six- ute average opacity of particulate emissions greater than 40% in this unit.	ADEM Admin. Code r. 335-3-401(1)
3. <u>Co</u>	mpli	ance and Performance Test Methods and Procedures	
		ng is required, opacity shall be determined by 40 CFR Part 60, ix A, Reference Method 9.	ADEM Admin. Code r. 335-3-105
l. <u>En</u>	nissi	on Monitoring	
(a)	the dev pra mai	e permittee shall operate and maintain this unit according to manufacturer's emission-related written instructions <u>or</u> elop a maintenance plan that provides for, to the extent cticable, the maintenance and operation of the engine in a nner consistent with good air pollution control practices for imizing emissions.	40 CFR §63.6625(e) & 40 CFR §63.6640(a)
(b)		e permittee shall install a non-resettable hour meter if one is already installed.	40 CFR §63.6625(f)
(c)	The	permittee shall only fire natural gas in this unit.	ADEM Admin. Code r. 335-3-1605(c)
(d)	sha	hin 15 days of the end of each calendar month, the permittee Il calculate the hours of operation for this unit for the previous endar month and the previous 12-month period.	ADEM Admin. Code r. 335-3-1605(c)

		Federally Enforceable Provisos	Regulations	
5.	<u>Rec</u>	cordkeeping and Reporting Requirements		
	(a)	The permittee shall keep records of the operation maintenance of the unit in accordance with 40 CFR §6 At a minimum, these records shall include:		ADEM Admin. Code r. 335-3-1605(c) and 40 CFR §63.6655
		 (i) For each period of operation, the length of operation reason the engine was in operation during that the periods of operation designated as "emergency op the records shall reflect what classified the oper emergency; 	me. For eration,"	
		 (ii) The total number of hours the engine was operated calendar year subtotaled by the reason the engine operation; 		
		(iii) The dates of each oil and filter change w corresponding hour on the hour meter;	vith the	
		(iv) The dates of each inspection and replacement of plugs, hoses, and belts with the corresponding hour hour meter; and		
		(v) The dates and nature of other emission-related rep maintenance performed.	airs and	
	(b)	The permittee shall maintain on-site for the life of each either a copy of the manufacturer's emission-related of and maintenance instructions for the unit or the mair plan developed in accordance with 40 CFR §63.6625(e unit.	peration ntenance	ADEM Admin. Code r. 335-3-1605(c)
	(c)	The permittee shall maintain files of all information (inclu- reports and notifications) required by 40 CFR Part 63, S A and ZZZZ for this unit recorded in a form suitable and available for expeditious inspection and review. The files retained for at least 5 years following the date of each occ measurement, maintenance, corrective action, report, o At a minimum, the most recent 2 years of data shall be on-site. The remaining 3 years of data may be retained of	Subparts d readily shall be currence, r record. retained	ADEM Admin. Code r. 335-3-1605(c), 40 CFR §63.6660, and 40 CFR §63.10(b)(1)
	(d)	The permittee shall report to the Air Division any far perform a work practice on the schedule required, it instances when the work practice standard was not per- due to emergency operation or unacceptable risk under a state, or local law. The permittee shall submit the repo- two working days of the deviation and shall pro- explanation as to why the work practice requirement performed.	ncluding erformed a federal, rt within ovide an	ADEM Admin. Code r. 335-3-1605(c) and 40 CFR §63.6640(b)

	Federally Enforceable Provisos	Regulations
(e)	The permittee shall submit a Semiannual Monitoring Report, as required by general Permit Proviso No. 21(a), no later than 60 days after the end of each semiannual reporting period (March 10 th to September 9 th and September 10 th to March 9 th). The report shall include a statement addressing whether only natural gas was fired in this unit and all emsission monitoring was conducted. In addition, the permittee shall provide the 12-month rolling total for this unit as part of the Semiannual Monitoring Report.	ADEM Admin. Code r. 335-3-1605(c)

Emission Unit Nos. FGH1 (No. 1 Fuel Gas Heater) Summary Page

Permitted Operating Schedule:	24 Hours	365 Days	8760 Hours
	Day	Year	Year

Emission Point No.	Description	Pollutant	Emission Limit	Regulation
	One 0.25 MMBtu/hr Sivalls IH 306-T2, Natural Gas- fired Fuel Gas Heater	NOx	N/A	N/A
		СО	N/A	N/A
DOILI		VOC	N/A	N/A
FGH1		SO_2	N/A	N/A
		РМ	N/A	N/A
		НАР	N/A	N/A

Emission Unit Nos. FGH1 (No. 1 Fuel Gas Heater)

	Federally Enforceable Provisos	Regulations
1.	Applicability	
	(a) This unit is subject to the applicable requirements of ADEM Admin. Code r. 335-3-1603, "Major Source Operating Permits."	ADEM Admin. Code r. 335-3-1603
	(b) This unit is subject to the applicable requirements of 40 CFR Part 63, Subpart DDDDD, National Emission Standards for Hazardous Air Pollutants for Major Sources: Industrial, Commercial, and Institutional Boiler and Process Heaters. Pursuant to 40 CFR §63.7495(b) the facility must comply with this Subpart no later than January 31, 2016.	40 CFR Part 63, Subpart DDDDD and ADEM Admin. Code r. 335-3-1106 (107)
2.	Emission Standards	
	The permittee shall not discharge more than one six-minute average opacity greater than 20% during any 60-minute period from this unit. At no time shall the permittee discharge a six-minute average opacity of particulate emissions greater than 40% from this unit.	ADEM Admin. Code r. 335-3-401(1)
3.	Compliance and Performance Test Methods and Procedures	
	If testing is required, opacity shall be determined by 40 CFR Part 60, Appendix A, Reference Method 9.	ADEM Admin. Code r. 335-3-105
4.	Emission Monitoring	
	(a) The permittee shall only fire natural gas in this unit.	ADEM Admin. Code r. 335-3-1605(c)
	(b) The permittee shall complete a tune-up on this unit every five years following the January 31, 2016, compliance date as specified in 40 CFR §63.7540(a)(10)(i) through (vi).	40 CFR §63.7500(e)
5.	Recordkeeping and Reporting Requirements	
	(a) The permittee shall keep a copy of each notification and report submitted to comply with 40 CFR Part 63, Subpart DDDDD, including all documentation supporting any Initial Notification or Notification of Compliance or compliance report submitted according to the requirements in 40 CFR §63.10(b)(2)(xiv).	40 CFR §63.7555 and 40 CFR §63.10
	(b) The permittee shall submit a compliance report every five years after the January 31, 2016, compliance date containing the information specified in 40 CFR §63.7550(c). The compliance report must be postmarked or submitted no later than January 31 following the end of the five year period.	40 CFR §63.7550

Federally Enforceable Provisos	Regulations
(c) The permittee shall submit a Semiannual Monitoring Report, as required by general Permit Proviso No. 21(a), no later than 60 days after the end of each semiannual reporting period (March 10 th to September 9 th and September 10 th to March 9 th). The report shall include a statement addressing whether only natural gas was fired in this unit during the reporting period.	