

EDWARD F. POOLOS
DIRECTOR

JEFFERY W. KITCHENS
DEPUTY DIRECTOR



KAY IVEY
GOVERNOR

September 25, 2025

Dr. William Dozier
Miller Research and Education Center
1088 Auburn Lakes Road
Auburn, AL 36830

RE: **UIC PERMIT NUMBER ALSI9941557**
Auburn Poultry Science Facility
1088 Auburn Lakes Road
Auburn, Lee County, AL

Dear Dr. Dozier:

A **Draft** copy of the permit is enclosed for your review.

If you have any comments on the draft permit, please submit them to this office **within the next thirty (30) days** so that any issues of concern might be resolved.

If you have any questions concerning this permit, please contact me at (334) 271-7959 or jessica.spence@adem.alabama.gov.

Sincerely,

Jessica Spence
UIC Program

Enclosure

JS/



Birmingham Office
110 Vulcan Road
Birmingham, AL 35209-4702
(205) 942-6168
(205) 941-1603 (FAX)

Decatur Office
2715 Sandlin Road, S.W.
Decatur, AL 35603-1333
(256) 353-1713
(256) 340-9359 (FAX)

Coastal Office
1615 South Broad Street
Mobile, AL 36605
(251) 450-3400
(251) 479-2593 (FAX)



UNDERGROUND INJECTION CONTROL PERMIT

PERMITTEE: Auburn University Miller Research and Education Center

FACILITY/LOCATION: Auburn Poultry Science Facility
1088 Auburn Lakes Road
Auburn, Lee County, Alabama
Lat: N 32.684722°/Long: W -85.506944°

PERMIT NUMBER: ALSI9941557

INJECTION WELL CLASS: Class V

SOURCE OF POLLUTANTS: Injection of treated poultry process and wash down water.

In accordance with and subject to the provisions of the Safe Drinking Water Act, as amended, 42 U.S.C. §§ 300f-300j (the "SDWA"), the Alabama Water Pollution Control Act, as amended, Code of Alabama 1975, §§ 22-22-1 to 22-22-14, (the "AWPCA"), the Alabama Environmental Management Act, as amended, Code of Alabama 1975, §§ 22-22A-1 to 22-22A-15, and rules and regulations adopted thereunder, and subject further to the terms and conditions set forth in this permit, the Permittee is hereby authorized to construct and operate injection well(s) of the above-described class.

ISSUANCE DATE:

EFFECTIVE DATE:

EXPIRATION DATE:

Alabama Department of Environmental Management
Water Division Chief

PART I Authorization to Operate

- A. The permittee is authorized to operate a Class V Injection Well at the facility described in the permit application and in the cover page of this permit, in accordance with the provisions set forth in this permit. In the case of this permit, the disposal system is defined as the injection well.
- B. The permittee must have routine and daily control of the treatment and effluent disposal system for operation in accordance with the terms of this permit.
- C. Only the treated sanitary wastewater described in the original permit application and any subsequent permit application modification issued by the Alabama Department of Environmental Management (ADEM) shall be injected.
- D. This permit and the authorization to inject shall remain in effect until the expiration date as stated on the cover page of this permit. If the permittee desires to continue injection past the expiration date of this permit, the permittee shall request a permit reissuance at least 180 days prior to expiration of this permit.

PART II Construction Requirements

- A. Injection Well Requirements
 - 1. The permittee shall inject only wastewater that has been treated by passing through a wastewater treatment system. The treatment system shall be adequate to meet the discharge limitations contained in Appendix A.
 - 2. Injected effluent shall not surface from the effluent disposal system.
 - 3. The permittee shall maintain a means of sampling the wastewater after treatment and prior to injection. The plans for the sampling access are required to be submitted to ADEM.
 - 4. The disposal field areas shall be the areas identified in the permit application.
 - 5. The disposal field areas shall be maintained so that standing or ponded water resulting from precipitation does not occur.
 - 6. Adequate select soil fill material shall be maintained in areas where shallow subsurface soil restrictive features might limit effluent absorption.
 - 7. The loading rate of treated wastewater shall not exceed the design loading rate as specified in the permit application.

B. Modifications

Approval by ADEM shall be obtained prior to modification of any injection well or supporting surface. Modification shall mean any action that will change the configuration of the well beneath the surface, the methods of monitoring injection, or will result in injection of a fluid not specifically authorized by this permit.

PART III Monitoring and Operating Requirements

A. Injection Fluid

1. The permittee shall not inject any substance that is defined as hazardous or toxic by Federal or State laws or regulations or any substance not identified in the application for this permit. The proposed use of substances other than those identified in the permit application must be reviewed and approved by ADEM prior to use.
2. The daily volume of injected wastewater shall not exceed the design flow of 5,400 gallons per day, in accordance with the plans and specifications submitted with the permit application.
3. The rate of wastewater injection into the effluent disposal system shall not exceed the soil infiltration rate and the requirements of Part II.A. of this permit.
4. The permittee shall monitor the fluid to be injected as specified in Appendix A of this permit.
5. The permittee shall not exceed the limits established in Appendix A of this permit.
6. ADEM may change the sampling requirements if the sampling data indicates a need to do so.

B. Groundwater Monitoring Requirements

1. The permittee shall maintain monitoring wells sufficient to monitor groundwater quality immediately hydraulically down gradient of the disposal fields.
2. Each monitoring well shall include the following.
 - a) The permittee shall screen each monitoring well in the uppermost saturated zone. The well screen shall be of sufficient length to account for seasonal fluctuations in the water table and effects of the subsurface effluent disposal system.
 - b) The annulus around each well casing above the well screen shall be sealed with bentonite to prevent the passage of surface water into the injection zone.
 - c) The surface installation shall include a concrete protective pad around the base of the well, a metal protective casing, and a locking cap.
3. All surface water shall be routed away from the monitoring well's surface installation.
4. The permittee shall monitor the groundwater as specified in Appendix B of this permit.
5. The permittee shall not exceed the limits established in Appendix B of this permit.
6. ADEM may change the sampling requirements if the sampling data indicates a need to do so.

C. Test Procedures

Test procedures for the analysis of pollutants shall conform to 40 CFR Part 136 of the Federal Register and guidelines published pursuant to Section 304(h) of the Federal Water Pollution Control Act (FWPCA). If more than one method of analysis of a substance is approved for use, a method having a detection limit lower than the permit limit shall be used. If the detection limit of all methods is higher than the permit limit, the method having the lowest detection limit shall be used and a report of less than detection limit shall constitute compliance. However, should the Environmental Protection Agency (EPA) approve a method with a lower detection limit during the term of this permit the permittee shall use the newly approved method.

D. Certified Operation

If required by ADEM, the wastewater treatment plant shall only be operated by a duly certified operator who meets the requirements specified in ADEM Administrative Code, Rule 335-10-1.

E. Operation

1. The injection well(s) operated under this permit shall function properly and wastewater shall not surface. Should the injection well fail to function properly, the permittee shall take immediate corrective action, to include cessation of injection, as required by ADEM.
2. The permittee shall adopt the following best management practices:
 - a) Properly operate and maintain in good working order all treatment or control facilities or systems (and related appurtenances) installed or used by the permittee to achieve compliance with the terms and conditions of this permit. Proper operation and maintenance includes effective performance, adequate funding, adequate operator staffing and training, and adequate laboratory and process controls, including appropriate quality assurance procedures. This provision requires operation of back-up or auxiliary facilities or similar systems only when necessary to achieve compliance with the terms and conditions of this permit.
 - b) Comply with Federal, State, and local solid and liquid waste disposal regulations.
 - c) Solids, sludges, filter backwash, or any other pollutant or other waste removed in the course of treatment or control of wastewaters shall be disposed in a manner that complies with all applicable ADEM rules and regulations.
 - d) Upon the loss or failure of any treatment facilities, including but not limited to the loss or failure of the primary source of power of the treatment facility, the permittee shall, where necessary to maintain compliance with the discharge limitations specified in Appendix A, of this permit, or any other terms or conditions of this permit, cease, reduce or otherwise control all discharges until treatment is restored. If control of discharges during loss or failure of the primary source of power is to be accomplished by means of alternate power sources, standby generators or retention of inadequately treated effluent, the permittee must furnish to ADEM prior to the initiation of injection, a certification that such control mechanisms have been installed.

3. Bypass

- a) A bypass of the permitted injection well is prohibited.

F. Monitoring Equipment and Instrumentation

All equipment and instrumentation used to determine compliance with the requirements of this permit shall be installed, maintained, and calibrated in accordance with the manufacturer's instructions or, in the absence of manufacturer's instructions, in accordance with accepted practices. At a minimum, flow measurement devices shall be calibrated at least once every 12 months.

PART IV Records, Reports, & Submittals

A. Records

1. The permittee shall record the information listed below for all monitoring activities:

- a) The date, exact place, and time of sampling or sampling measurement(s);
- b) The name of individual(s) who perform the sampling or measurement(s);
- c) The date(s) analyses were performed;
- d) The name of the individual(s) who performed the analyses;
- e) The analytical or technical methods used;
- f) The results of each analysis performed; and
- g) The completed chain-of-custody forms for all samples collected.

2. The permittee shall retain all records concerning the data used to complete the permit application, the operation of the wells, and the nature and composition of pollutants injected; to include records of the calibration of instruments, meters and gauges, quality control records, and recordings from continuous monitoring instrumentation for the previous three years of operation.

3. When requested by ADEM, the permittee shall deliver to ADEM copies of any of the records maintained in accordance with this permit.

B. Reports

1. The permittee shall submit monitoring reports not later than 28 days after each reporting period, whether a discharge occurs from the treatment system or not. The monitoring reports shall include:

- a) The date, exact place, and time of sampling or sampling measurement(s);
- b) The results of each analysis performed.

2. If applicable, the permittee shall submit sludge inventory data not later than 30 days from the effective date of the permit which at a minimum contains the following information:
 - a) Type of sludge stabilization/digestion method, daily or annual sludge production (dry weight basis), and ultimate sludge disposal practice(s).
 - b) The permittee shall give prior notice to ADEM of at least 30 days of any change planned in the permittee's sludge disposal practices.
3. The permittee shall report to ADEM any of the following:
 - a) Any planned action which will change the use of the injection well, will result in injection of a fluid different from that authorized by this permit, will result in injection of wastewater at a rate greater than the design flow rate, will change the method of operations of the injection well, or will change the method of the monitoring of well operations or injected fluids. No such changes shall be implemented unless or until a permit modification has been received.
 - b) Any planned transfer of ownership of all or part of the permitted facility.
 - c) Any relevant facts of which the permittee becomes aware which should have been submitted in a permit application and any corrections to data previously submitted in a permit application.
4. Within 30 days upon the effective date of this permit the permittee must enroll and participate in the Department's Alabama Environmental and Permitting Compliance System (AEPACS) (<https://adem.alabama.gov/aepacs>). Once the permittee is enrolled in the system, the permittee must utilize the system for the submittal of DMRs. If the system is down due to technical problems originating with the Department's system, the permittee is not relieved of the obligation to submit DMR data by the required submittal date via faxing, e-mailing, mailing, or hand-delivery of data such that they are received by the required reporting date.
5. Studies, engineering reports, plans and specifications, plugging and abandonment plans, logging reports, and other technical documents submitted to comply with this permit shall be prepared by or under the supervision of qualified persons defined by Rule 6-8-.13 of the Underground Injection Control (UIC) Regulations of ADEM.

PART V Plugging and Abandonment

The permittee shall perform any abandonment and closure actions that may be required by ADEM to remove a threat to groundwater quality or to the health of persons.

PART VI Permit Modification, Revocation, Suspension, and Termination

- A. ADEM may impose emergency additional conditions to this permit when necessary to protect waters of the state from pollution. These conditions may include suspension of the permit to inject. Any such condition shall remain in effect until the permit is modified, revoked, suspended or terminated in accordance with the UIC Regulations of ADEM.

- B. Non-emergency permit modification, revocation, suspension, and termination actions shall be accomplished in accordance with ADEM Administrative Rule 335-6-8.

PART VII General Provisions

- A. The permittee shall comply with all provisions of the UIC Regulations of ADEM and shall comply with all provisions of this permit and shall reduce or halt injection if needed to maintain compliance with the permit and regulations.
- B. The permittee shall comply with all applicable Federal and State hazardous waste management regulations.
- C. The permittee shall allow members of the ADEM staff to:
1. Access property and records of the permittee for purposes of inspection.
 2. Collect samples of the injected fluids, process and wastewater streams associated with the permitted injection wells.
 3. Collect samples from monitoring wells.
 4. Obtain copies of records upon request.
- D. The permittee shall immediately take all reasonable steps to minimize or correct any adverse environmental impact resulting from the operation of the permitted injection wells.
- E. This permit does not convey any property rights of any sort, or any exclusive privilege.
- F. The filing of a request by the permittee for a permit modification, revocation, and reissuance, or termination, or a notification of planned changes or anticipated noncompliance does not stay any permit condition.
- G. Any noncompliance with this permit constitutes a violation of the Alabama Water Pollution Control Act (AWPCA) and/or the UIC regulations and is grounds for enforcement action such as permit termination, revocation, modification; or denial of a permit renewal application.
- H. Injection to waters of the state, which in this case is groundwater, in accordance with this permit shall not result in the exceedance of a Maximum Contaminant Level (MCL) as established by the Environmental Protection Agency. Injection to groundwater, in accordance with this permit shall not result in a violation of a surface water quality standard.
- I. All provisions of ADEM Code Rule 335-6-8.12 are incorporated as terms and conditions of this permit by reference.
- J. The permittee authorized to discharge under this permit, who wishes to continue to discharge upon the expiration of this permit, shall submit an application for reissuance, using the Department's Alabama Environmental Permitting and Compliance System (AEPACS), unless the Permittee submits in writing valid justification as to why the electronic submittal process cannot be utilized and the Department approves in writing the utilization of hard copy submittals. The AEPACS can be accessed at the following link: <http://adem.alabama.gov/AEPACS>. Such application shall be submitted at least 180 days prior to the expiration date of this permit. Permit requests for initial

issuance and modifications of the existing permit should all be submitted through the AEPACS system.

DRAFT

APPENDIX A

Effluent from the treatment system shall be limited and monitored prior to flowing into the effluent disposal system by the permittee as specified below:

<u>EFFLUENT CHARACTERISTICS</u>	<u>DISCHARGE LIMITATIONS</u>	<u>MONITORING REQUIREMENTS</u>		
	Monthly (mg/L)	FREQUENCY	SAMPLE TYPE	LOCATION
Biochemical Oxygen Demand (BOD5)	Report	Quarterly	Grab	Effluent
Total Suspended Solids (TSS)	Report	Quarterly	Grab	Effluent
Total Kjeldahl Nitrogen (TKN)	Report	Quarterly	Grab	Effluent
Fecal Coliform colonies/100 ml	Report	Quarterly	Grab	Effluent
MAXIMUM				
pH	Report	Quarterly	Grab	Effluent
Flow (gallons per day)	5,400	Daily	Continuous	Effluent

APPENDIX B

The groundwater shall be limited and monitored by the permittee as specified below:

<u>GROUNDWATER CHARACTERISTICS</u>	<u>UNITS</u>	<u>DISCHARGE LIMITS</u>	<u>MONITORING REQUIREMENTS</u>	
			<u>FREQUENCY</u>	<u>SAMPLE TYPE</u>
Total Nitrate	mg/l	10	Quarterly	Grab
pH	Standard	Report	Quarterly	Grab

ADEM Permit Rationale

Date: September 25, 2025
Prepared By: Jessica Spence

Responsible Official: William Dozier

Permittee Name: Auburn University Miller Research and Education Center
1088 Auburn Lakes Road
Auburn, AL 36830

Facility/Site Name: Auburn Poultry Science Facility

Location: 1088 Auburn Lakes Road
Auburn, Lee County, AL 36830
Latitude: 32.684722/Longitude: -85.506944

UIC Permit Number: ALSI9941557

Draft permit is: Reissuance

Injection Description: Injection of treated poultry process and wash down water.

Discussion: Standard permit drafted.

1. No hazardous injection
2. Sampling point required
3. Monitoring well must be installed and sampled
4. Discharge must be sampled in accordance with Appendix A and B
5. Results must be submitted in a timely manner
6. BMPs included in permit
7. The effluent disposal area must be maintained to prevent the occurrence of standing water resulting from precipitation or injection of treated wastewater
8. All subsurface effluent disposal system components and equipment must be installed, monitored, and maintained in accordance with manufactures' directions
9. The loading rate of treated wastewater shall not exceed the design loading rate
10. AEPACS DMR Requirement included in permit
11. AEPACS required to be utilized for permit reissuances/modifications/transfers