



MAJOR SOURCE OPERATING PERMIT

PERMITTEE: TRANSCONTINENTAL GAS PIPE LINE COMPANY, LLC
FACILITY NAME: STATION 110
FACILITY/PERMIT NO.: 308-0014
LOCATION: WADLEY, RANDOLPH COUNTY, ALABAMA

In accordance with and subject to the provisions of the Alabama Air Pollution Control Act of 1971, Ala. Code §§ 22-28-1 to 22-28-23, as amended, the Alabama Environmental Management Act, Ala. Code §§ 22-22A-1 to 22-22A-17, as amended, and rules and regulations adopted there under, and subject further to the conditions set forth in this permit, the Permittee is hereby authorized to construct, install and use the equipment, device or other article described above.

*Pursuant to the **Clean Air Act of 1990**, all conditions of this permit are federally enforceable by EPA, the Alabama Department of Environmental Management, and citizens in general. Those provisions which are not required under the **Clean Air Act of 1990** are considered to be state permit provisions and are not federally enforceable by EPA and citizens in general. Those provisions are contained in separate sections of this permit.*

Issuance Date: DRAFT
Effective Date: DRAFT
Expiration Date: DRAFT

TABLE OF CONTENTS

GENERAL PERMIT PROVISOS	1
1. <i>Transfer</i>	1
2. <i>Renewals</i>	1
3. <i>Severability Clause</i>	1
4. <i>Compliance</i>	1
5. <i>Termination for Cause</i>	1
6. <i>Property Rights</i>	2
7. <i>Submission of Information</i>	2
8. <i>Economic Incentives, Marketable Permits, and Emissions Trading</i>	2
9. <i>Certification of Truth, Accuracy, and Completeness</i>	2
10. <i>Inspection and Entry</i>	2
11. <i>Compliance Provisions</i>	3
12. <i>Compliance Certification</i>	3
13. <i>Reopening for Cause</i>	4
14. <i>Additional Rules and Regulations</i>	4
15. <i>Equipment Maintenance or Breakdown</i>	4
16. <i>Operation of Capture and Control Devices</i>	5
17. <i>Obnoxious Odors</i>	5
18. <i>Fugitive Dust</i>	5
19. <i>Additions and Revisions</i>	6
20. <i>Recordkeeping Requirements</i>	6
21. <i>Reporting Requirements</i>	7
22. <i>Emission Testing Requirements</i>	7
23. <i>Payment of Emission Fees</i>	8
24. <i>Other Reporting and Testing Requirements</i>	8
25. <i>Title VI Requirements (Refrigerants)</i>	8
26. <i>Chemical Accidental Prevention Provisions</i>	8
27. <i>Display of Permit</i>	9
28. <i>Circumvention</i>	9
29. <i>Visible Emissions</i>	9
30. <i>Fuel-Burning Equipment</i>	9
31. <i>Process Industries – General</i>	9
32. <i>Averaging Time for Emission Limits</i>	10
33. <i>Open Burning</i>	10
34. <i>Permit Shield</i>	10
 EMISSION UNIT NOS. 001-007 (MAINLINE UNIT NOS. 1-7)	 11
<i>Summary Page</i>	11
<i>Unit Specific Provisos</i>	12
1. <i>Applicability</i>	12
2. <i>Emission Standards</i>	12
3. <i>Compliance and Performance Test Methods and Procedures</i>	12
4. <i>Emission Monitoring</i>	12
5. <i>Recordkeeping and Reporting Requirements</i>	13
 EMISSION UNIT NOS. 008 AND 009 (MAINLINE UNIT NOS. 8 AND 9).....	 14
<i>Summary Page</i>	14
<i>Unit Specific Provisos</i>	15
1. <i>Applicability</i>	15

2. Emission Standards	15
3. Compliance and Performance Test Methods and Procedures	15
4. Emission Monitoring.....	15
5. Recordkeeping and Reporting Requirements.....	16
EMISSION UNIT NOS. 010-012 (MAINLINE UNIT NOS. 10-12)	17
<i>Summary Page</i>	17
<i>Unit Specific Provisos</i>	18
1. Applicability	18
2. Emission Standards	18
3. Compliance and Performance Test Methods and Procedures	18
4. Emission Monitoring.....	18
5. Recordkeeping and Reporting Requirements.....	19
EMISSION UNIT NO. 013 (MAINLINE UNIT NO. 13)	20
<i>Summary Page</i>	20
<i>Unit Specific Provisos</i>	21
1. Applicability	21
2. Emission Standards	21
3. Compliance and Performance Test Methods and Procedures	21
4. Emission Monitoring.....	21
5. Recordkeeping and Reporting Requirements.....	21
EMISSION UNIT NOS. 014 AND 015 (MAINLINE UNIT NOS. 14 AND 15).....	22
<i>Summary Page</i>	22
<i>Unit Specific Provisos</i>	23
1. Applicability	23
2. Emission Standards	23
3. Compliance and Performance Test Methods and Procedures	23
4. Emission Monitoring.....	24
5. Recordkeeping and Reporting Requirements.....	24
EMISSION UNIT NOS. 022-024 (AUXILIARY UNIT NOS. 1-3).....	26
<i>Summary Page</i>	26
<i>Unit Specific Provisos</i>	27
1. Applicability	27
2. Emission Standards	27
3. Compliance and Performance Test Methods and Procedures	28
4. Emission Monitoring.....	28
5. Recordkeeping and Reporting Requirements.....	29
EMISSION UNIT NO. 025 (MAINLINE UNIT NO. 16)	31
<i>Summary Page</i>	31
<i>Unit Specific Provisos</i>	32
1. Applicability	32
2. Emission Standards	32
3. Compliance and Performance Test Methods and Procedures	33
4. Emission Monitoring.....	34
5. Recordkeeping and Reporting Requirements.....	35

EMISSION UNIT NO. 026 (MAINLINE UNIT NO. 17)	37
<i>Summary Page</i>	37
<i>Unit Specific Provisos</i>	38
1. Applicability	38
2. Emission Standards	38
3. Compliance and Performance Test Methods and Procedures	39
4. Emission Monitoring.....	41
5. Recordkeeping and Reporting Requirements.....	43
 EMISSION UNIT NO. 027 (AUXILIARY UNIT NO. 4)	 45
<i>Summary Page</i>	45
<i>Unit Specific Provisos</i>	46
1. Applicability	46
2. Emission Standards	46
3. Compliance and Performance Test Methods and Procedures	47
4. Emission Monitoring.....	47
5. Recordkeeping and Reporting Requirements.....	48

General Permit Provisos

Federally Enforceable Provisos	Regulations
<p>1. <u>Transfer</u></p> <p>This permit is not transferable, whether by operation of law or otherwise, either from one location to another, from one piece of equipment to another, or from one person to another, except as provided in ADEM Admin. Code r. 335-3-16-.13(1)(a)5.</p>	<p>ADEM Admin. Code r. 335-3-16-.02(6)</p>
<p>2. <u>Renewals</u></p> <p>An application for permit renewal shall be submitted at least six (6) months, but not more than eighteen (18) months, before the date of expiration of this permit.</p> <p>The source for which this permit is issued shall lose its right to operate upon the expiration of this permit unless a timely and complete renewal application has been submitted within the time constraints listed in the previous paragraph.</p>	<p>ADEM Admin. Code r. 335-3-16-.12(2)</p>
<p>3. <u>Severability Clause</u></p> <p>The provisions of this permit are declared to be severable and if any section, paragraph, subparagraph, subdivision, clause, or phrase of this permit shall be adjudged to be invalid or unconstitutional by any court of competent jurisdiction, the judgment shall not affect, impair, or invalidate the remainder of this permit, but shall be confined in its operation to the section, paragraph, subparagraph, subdivisions, clause, or phrase of this permit that shall be directly involved in the controversy in which such judgment shall have been rendered.</p>	<p>ADEM Admin. Code r. 335-3-16-.05(e)</p>
<p>4. <u>Compliance</u></p> <p>(a) The permittee shall comply with all conditions of ADEM Admin. Code 335-3. Noncompliance with this permit will constitute a violation of the Clean Air Act of 1990 and ADEM Admin. Code 335-3 and may result in an enforcement action; including but not limited to, permit termination, revocation and reissuance, or modification; or denial of a permit renewal application by the permittee.</p> <p>(b) The permittee shall not use as a defense in an enforcement action that maintaining compliance with conditions of this permit would have required halting or reducing the permitted activity.</p>	<p>ADEM Admin. Code r. 335-3-16-.05(f)</p> <p>ADEM Admin. Code r. 335-3-16-.05(g)</p>
<p>5. <u>Termination for Cause</u></p> <p>This permit may be modified, revoked, reopened, and reissued, or terminated for cause. The filing of a request by the permittee for a permit modification, revocation and reissuance, or termination, or of a notification of planned changes or anticipated noncompliance will not stay any permit condition.</p>	<p>ADEM Admin. Code r. 335-3-16-.05(h)</p>

General Permit Provisos

Federally Enforceable Provisos	Regulations
<p>6. <u>Property Rights</u></p> <p>The issuance of this permit does not convey any property rights of any sort, or any exclusive privilege.</p>	ADEM Admin. Code r. 335-3-16-.05(i)
<p>7. <u>Submission of Information</u></p> <p>The permittee must submit to the Air Division, within 30 days or for such other reasonable time as the Air Division may set, any information that the Air Division may request in writing to determine whether cause exists for modifying, revoking and reissuing, or terminating this permit or to determine compliance with this permit. Upon receiving a specific request, the permittee shall also furnish to the Air Division copies of records required to be kept by this permit.</p>	ADEM Admin. Code r. 335-3-16-.05(j)
<p>8. <u>Economic Incentives, Marketable Permits, and Emissions Trading</u></p> <p>No permit revision shall be required, under any approved economic incentives, marketable permits, emissions trading and other similar programs or processes for changes that are provided for in this permit.</p>	ADEM Admin. Code r. 335-3-16-.05(k)
<p>9. <u>Certification of Truth, Accuracy, and Completeness</u></p> <p>Any application form, report, test data, monitoring data, or compliance certification submitted pursuant to this permit shall contain certification by a responsible official of truth, accuracy, and completeness. This certification shall state that, based on information and belief formed after reasonable inquiry, the statements and information in the document are true, accurate and complete.</p>	ADEM Admin. Code r. 335-3-16-.07(a)
<p>10. <u>Inspection and Entry</u></p> <p>Upon presentation of credentials and other documents as may be required by law, the permittee shall allow authorized representatives of the Alabama Department of Environmental Management and EPA to conduct the following:</p> <ul style="list-style-type: none">(a) Enter upon the permittee's premises where a source is located or emissions-related activity is conducted, or where records must be kept pursuant to the conditions of this permit;(b) Review and/or copy, at reasonable times, any records that must be kept pursuant to the conditions of this permit;(c) Inspect, at reasonable times, this facility's equipment (including monitoring equipment and air pollution control equipment), practices, or operations regulated or required pursuant to this permit;	ADEM Admin. Code r. 335-3-16-.07(b)

General Permit Provisos	
Federally Enforceable Provisos	Regulations
<p>(d) Sample or monitor, at reasonable times, substances or parameters for the purpose of assuring compliance with this permit or other applicable requirements.</p> <p>11. Compliance Provisions</p> <p>(a) The permittee shall continue to comply with the applicable requirements with which the company has certified that it is already in compliance.</p> <p>(b) The permittee shall comply in a timely manner with applicable requirements that become effective during the term of this permit.</p> <p>12. Compliance Certification</p> <p>The permittee shall submit a complete and accurate compliance certification by April 2nd of each year for each annual reporting period of this permit (February 1st – January 31st).</p> <p>(a) The compliance certification shall include the following:</p> <ol style="list-style-type: none"> (1) The identification of each term or condition of this permit that is the basis of the certification; (2) The compliance status; (3) The method(s) used for determining the compliance status of the source, currently and over the reporting period consistent with ADEM Admin. Code r. 335-3-16-.05(c) (Monitoring and Recordkeeping Requirements); (4) Whether compliance has been continuous or intermittent; (5) Such other facts as the Air Division may require to determine the compliance status of the source; <p>(b) The compliance certification shall be submitted to:</p> <p style="text-align: center;">Alabama Department of Environmental Management Air Division P.O. Box 301463 Montgomery, AL 36130-1463</p> <p style="text-align: center;">and to:</p> <p style="text-align: center;">EPA Region 4 via email at EPA_R4_CAA_Reports@epa.gov or through the EPA's Compliance and Emissions Data Reporting Interface (CEDRI)</p>	<p>ADEM Admin. Code r. 335-3-16-.07(c)</p> <p>ADEM Admin. Code r. 335-3-16-.07(e)</p>

General Permit Provisos

Federally Enforceable Provisos	Regulations
<p>13. <u>Reopening for Cause</u></p> <p>Under any of the following circumstances, this permit will be reopened prior to the expiration of the permit:</p> <ul style="list-style-type: none">(a) Additional applicable requirements under the Clean Air Act of 1990 become applicable to the permittee with a remaining permit term of three (3) or more years. Such a reopening shall be completed not later than eighteen (18) months after promulgation of the applicable requirement. No such reopening is required if the effective date of the requirement is later than the date on which this permit is due to expire.(b) Additional requirements (including excess emissions requirements) become applicable to an affected source under the acid rain program. Upon approval by the Administrator, excess emissions offset plans shall be deemed to be incorporated into this permit.(c) The Department or EPA determines that this permit contains a material mistake or that inaccurate statements were made in establishing the emissions standards or other terms or conditions of this permit.(d) The Administrator or the Department determines that this permit must be revised or revoked to assure compliance with the applicable requirements.	<p>ADEM Admin. Code r. 335-3-16-.13(5)</p>
<p>14. <u>Additional Rules and Regulations</u></p> <p>This permit is issued on the basis of Rules and Regulations existing on the date of issuance. In the event additional Rules and Regulations are adopted, it shall be the permit holder's responsibility to comply with such rules.</p>	<p>§22-28-16(d), <u>Code of Alabama 1975</u>, as amended</p>
<p>15. <u>Equipment Maintenance or Breakdown</u></p> <ul style="list-style-type: none">(a) In case of shutdown of air pollution control equipment (which operates pursuant to any permit issued by the Director) for necessary scheduled maintenance, the intent to shut down such equipment shall be reported to the Air Division at least (24) hours prior to the planned shutdown, unless such shutdown is accompanied by the shutdown of the source which such equipment is intended to control. Such prior notice shall include, but is not limited to the following:<ul style="list-style-type: none">(1) Identification of the specific facility to be taken out of service as well as its location and permit number;(2) The expected length of time that the air pollution control equipment will be out of service;	<p>ADEM Admin. Code r. 335-3-1-.07(1),(2)</p>

General Permit Provisos

Federally Enforceable Provisos	Regulations
<p>(3) The nature and quality of emissions of air contaminants likely to occur during the shutdown period;</p> <p>(4) Measures such as the use of off-shift labor and equipment that will be taken to minimize the length of the shutdown period;</p> <p>(5) The reasons that it would be impossible or impractical to shut down the sources operation during the maintenance period.</p> <p>(b) In the event that there is a breakdown of equipment or upset of process in such a manner as to cause, or is expected to cause, increased emissions of air contaminants which are above an applicable standard, the person responsible for such equipment shall notify the Director within 24 hours or the next working day and provide a statement giving all pertinent facts, including the estimated duration of the breakdown. The Director will be notified when the breakdown has been corrected.</p>	
<p>16. <u>Operation of Capture and Control Devices</u></p> <p>All air pollution control devices and capture systems for which this permit is issued shall be maintained and operated at all times in a manner so as to minimize the emissions of air contaminants. Procedures for ensuring that the above equipment is properly operated and maintained so as to minimize the emission of air contaminants shall be established.</p>	<p>§22-28-16(d), <u>Code of Alabama 1975</u>, as amended</p>
<p>17. <u>Obnoxious Odors</u></p> <p>This permit is issued with the condition that, should obnoxious odors arising from the plant operations be verified by Air Division inspectors, measures to abate the odorous emissions shall be taken upon a determination by the Alabama Department of Environmental Management that these measures are technically and economically feasible.</p>	<p>ADEM Admin. Code r. 335-3-1-.08</p>
<p>18. <u>Fugitive Dust</u></p> <p>(a) Precautions shall be taken to prevent fugitive dust emanating from plant roads, grounds, stockpiles, screens, dryers, hoppers, ductwork, etc.</p> <p>(b) Plant or haul roads and grounds will be maintained in the following manner so that dust will not become airborne. A minimum of one, or a combination, of the following methods shall be utilized to minimize airborne dust from plant or haul roads and grounds:</p>	<p>ADEM Admin. Code r. 335-3-4-.02</p>

General Permit Provisos

Federally Enforceable Provisos	Regulations
<p>(1) By the application of water any time the surface of the road is sufficiently dry to allow the creation of dust emissions by the act of wind or vehicular traffic;</p> <p>(2) By reducing the speed of vehicular traffic to a point below that at which dust emissions are created;</p> <p>(3) By paving;</p> <p>(4) By the application of binders to the road surface at any time the road surface is found to allow the creation of dust emissions.</p> <p>Should one, or a combination, of the above methods fail to adequately reduce airborne dust from plant or haul roads and grounds, alternative methods shall be employed, either exclusively or in combination with one or all of the above control techniques, so that dust will not become airborne. Alternative methods shall be approved by the Air Division prior to utilization.</p>	
<p>19. Additions and Revisions</p> <p>Any modifications to this source shall comply with the modification procedures in ADEM Admin. Code r. 335-3-16-.13 or 335-3-16-.14.</p>	<p>ADEM Admin. Code r. 335-3-16-.13 and 335-3-16-.14</p>
<p>20. Recordkeeping Requirements</p> <p>(a) Records of required monitoring information of the source shall include the following:</p> <ul style="list-style-type: none">(1) The date, place, and time of all sampling or measurements;(2) The date analyses were performed;(3) The company or entity that performed the analyses;(4) The analytical techniques or methods used;(5) The results of all analyses; and(6) The operating conditions that existed at the time of sampling or measurement. <p>(b) Retention of records of all required monitoring data and support information of the source for a period of at least 5 years from the date of the monitoring sample, measurement, report, or application. Support information includes all calibration and maintenance records and all original strip-chart recordings for continuous monitoring instrumentation and copies of all reports required by the permit.</p>	<p>ADEM Admin. Code r. 335-3-16-.05(c)2.</p>

General Permit Provisos

Federally Enforceable Provisos

Regulations

21. Reporting Requirements

- (a) Reports to the Air Division of any required monitoring shall be submitted at least every 6 months. All instances of deviations from permit requirements must be clearly identified in said reports. All required reports must be certified by a responsible official consistent with ADEM Admin. Code r. 335-3-16-.04(9).
- (b) Deviations from permit requirements shall be reported within 48 hours or 2 working days of such deviations, including those attributable to upset conditions as defined in the permit. The report will include the probable cause of said deviations, and any corrective actions or preventive measures that were taken.

ADEM Admin. Code r. 335-3-16-.05(c)3.

22. Emission Testing Requirements

Each point of emission which requires testing will be provided with sampling ports, ladders, platforms, and other safety equipment to facilitate testing performed in accordance with procedures established by Part 60 of Title 40 of the Code of Federal Regulations, as the same may be amended or revised.

ADEM Admin. Code r. 335-3-1-.05(3) and 335-3-1-.04(1)

The Air Division must be notified in writing at least 10 days in advance of all emission tests to be conducted and submitted as proof of compliance with the Department's air pollution control rules and regulations.

To avoid problems concerning testing methods and procedures, the following shall be included with the notification letter:

ADEM Admin. Code r. 335-3-1-.04

- (a) The date the test crew is expected to arrive, the date and time anticipated of the start of the first run, how many and which sources are to be tested, and the names of the persons and/or testing company that will conduct the tests.
- (b) A complete description of each sampling train to be used, including type of media used in determining gas stream components, type of probe lining, type of filter media, and probe cleaning method and solvent to be used (if test procedures require probe cleaning).
- (c) A description of the process(es) to be tested including the feed rate, any operating parameters used to control or influence the operations, and the rated capacity.
- (d) A sketch or sketches showing sampling point locations and their relative positions to the nearest upstream and downstream gas flow disturbances.

A pretest meeting may be held at the request of the source owner or the Air Division. The necessity for such a meeting and the required attendees will be determined on a case-by-case basis.

ADEM Admin. Code r. 335-3-1-.04

General Permit Provisos

Federally Enforceable Provisos	Regulations
<p>All test reports must be submitted to the Air Division within 30 days of the actual completion of the test unless an extension of time is specifically approved by the Air Division.</p>	
<p>23. <u>Payment of Emission Fees</u></p>	
<p>(a) The permittee shall remit the annual Operating Permit Fees required by ADEM Admin. Code r. 335-1-7-.04 according to the schedule in ADEM Admin. Code r. 335-1-7-.05.</p>	<p>ADEM Admin. Code r. 335-1-7-.05</p>
<p>(b) The permittee shall submit its estimate of actual emissions for the previous calendar year according to the schedule in ADEM Admin. Code r. 335-1-7-.05.</p>	<p>ADEM Admin. Code r. 335-1-7-.05</p>
<p>24. <u>Other Reporting and Testing Requirements</u></p>	
<p>Submission of other reports regarding monitoring records, fuel analyses, operating rates, and equipment malfunctions may be required as authorized in the Department's air pollution control rules and regulations. The Department may require emission testing at any time.</p>	<p>ADEM Admin. Code r. 335-3-1-.04(1)</p>
<p>25. <u>Title VI Requirements (Refrigerants)</u></p>	
<p>Any facility having appliances or refrigeration equipment, including air conditioning equipment, which use Class I or Class II ozone-depleting substances as listed in 40 CFR Part 82, Subpart A, Appendices A and B, shall service, repair, and maintain such equipment according to the work practices, personnel certification requirements, and certified recycling and recovery equipment specified in 40 CFR Part 82, Subpart F.</p>	<p>ADEM Admin. Code r. 335-3-16-.05(a)</p>
<p>No person shall knowingly vent or otherwise release any Class I or Class II substance into the environment during the repair, servicing, maintenance, or disposal of any device except as provided in 40 CFR Part 82, Subpart F.</p>	
<p>The responsible official shall comply with all reporting and recordkeeping requirements of 40 CFR §82.166. Reports shall be submitted to the US EPA and the Department as required.</p>	
<p>26. <u>Chemical Accidental Prevention Provisions</u></p>	
<p>If a chemical listed in Table 1 of 40 CFR §68.130 is present in a process in quantities greater than the threshold quantity listed in Table 1, then:</p>	<p>40 CFR Part 68</p>
<p>(a) The owner or operator shall comply with the provisions in 40 CFR Part 68.</p>	
<p>(b) The owner or operator shall submit one of the following:</p>	

General Permit Provisos

Federally Enforceable Provisos	Regulations
<p>(1) A compliance schedule for meeting the requirements of 40 CFR Part 68 by the date provided in 40 CFR § 68.10(a) or,</p> <p>(2) A certification statement that the source is in compliance with all requirements of 40 CFR Part 68, including the registration and submission of the Risk Management Plan.</p>	
<p>27. <u>Display of Permit</u></p> <p>This permit shall be kept under file or on display at all times at the site where the facility for which the permit is issued is located and will make the permit readily available for inspection by any or all persons who may request to see it.</p>	<p>ADEM Admin. Code r. 335-3-16-.02(2)</p>
<p>28. <u>Circumvention</u></p> <p>No person shall cause or permit the installation or use of any device or any means which, without resulting in the reduction in the total amount of air contaminant emitted, conceals or dilutes any emission of air contaminant which would otherwise violate the Division 3 rules and regulations.</p>	<p>ADEM Admin. Code r. 335-3-1-.10</p>
<p>29. <u>Visible Emissions</u></p> <p>Unless otherwise specified in the Unit Specific provisos of this permit, any source of particulate emissions shall not discharge more than one 6-minute average opacity greater than 20% in any 60-minute period. At no time shall any source discharge a 6-minute average opacity of particulate emissions greater than 40%. Opacity will be determined by 40 CFR Part 60, Appendix A, Method 9, unless otherwise specified in the Unit Specific provisos of this permit.</p>	<p>ADEM Admin. Code r. 335-3-4-.01(1)</p>
<p>30. <u>Fuel-Burning Equipment</u></p> <p>Unless otherwise specified in the Unit Specific provisos of this permit, no fuel-burning equipment may discharge particulate emissions in excess of the emissions specified in ADEM Admin. Code r. 335-3-4-.03.</p> <p>Unless otherwise specified in the Unit Specific provisos of this permit, no fuel-burning equipment may discharge sulfur dioxide emissions in excess of the emissions specified in ADEM Admin. Code r. 335-3-5-.01.</p>	<p>ADEM Admin. Code r. 335-3-4-.03</p> <p>ADEM Admin. Code r. 335-3-5-.01</p>
<p>31. <u>Process Industries – General</u></p> <p>Unless otherwise specified in the Unit Specific provisos of this permit, no process may discharge particulate emissions in excess of the emissions specified in ADEM Admin. Code r. 335-3-4-.04.</p>	<p>ADEM Admin. Code r. 335-3-4-.04</p>

General Permit Provisos

Federally Enforceable Provisos	Regulations
<p>32. <u>Averaging Time for Emission Limits</u></p> <p>Unless otherwise specified in the permit, the averaging time for the emission limits listed in this permit shall be the nominal time required by the specific test method.</p> <p>33. <u>Open Burning</u></p> <p>Precautions should be taken to ensure that no person shall ignite, cause to ignite, permit to be ignited, or maintain any open fire in such a manner as to cause the Department's rules and regulations applicable to open burning to be violated.</p> <p>34. <u>Permit Shield</u></p> <p>A Permit Shield exists under this operating permit in accordance with ADEM Admin. Code r. 335-3-16-.10 in that compliance with the conditions of this permit shall be deemed compliance with any applicable requirements as of the date of permit issuance. The permit shield is based on the accuracy of the information supplied in Regulatory Applicability Section of the application for this permit. Under this shield, it has been determined that requirements listed as non-applicable in such section are not applicable to this source.</p>	<p>ADEM Admin. Code r. 335-3-1-.05</p> <p>ADEM Admin. Code r. 335-3-3-.01</p> <p>ADEM Admin. Code r. 335-3-16-.10</p>

Emission Unit Nos. 001-007 (Mainline Unit Nos. 1-7)

Summary Page

Description: Seven (7) 2,500 hp Cooper GMW-10, 2-Stroke, Lean Burn, Natural Gas-fired Reciprocating Engines (MLU 1-7)

Permitted Operating Schedule: $\frac{24 \text{ Hours}}{\text{Day}} \times \frac{365 \text{ Days}}{\text{Year}} = \frac{8760 \text{ Hours}}{\text{Year}}$

Emission Limitations:

Emission Point Nos.	Description	Pollutant	Emission Limit	Regulation
001	Seven (7) 2,500 hp Cooper GMW-10, 2-Stroke, Lean Burn, Natural Gas-fired Reciprocating Engines	NO _x	22.87 lb/hr, each (Ozone Season May 1 st - September 30 th)	ADEM Admin. Code r. 335-3-8-.04
002		CO	N/A	N/A
003		VOC	N/A	N/A
004		SO ₂	N/A	N/A
005		PM	N/A	N/A
006		HAP	N/A	N/A
007				

Emission Unit Nos. 001-007 (Mainline Unit Nos. 1-7)

Unit Specific Provisos

Federally Enforceable Provisos	Regulations
<p>1. <u>Applicability</u></p> <p>(a) These units are subject to the applicable requirements of ADEM Admin. Code r. 335-3-16-.03, "Major Source Operating Permits."</p> <p>(b) These units are affected sources under 40 CFR Part 63, Subpart ZZZZ, the National Emission Standards for Hazardous Air Pollutants for Stationary Reciprocating Internal Combustion Engines.</p> <p>(c) These units are subject to the applicable requirements of ADEM Admin. Code r. 335-3-8-.04, "Standards for Stationary Reciprocating Internal Combustion Engines."</p>	<p>ADEM Admin. Code r. 335-3-16-.03</p> <p>ADEM Admin. Code r. 335-3-11-.06(103)</p> <p>ADEM Admin. Code r. 335-3-8-.04</p>
<p>2. <u>Emission Standards</u></p> <p>(a) The permittee shall not cause or allow emissions of nitrogen oxides (NO_x) from each of these units in excess of 22.87 lb/hr during each ozone season (May 1st - September 30th).</p> <p>(b) The permittee shall not discharge more than one six-minute average opacity greater than 20% in any 60-minute period from each of these units. At no time shall the permittee discharge a six-minute average opacity of particulate emissions greater than 40% from each of these units.</p>	<p>ADEM Admin. Code r. 335-3-8-.04</p> <p>ADEM Admin. Code r. 335-3-4-.01(1)</p>
<p>3. <u>Compliance and Performance Test Methods and Procedures</u></p> <p>(a) Compliance with the nitrogen oxides (NO_x) emission rate applicable to each unit shall be determined by Reference Methods 1, 2, 3 and 4 or 19, and Reference Method 7E in Appendix A of 40 CFR 60.</p> <p>(b) If testing is required, opacity shall be determined by 40 CFR Part 60, Appendix A, Method 9.</p>	<p>ADEM Admin. Code r. 335-3-8-.04</p> <p>ADEM Admin. Code r. 335-3-1-.05</p>
<p>4. <u>Emission Monitoring</u></p> <p>(a) For any ozone season (May 1st - September 30th) in which these units operate for the purpose of production (i.e. the compression/transmission of natural gas), emission testing for NO_x shall be conducted at least once during that ozone season or at least once during the six-month period preceding the first day of the ozone season. This emission testing may be conducted using either an approved EPA Reference Method for that pollutant or utilizing a portable analyzer in accordance with a protocol/method approved in advance by the Air Division.</p>	<p>ADEM Admin. Code r. 335-3-8-.04(6)</p>

Federally Enforceable Provisos	Regulations
<p>(b) The permittee shall only fire natural gas in these units.</p>	<p>ADEM Admin. Code r. 335-3-16-.05(c)</p>
<p>5. <u>Recordkeeping and Reporting Requirements</u></p>	
<p>(a) The permittee shall submit the results of all emission tests conducted to the Air Division within 30 days of the actual completion of the test unless the Air Division specifically approves an extension of time.</p>	<p>ADEM Admin. Code r. 335-3-8-.04(7)(c)</p>
<p>(b) The permittee shall maintain the following records for each of these units for each ozone season (May 1st - September 30th). These records shall be compiled into a permanent form suitable for inspection within 30 days of the end of each ozone season and shall be maintained on-site for a period of five years from the date of generation of each record.</p> <ul style="list-style-type: none"> (i) Identification and location of the unit; (ii) Calendar date of record; (iii) Number of hours operated during the ozone season; (iv) Type and quantity of fuel used during the ozone season; (v) Date and results of each emission-related inspection and a summary of any emissions-related maintenance, if taken; (vi) Results of all emission tests; and (vii) Any additional information described in the permittee's Phase II NO_x SIP Call Compliance Plan. 	<p>ADEM Admin. Code r. 335-3-8-.04(7)(a)</p>
<p>(c) The permittee shall submit a Semiannual Monitoring Report, as required by General Permit Proviso No. 21(a), no later than 60 days after the end of each semiannual period (January 1st - June 30th and July 1st - December 31st). The report shall include a statement addressing whether only natural gas was fired in these units and all emission monitoring was conducted as required during the reporting period. If all emission monitoring was not conducted, the report shall explain the reason(s) why it was not performed.</p>	<p>ADEM Admin. Code r. 335-3-16-.05(c)</p>

Emission Unit Nos. 008 and 009 (Mainline Unit Nos. 8 and 9)

Summary Page

Description: Two (2) 2,625 hp Cooper GMWA-10, 2-Stroke, Lean Burn, Natural Gas-fired Reciprocating Engines (MLU 8 and 9)

Permitted Operating Schedule: $\frac{24 \text{ Hours}}{\text{Day}} \times \frac{365 \text{ Days}}{\text{Year}} = \frac{8760 \text{ Hours}}{\text{Year}}$

Emission Limitations:

Emission Point Nos.	Description	Pollutant	Emission Limit	Regulation
008 009	Two (2) 2,625 hp Cooper GMWA-10, 2-Stroke, Lean Burn, Natural Gas-fired Reciprocating Engines	NO _x	24.02 lb/hr, each (Ozone Season May 1 st - September 30 th)	ADEM Admin. Code r. 335-3-8-.04
		CO	N/A	N/A
		VOC	N/A	N/A
		SO ₂	N/A	N/A
		PM	N/A	N/A
		HAP	N/A	N/A

Emission Unit Nos. 008 and 009 (Mainline Unit Nos. 8 and 9)

Unit Specific Provisos

Federally Enforceable Provisos	Regulations
<p>1. <u>Applicability</u></p> <p>(a) These units are subject to the applicable requirements of ADEM Admin. Code r. 335-3-16-.03, "Major Source Operating Permits."</p> <p>(b) These units are affected sources under 40 CFR Part 63, Subpart ZZZZ, the National Emission Standards for Hazardous Air Pollutants for Stationary Reciprocating Internal Combustion Engines.</p> <p>(c) These units are subject to the applicable requirements of ADEM Admin. Code r. 335-3-8-.04, "Standards for Stationary Reciprocating Internal Combustion Engines."</p>	<p>ADEM Admin. Code r. 335-3-16-.03</p> <p>ADEM Admin. Code r. 335-3-11-.06(103)</p> <p>ADEM Admin. Code r. 335-3-8-.04</p>
<p>2. <u>Emission Standards</u></p> <p>(a) The permittee shall not cause or allow emissions of nitrogen oxides (NO_x) from each of these units in excess of 24.02 lb/hr during each ozone season (May 1st - September 30th).</p> <p>(b) The permittee shall not discharge more than one six-minute average opacity greater than 20% in any 60-minute period from each of these units. At no time shall the permittee discharge a six-minute average opacity of particulate emissions greater than 40% from each of these units.</p>	<p>ADEM Admin. Code r. 335-3-14-.04</p> <p>ADEM Admin. Code r. 335-3-4-.01(1)</p>
<p>3. <u>Compliance and Performance Test Methods and Procedures</u></p> <p>(a) Compliance with the nitrogen oxides (NO_x) emission rate applicable to each unit shall be determined by Reference Methods 1, 2, 3 and 4 or 19, and Reference Method 7E in Appendix A of 40 CFR 60. Alternate test methods may be used provided prior approval by the Air Division is granted.</p> <p>(b) If testing is required, opacity shall be determined by 40 CFR Part 60, Appendix A, Method 9.</p>	<p>ADEM Admin. Code r. 335-3-8-.04</p> <p>ADEM Admin. Code r. 335-3-1-.05</p>
<p>4. <u>Emission Monitoring</u></p> <p>(a) For any ozone season (May 1st - September 30th) in which these units operate for the purpose of production (i.e. the compression/transmission of natural gas), emission testing for NO_x shall be conducted at least once during that ozone season or at least once during the six-month period preceding the first day of the ozone season. This emission testing may be conducted using either an approved EPA Reference Method for that pollutant or utilizing a portable analyzer in accordance with a protocol/method approved in advance by the Air Division.</p>	<p>ADEM Admin. Code r. 335-3-8-.04(6)</p>

Federally Enforceable Provisos	Regulations
<p>(b) The permittee shall only fire natural gas in these units.</p>	<p>ADEM Admin. Code r. 335-3-16-.05(c)</p>
<p>5. <u>Recordkeeping and Reporting Requirements</u></p>	
<p>(a) The permittee shall submit the results of all emission tests conducted to the Air Division within 30 days of the actual completion of the test unless the Air Division specifically approves an extension of time.</p>	<p>ADEM Admin. Code r. 335-3-8-.04(7)(c)</p>
<p>(b) The permittee shall maintain the following records for each of these units for each ozone season (May 1st – September 30th). These records shall be compiled into a permanent form suitable for inspection within 30 days of the end of each ozone season and shall be maintained on-site for a period of five years from the date of generation of each record.</p> <ul style="list-style-type: none"> (i) Identification and location of the unit; (ii) Calendar date of record; (iii) Number of hours operated during the ozone season; (iv) Type and quantity of fuel used during the ozone season; (v) Date and results of each emission-related inspection and a summary of any emissions-related maintenance, if taken; (vi) Results of all emission tests; and (vii) Any additional information described in the permittee's Phase II NO_x SIP Call Compliance Plan. 	<p>ADEM Admin. Code r. 335-3-8-.04(7)(a)</p>
<p>(c) The permittee shall submit a Semiannual Monitoring Report, as required by General Permit Proviso No. 21(a), no later than 60 days after the end of each semiannual period (January 1st – June 30th and July 1st – December 31st). The report shall include a statement addressing whether only natural gas was fired in these units and all emission monitoring was conducted as required during the reporting period. If all emission monitoring was not conducted, the report shall explain the reason(s) why it was not performed.</p>	<p>ADEM Admin. Code r. 335-3-16-.05(c)</p>

Emission Unit Nos. 010-012 (Mainline Unit Nos. 10-12)

Summary Page

Description: Three (3) 3,400 hp Cooper GMWC-10, 2-Stroke, Lean Burn, Natural Gas-fired Reciprocating Engines (MLU 10-12)

Permitted Operating Schedule: $\frac{24 \text{ Hours}}{\text{Day}} \times \frac{365 \text{ Days}}{\text{Year}} = \frac{8760 \text{ Hours}}{\text{Year}}$

Emission Limitations:

Emission Point Nos.	Description	Pollutant	Emission Limit	Regulation
010 011 012	Three (3) 3,400 hp Cooper GMWC-10, 2-Stroke, Lean Burn, Natural Gas-fired Reciprocating Engines	NO _x	31.11 lb/hr, each (Ozone Season May 1 st - September 30 th)	ADEM Admin. Code r. 335-3-8-.04
		CO	N/A	N/A
		VOC	N/A	N/A
		SO ₂	N/A	N/A
		PM	N/A	N/A
		HAP	N/A	N/A

Emission Unit Nos. 010-012 (Mainline Unit Nos. 10-12)

Unit Specific Provisos

Federally Enforceable Provisos	Regulations
<p>1. <u>Applicability</u></p> <p>(a) These units are subject to the applicable requirements of ADEM Admin. Code r. 335-3-16-.03, "Major Source Operating Permits."</p> <p>(b) These units are affected sources under 40 CFR Part 63, Subpart ZZZZ, the National Emission Standards for Hazardous Air Pollutants for Stationary Reciprocating Internal Combustion Engines.</p> <p>(c) These units are subject to the applicable requirements of ADEM Admin. Code r. 335-3-8-.04, "Standards for Stationary Reciprocating Internal Combustion Engines."</p>	<p>ADEM Admin. Code r. 335-3-16-.03</p> <p>ADEM Admin. Code r. 335-3-11-.06(103)</p> <p>ADEM Admin. Code r. 335-3-8-.04</p>
<p>2. <u>Emission Standards</u></p> <p>(a) The permittee shall not cause or allow emissions of nitrogen oxides (NO_x) from each of these units in excess of 31.11 lb/hr during each ozone season (May 1st – September 30th).</p> <p>(b) The permittee shall not discharge more than one six-minute average opacity greater than 20% in any 60-minute period from each of these units. At no time shall the permittee discharge a six-minute average opacity of particulate emissions greater than 40% from each of these units.</p>	<p>ADEM Admin. Code r. 335-3-14-.04</p> <p>ADEM Admin. Code r. 335-3-4-.01(1)</p>
<p>3. <u>Compliance and Performance Test Methods and Procedures</u></p> <p>(a) Compliance with the nitrogen oxides (NO_x) emission rate applicable to each unit shall be determined by Reference Methods 1, 2, 3 and 4 or 19, and Reference Method 7E in Appendix A of 40 CFR 60.</p> <p>(b) If testing is required, opacity shall be determined by 40 CFR Part 60, Appendix A, Method 9.</p>	<p>ADEM Admin. Code r. 335-3-8-.04</p> <p>ADEM Admin. Code r. 335-3-1-.05</p>
<p>4. <u>Emission Monitoring</u></p> <p>(a) For any ozone season (May 1st – September 30th) in which these units operate for the purpose of production (i.e. the compression/transmission of natural gas), emission testing for NO_x shall be conducted at least once during that ozone season or at least once during the six-month period preceding the first day of the ozone season. This emission testing may be conducted using either an approved EPA Reference Method for that pollutant or utilizing a portable analyzer in accordance with a protocol/method approved in advance by the Air Division.</p>	<p>ADEM Admin. Code r. 335-3-8-.04(6)</p>

Federally Enforceable Provisos	Regulations
<p>(b) The permittee shall only fire natural gas in these units.</p>	<p>ADEM Admin. Code r. 335-3-16-.05(c)</p>
<p>5. <u>Recordkeeping and Reporting Requirements</u></p>	
<p>(a) The permittee shall submit the results of all emission tests conducted to the Air Division within 30 days of the actual completion of the test unless the Air Division specifically approves an extension of time.</p>	<p>ADEM Admin. Code r. 335-3-8-.04(7)(c)</p>
<p>(b) The permittee shall maintain the following records for each of these units for each ozone season (May 1st – September 30th). These records shall be compiled into a permanent form suitable for inspection within 30 days of the end of each ozone season and shall be maintained on-site for a period of five years from the date of generation of each record.</p> <ul style="list-style-type: none"> (i) Identification and location of the unit; (ii) Calendar date of record; (iii) Number of hours operated during the ozone season; (iv) Type and quantity of fuel used during the ozone season; (v) Date and results of each emission-related inspection and a summary of any emissions-related maintenance, if taken; (vi) Results of all emission tests; and (vii) Any additional information described in the permittee's Phase II NO_x SIP Call Compliance Plan. 	<p>ADEM Admin. Code r. 335-3-8-.04(7)(a)</p>
<p>(c) The permittee shall submit a Semiannual Monitoring Report, as required by General Permit Proviso No. 21(a), no later than 60 days after the end of each semiannual period (January 1st – June 30th and July 1st – December 31st). The report shall include a statement addressing whether only natural gas was fired in these units and all emission monitoring was conducted as required during the reporting period. If all emission monitoring was not conducted, the report shall explain the reason(s) why it was not performed.</p>	<p>ADEM Admin. Code r. 335-3-16-.05(c)</p>

Emission Unit No. 013 (Mainline Unit No. 13)

Summary Page

Description: 3,400 hp Cooper 10V-250, 2-Stroke, Lean Burn, Natural Gas-fired Reciprocating Engine (MLU 13)

$$\text{Permitted Operating Schedule: } \frac{24 \text{ Hours}}{\text{Day}} \times \frac{365 \text{ Days}}{\text{Year}} = \frac{8760 \text{ Hours}}{\text{Year}}$$

Emission Limitations:

Emission Point No.	Description	Pollutant	Emission Limit	Regulation
013	3,400 hp Cooper 10V-250, 2-Stroke, Lean Burn, Natural Gas-fired Reciprocating Engine	NO _x	N/A	N/A
		CO	N/A	N/A
		VOC	N/A	N/A
		SO ₂	N/A	N/A
		PM	N/A	N/A
		HAP	N/A	N/A

Emission Unit No. 013 (Mainline Unit No. 13)

Unit Specific Provisos

Federally Enforceable Provisos	Regulations
<p>1. <u>Applicability</u></p> <p>(a) This unit is subject to the applicable requirements of ADEM Admin. Code r. 335-3-16-.03, "Major Source Operating Permits."</p> <p>(b) This unit is an affected source under 40 CFR Part 63, Subpart ZZZZ, the National Emission Standards for Hazardous Air Pollutants for Stationary Reciprocating Internal Combustion Engines.</p>	<p>ADEM Admin. Code r. 335-3-16-.03</p> <p>ADEM Admin. Code r. 335-3-11-.06(103)</p>
<p>2. <u>Emission Standards</u></p> <p>The permittee shall not discharge more than one six-minute average opacity greater than 20% in any 60-minute period from this unit. At no time shall the permittee discharge a six-minute average opacity of particulate emissions greater than 40% from this unit.</p>	<p>ADEM Admin. Code r. 335-3-4-.01(1)</p>
<p>3. <u>Compliance and Performance Test Methods and Procedures</u></p> <p>If testing is required, opacity shall be determined by 40 CFR Part 60, Appendix A, Method 9.</p>	<p>ADEM Admin. Code r. 335-3-1-.05</p>
<p>4. <u>Emission Monitoring</u></p> <p>The permittee shall only fire natural gas in this unit.</p>	<p>ADEM Admin. Code r. 335-3-16-.05(c)</p>
<p>5. <u>Recordkeeping and Reporting Requirements</u></p> <p>The permittee shall submit a Semiannual Monitoring Report, as required by General Permit Proviso No. 21(a), no later than 60 days after the end of each semiannual period (January 1st – June 30th and July 1st – December 31st). The report shall include a statement addressing whether only natural gas was fired in this unit during the reporting period.</p>	<p>ADEM Admin. Code r. 335-3-16-.05(c)</p>

Emission Unit Nos. 014 and 015 (Mainline Unit Nos. 14 and 15)

Summary Page

Description: Two (2) 5,500 hp Cooper 16V-250, 2-Stroke, Lean Burn, Natural Gas-fired Reciprocating Engines (MLU 14 and 15)

Permitted Operating Schedule: $\frac{24 \text{ Hours}}{\text{Day}} \times \frac{365 \text{ Days}}{\text{Year}} = \frac{8760 \text{ Hours}}{\text{Year}}$

Emission Limitations:

Emission Point Nos.	Description	Pollutant	Emission Limit	Regulation
014 015	Two (2) 5,500 hp Cooper 16V-250, 2-Stroke, Lean Burn, Natural Gas-fired Reciprocating Engines	NO _x	48.5 lb/hr, each	ADEM Admin. Code r. 335-3-14-.04
		CO	N/A	N/A
		VOC	N/A	N/A
		SO ₂	N/A	N/A
		PM	N/A	N/A
		HAP	N/A	N/A

Emission Unit Nos. 014 and 015 (Mainline Unit Nos. 14 and 15)

Unit Specific Provisos

Federally Enforceable Provisos	Regulations
<p>1. <u>Applicability</u></p> <p>(a) These units are subject to the applicable requirements of ADEM Admin. Code r. 335-3-16-.03, “Major Source Operating Permits.”</p> <p>(b) These units are subject to a synthetic minor source emission limit to restrict their potential to emit below the applicability threshold established at ADEM Admin. Code r. 335-3-14-.04, Air Permits Authorizing Construction in Clean Areas [Prevention of Significant Deterioration (PSD)].</p> <p>(c) These units are affected sources under 40 CFR Part 63, Subpart ZZZZ, the National Emission Standards for Hazardous Air Pollutants for Stationary Reciprocating Internal Combustion Engines.</p> <p>(d) These units are subject to the applicable requirements of ADEM Admin. Code r. 335-3-8-.04, “Standards for Stationary Reciprocating Internal Combustion Engines.”</p> <p>2. <u>Emission Standards</u></p> <p>(a) The permittee shall not cause or allow emissions of nitrogen oxides (NO_x) from each unit in excess of 48.5 lb/hr.</p> <p>(b) The permittee shall not discharge more than one six-minute average opacity greater than 20% in any 60-minute period from each of these units. At no time shall the permittee discharge a six-minute average opacity of particulate emissions greater than 40% from each of these units.</p> <p>3. <u>Compliance and Performance Test Methods and Procedures</u></p> <p>(a) Compliance with the nitrogen oxides (NO_x) emission rate applicable to each unit shall be determined by EPA Reference Methods 1, 2, 3 and 4 or 19, and EPA Reference Method 7E in Appendix A of 40 CFR 60.</p> <p>(b) If testing is required, opacity shall be determined by 40 CFR Part 60, Appendix A, Method 9.</p>	<p>ADEM Admin. Code r. 335-3-16-.03</p> <p>ADEM Admin. Code r. 335-3-14-.04</p> <p>ADEM Admin. Code r. 335-3-11-.06(103)</p> <p>ADEM Admin. Code r. 335-3-8-.04</p> <p>ADEM Admin. Code r. 335-3-14-.04</p> <p>ADEM Admin. Code r. 335-3-4-.01(1)</p> <p>ADEM Admin. Code r. 335-3-1-.05</p> <p>ADEM Admin. Code r. 335-3-1-.05</p>

Federally Enforceable Provisos	Regulations
<p>4. <u>Emission Monitoring</u></p> <p>(a) Emission testing shall be conducted semiannually to determine compliance with the applicable PSD synthetic minor source emission standard for NO_x. Testing shall be conducted twice per calendar year at a frequency of once per semiannual period (Jan 1st - Jun 30th and Jul 1st - Dec 31st), with a minimum of three (3) calendar months elapsing between tests. The first emission testing conducted following the effective date of this permit shall be conducted in accordance with an approved EPA Reference Method for NO_x. All subsequent emission testing during the permit term may be conducted using either an approved EPA Reference Method for that pollutant or utilizing a portable analyzer in accordance with a protocol/method approved in advance by the Air Division.</p> <p>(i) If emission results from the above referenced performance test are less than or equal to 75% of the emission limit, then the frequency of subsequent performance tests may be reduced from a semiannual to an annual basis, with no more than fourteen (14) months elapsing between tests.</p> <p>(ii) If the results of any subsequent performance test exceed 75% of the emission limit, then semiannual performance testing shall resume until the unit demonstrates compliance for two (2) consecutive testing events demonstrating emissions are less than or equal to 75% of the emission limit, at which time annual testing may resume.</p> <p>(iii) After the first performance test conducted following the issuance of this renewal permit, no periodic monitoring will be required if a unit does not operate for production purposes during the respective semiannual or annual testing period, whichever applies.</p> <p>(b) The permittee shall only fire natural gas in these units.</p>	<p>ADEM Admin. Code r. 335-3-16-.05(c)</p> <p>ADEM Admin. Code r. 335-3-16-.05(c)</p>
<p>5. <u>Recordkeeping and Reporting Requirements</u></p> <p>(a) The permittee shall submit the results of all emission tests conducted to the Air Division within 30 days of the actual completion of the test unless the Air Division specifically approves an extension of time.</p>	<p>ADEM Admin. Code r. 335-3-16-.05(c)</p>

Federally Enforceable Provisos	Regulations
<p>(b) The permittee shall submit a Semiannual Monitoring Report, as required by General Permit Proviso No. 21(a), no later than 60 days after the end of each semiannual period (January 1st – June 30th and July 1st – December 31st). The report shall include a statement addressing whether only natural gas was fired in these units and all emission monitoring was conducted as required during the reporting period. If all emission monitoring was not conducted, the report shall explain the reason(s) why it was not performed. The report shall also include a statement addressing whether these units were operated for production purposes during each respective reporting period.</p>	<p>ADEM Admin. Code r. 335-3-16-.05(c)</p>

Emission Unit Nos. 022-024 (Auxiliary Unit Nos. 1-3)

Summary Page

Description: Three (3) 498 hp Caterpillar G3508LE, 4-Stroke, Lean Burn Natural Gas-fired Emergency Reciprocating Engines (AUX 1-3)

Permitted Operating Schedule: $\frac{24 \text{ Hours}}{\text{Day}} \times \frac{365 \text{ Days}}{\text{Year}} = \frac{8760 \text{ Hours}}{\text{Year}}$

Emission Limitations:

Emission Point Nos.	Description	Pollutant	Emission Limit	Regulation
022 023 024	Three (3) 498 hp Caterpillar G3508LE, 4-Stroke, Lean Burn Natural Gas-fired Emergency Reciprocating Engines	NO _x	N/A	ADEM Admin. Code r. 335-3-11-.06(103) 40 CFR Part 63, Subpart ZZZZ (NESHAP)
		CO	N/A	
		VOC	N/A	
		SO ₂	N/A	
		PM	N/A	
		HAP	N/A	

Emission Unit Nos. 022-024 (Auxiliary Unit Nos. 1-3)

Unit Specific Provisos

Federally Enforceable Provisos	Regulations
<p>1. <u>Applicability</u></p> <p>(a) These units are subject to the applicable requirements of ADEM Admin. Code r. 335-3-16-.03, “Major Source Operating Permits.”</p> <p>(b) These units are subject to the applicable requirements of 40 CFR Part 63, Subpart ZZZZ, the National Emission Standards for Hazardous Air Pollutants for Stationary Reciprocating Internal Combustion Engines (RICE), and meet the definition for an emergency stationary RICE as provided by 40 CFR §63.6640(f). The permittee shall only operate these units as emergency stationary RICE as defined in this standard.</p> <p>2. <u>Emission Standards</u></p> <p>(a) The permittee shall comply with the applicable requirements of 40 CFR §63.6602 and Table 2c to Subpart ZZZZ, which include, but may not be limited to:</p> <p>(i) Meet the following work practice requirements, except during periods of startup:</p> <p>A. Change oil and filter every 500 hours of operation or within one year plus 30 days of the previous change, whichever comes first; <i>or</i> participate in the oil analysis program per 40 CFR §63.6625(j);</p> <p>B. Inspect spark plugs every 1,000 hours of operation or within one year plus 30 days of the previous inspection, whichever comes first, and replace as necessary; and</p> <p>C. Inspect all hoses and belts every 500 hours of operation or within one year plus 30 days of the previous inspection, whichever comes first, and replace as necessary.</p> <p>(ii) During periods of startup, minimize the engine’s time spent at idle and minimize the engine’s startup time at startup to a period needed for appropriate and safe loading of the engine, not to exceed 30 minutes, after which time the non-startup emission limitations apply.</p>	<p>ADEM Admin. Code r. 335-3-16-.03</p> <p>ADEM Admin. Code r. 335-3-11-.06(103)</p> <p>ADEM Admin. Code r. 335-3-11-.06(103)</p>

Federally Enforceable Provisos	Regulations
<p>(iii) If a unit is operating during an emergency and it is not possible to shut down the engine in order to perform the work practice requirements on the schedule required, or if performing the work practice on the required schedule would otherwise pose an unacceptable risk under Federal, State, or local law, the work practice can be delayed until the emergency is over or the unacceptable risk under Federal, State, or local law has abated. The work practice should be performed as soon as practicable after the emergency has ended or the unacceptable risk under Federal, State, or local law has abated.</p> <p>(b) The permittee shall not operate these units except as provided in 40 CFR §63.6640(f)(1) through (f)(4), which include but may not be limited to:</p> <p>(i) Emergency Situations;</p> <p>(ii) Operate the emergency stationary RICE for the purpose of maintenance checks and readiness testing, provided that the test are recommended by Federal, State or local government, the manufacturer, the vendor, or the insurance company associated with the engines. Maintenance checks and readiness testing of the units are limited to 100 hours per year; and</p> <p>(iii) Operate the emergency stationary RICE up to 50 hours per year in non-emergency situations, but those 50 hours are counted toward the 100 hours per year provided for maintenance and testing. The 50 hours per year for non-emergency situations cannot be used for peak shaving or to generate income for a facility to supply power to an electric grid or otherwise supply power as part of a financial arrangement with another entity.</p>	<p>ADEM Admin. Code r. 335-3-11-.06(103)</p>
<p>(c) The permittee shall not discharge more than one six-minute average opacity greater than 20% in any 60-minute period from each of these units. At no time shall the permittee discharge a six-minute average opacity of particulate emissions greater than 40% from each of these units.</p>	<p>ADEM Admin. Code r. 335-3-4-.01(1)</p>
<p>3. <u>Compliance and Performance Test Methods and Procedures</u></p>	
<p>If testing is required, opacity shall be determined by 40 CFR Part 60, Appendix A, Method 9.</p>	<p>ADEM Admin. Code r. 335-3-1-.05</p>
<p>4. <u>Emission Monitoring</u></p>	
<p>(a) The permittee shall operate and maintain these units according to the manufacturer's emission-related operation and maintenance instructions or develop and follow a maintenance plan that provides for, to the extent practicable, the maintenance and operation of the engine in a manner consistent with good air pollution control practices for minimizing emissions.</p>	<p>ADEM Admin. Code r. 335-3-11-.06(103)</p>

Federally Enforceable Provisos	Regulations
<p>(b) The permittee shall install a non-resettable hour meter on each unit if one is not already installed.</p> <p>(c) The permittee shall only fire natural gas in these units.</p> <p>(d) Within 15 days of the end of the month, the permittee shall calculate the hours of operation of each unit for the previous calendar month and the previous 12-month period.</p>	<p>ADEM Admin. Code r. 335-3-11-.06(103)</p> <p>ADEM Admin. Code r. 335-3-16-.05(c)</p> <p>ADEM Admin. Code r. 335-3-16-.05(c)</p>
<p>5. <u>Recordkeeping and Reporting Requirements</u></p>	
<p>(a) The permittee shall keep records of the operation and maintenance of each unit in accordance with 40 CFR §63.6655. At a minimum, these records shall include:</p> <p>(i) For each period of operation, the length of operation and the reason the engine was in operation during that time. For periods of operation designated as “emergency operation,” the records shall reflect what classified the operation as emergency;</p> <p>(ii) The total number of hours the engine was operated during a calendar year subtotaled by the reason the engine was in operation;</p> <p>(iii) The dates of each oil and filter change with the corresponding hour on the hour meter; <i>or</i> the dates of each oil analysis with the parameters that are analyzed as part of the program, the results of the analysis, and the oil changes for the engine;</p> <p>(iv) The dates of each inspection and replacement of air cleaners, hoses, and belts with the corresponding hour on the hour meter; and</p> <p>(v) The dates and nature of other emission-related repairs and maintenance performed.</p>	<p>ADEM Admin. Code r. 335-3-16-.05(c) and ADEM Admin. Code r. 335-3-11-.06(103)</p>
<p>(b) The permittee shall maintain on-site for the life of each unit either a copy of the manufacturer’s emission-related operation and maintenance instructions for the unit or the maintenance plan developed in accordance with 40 CFR §63.6625(e) for each unit.</p>	<p>ADEM Admin. Code r. 335-3-16-.05(c) and ADEM Admin. Code r. 335-3-11-.06(103)</p>
<p>(c) The permittee shall maintain files of all information (including all reports and notifications) required by 40 CFR Part 63, Subparts A and ZZZZ for each unit recorded in a form suitable and readily available for expeditious inspection and review. The files shall be retained for at least 5 years following the date of each occurrence, measurement, maintenance, corrective action, report, or record. At a minimum, the most recent 2 years of data shall be retained on-site. The remaining 3 years of data may be retained off-site.</p>	<p>ADEM Admin. Code r. 335-3-16-.05(c) and ADEM Admin. Code r. 335-3-11-.06(103)</p>

Federally Enforceable Provisos	Regulations
<p>(d) The permittee shall report to the Air Division any failure to perform a work practice on the schedule required, including instances when the work practice standard was not performed due to emergency operation or unacceptable risk under a federal, state, or local law. The permittee shall submit the report within two working days of the deviation and shall provide an explanation as to why the work practice requirement was not performed.</p> <p>(e) The permittee shall submit a Semiannual Monitoring Report, as required by General Permit Proviso No. 21(a), no later than 60 days after the end of each semiannual period (January 1st – June 30th and July 1st – December 31st). The report shall include a statement addressing whether only natural gas was fired in these units during the reporting period. If all emission monitoring was not conducted, the report shall explain the reason(s) why it was not performed.</p>	<p>ADEM Admin. Code r. 335-3-16-.05(c) and ADEM Admin. Code r. 335-3-11-.06(103)</p> <p>ADEM Admin. Code r. 335-3-16-.05(c)</p>

Emission Unit No. 025 (Mainline Unit No. 16)

Summary Page

Description: 16,553 hp Solar Mars 100-16000 Natural Gas-fired Combustion Turbine equipped with a Dry Low NO_x Combustor (MLU 16)

Permitted Operating Schedule: $\frac{24 \text{ Hours}}{\text{Day}} \times \frac{365 \text{ Days}}{\text{Year}} = \frac{8760 \text{ Hours}}{\text{Year}}$

Emission Limitations:

Emission Point No.	Description	Pollutant	Emission Limit	Regulation
025	16,553 hp Solar Mars T16000 Natural Gas-fired Combustion Turbine	NO _x	4.55 lb/hr OR 9 ppmvd at 15% O ₂ , dry basis	ADEM Admin. Code r. 335-3-14-.04
			25 ppmvd at 15% O ₂ , dry basis OR 150 ng/J of useful output (1.2 lb/MWh)	ADEM Admin. Code r. 335-3-10-.02(89) 40 CFR Part 60, Subpart KKKK (NSPS)
		CO	N/A	N/A
		VOC	N/A	N/A
		SO ₂	26 ng SO ₂ /J (0.060 lb SO ₂ /MMBtu) OR Fuel Sulfur Content < 20 grains per 100 standard cubic feet	ADEM Admin. Code r. 335-3-10-.02(89) 40 CFR Part 60, Subpart KKKK (NSPS)
		PM	N/A	N/A
		HAP	N/A	N/A

Emission Unit No. 025 (Mainline Unit No. 16)

Unit Specific Provisos

Federally Enforceable Provisos	Regulations
1. <u>Applicability</u>	
(a) This unit is subject to the applicable requirements of ADEM Admin. Code r. 335-3-16-.03, “Major Source Operating Permits.”	ADEM Admin. Code r. 335-3-16-.03
(b) This unit is subject to a synthetic minor source emission limit to restrict its potential to emit below the applicability threshold established at ADEM Admin. Code r. 335-3-14-.04, Air Permits Authorizing Construction in Clean Areas [Prevention of Significant Deterioration (PSD)].	ADEM Admin. Code r. 335-3-14-.04
(c) This unit is subject to the applicable requirements of 40 CFR Part 60, Subpart KKKK, the Standards of Performance for Stationary Combustion Turbines.	ADEM Admin. Code r. 335-3-10-.02(89)
(d) This unit is an affected source under 40 CFR Part 63, Subpart YYYY, the National Emission Standards for Hazardous Air Pollutants for Stationary Combustion Turbines.	ADEM Admin. Code r. 335-3-11-.06(102)
(e) This unit is subject to the applicable requirements of 40 CFR Part 60, Subpart OOOOb, the Standards of Performance for Crude Oil and Natural Gas Facilities For Which Construction, Modification, Or Reconstruction Commenced After December 6, 2022.	40 CFR Part 60, Subpart OOOOb
2. <u>Emission Standards</u>	
(a) The permittee shall not discharge more than one six-minute average opacity greater than 20% in any 60-minute period from this unit. At no time shall the permittee discharge a six-minute average opacity of particulate emissions greater than 40% from this unit.	ADEM Admin. Code r. 335-3-4-.01(1)
(b) PSD – Synthetic Minor Source Requirements	
The permittee shall not cause or allow emissions of nitrogen oxides (NO _x) from this unit in excess of 4.55 lb/hr or 9 ppmvd at 15% O ₂ , dry basis.	ADEM Admin. Code r. 335-3-14-.04
(c) 40 CFR Part 60, Subpart KKKK	
(i) This unit is subject to the applicable emission standards of 40 CFR §60.4320. The permittee shall not cause or allow emissions of nitrogen oxides (NO _x) from this unit in excess of 25 ppmvd at 15% O ₂ , dry basis or 150 ng/J of useful output (1.2 lb/MWh).	ADEM Admin. Code r. 335-3-10-.02(89)

Federally Enforceable Provisos	Regulations
<p>(ii) This unit is subject to the applicable emission standards of 40 CFR §60.4330. The permittee shall not burn any fuel in this turbine which contains total potential sulfur emissions in excess of 26 ng SO₂ (0.060 lb SO₂/MMBtu heat input) OR, as an alternative, no fuel shall be burned in this unit that contains sulfur in excess of 20 grains per 100 standard cubic feet.</p>	<p>ADEM Admin. Code r. 335-3-10-.02(89)</p>
<p>3. <u>Compliance and Performance Test Methods and Procedures</u></p>	
<p>(a) PSD – Synthetic Minor Source Requirements</p>	
<p>Compliance with the nitrogen oxides (NO_x) emission rate applicable to this unit shall be determined by EPA Reference Methods 1, 2, 3 and 4 or 19, and EPA Reference Method 7E in Appendix A of 40 CFR Part 60.</p>	<p>ADEM Admin. Code r. 335-3-1-.05</p>
<p>(b) 40 CFR Part 60, Subpart KKKK</p>	
<p>(i) Compliance with the nitrogen oxides (NO_x) emission rate applicable to this unit shall be determined by EPA Reference Methods 1, 2, 3 and 4 or 19, and EPA Reference Method 7E in Appendix A of 40 CFR Part 60.</p>	<p>ADEM Admin. Code r. 335-3-1-.05</p>
<p>(ii) This unit is subject to the applicable testing and procedure requirements of 40 CFR §60.4365, which include determining the sulfur content of the fuel burned in this turbine in accordance with one of the methods described in 40 CFR §60.4365(a).</p>	<p>ADEM Admin. Code r. 335-3-10-.02(89)</p>
<p>(c) 40 CFR Part 60, Subpart OOOOb</p>	
<p>The permittee shall demonstrate initial and continuous compliance with the following standards that apply to fugitive emissions components affected facilities found in 40 CFR §60.5410b(k) and §60.5415b(l):</p>	<p>40 CFR Part 60, Subpart OOOOb</p>
<p>(i) The permittee shall develop a fugitive emissions monitoring plan as required by 40 CFR §60.5397b(b), (c), and (d) [40 CFR §60.5410b(k)];</p>	
<p>(ii) The permittee shall conduct an initial and subsequent periodic monitoring survey as required by 40 CFR §60.5397b(f)(3) and 40 CFR §60.5397b(g)(1)(v) [40 CFR §60.5410b(k) and §60.5415b(l)]; and</p>	
<p>(iii) The permittee must repair each identified source of fugitive emissions for each affected facility as required by 40 CFR §60.5397b(h) [40 CFR §60.5410b(k) and §60.5415b(l)].</p>	
<p>(d) If testing is required, opacity shall be determined by 40 CFR Part 60, Appendix A, Method 9.</p>	<p>ADEM Admin. Code r. 335-3-1-.05</p>

Federally Enforceable Provisos	Regulations
<p>4. Emission Monitoring</p> <p>(a) The permittee shall only fire natural gas in this unit.</p> <p>(b) PSD – Synthetic Minor Source Requirements</p> <p>Emission testing shall be conducted semiannually to determine compliance with the applicable PSD synthetic minor source emission standard for NO_x. Testing shall be conducted twice per calendar year at a frequency of once per semiannual period (Jan 1st - Jun 30th and Jul 1st - Dec 31st), with a minimum of three (3) calendar months elapsing between tests. The first emission testing conducted following the effective date of this permit shall be conducted in accordance with an approved EPA Reference Method for NO_x. All subsequent emission testing during the permit term may be conducted using either an approved EPA Reference Method for that pollutant or utilizing a portable analyzer in accordance with a protocol/method approved in advance by the Air Division.</p> <p>(i) If emission results from the above referenced performance test are less than or equal to 75% of the emission limit, then the frequency of subsequent performance tests may be reduced from a semiannual to an annual basis, with no more than fourteen (14) months elapsing between tests.</p> <p>(ii) If the results of any subsequent performance test exceed 75% of the emission limit, then semiannual performance testing shall resume until the unit demonstrates compliance for two (2) consecutive testing events demonstrating emissions are less than or equal to 75% of the emission limit, at which time annual testing may resume.</p> <p>(iii) Periodic monitoring may be conducted concurrently with the annual or biennial EPA Reference Method test that is required by 40 CFR Part 60, Subpart KKKK.</p> <p>(iv) After the first performance test conducted following the issuance of this renewal permit, no periodic monitoring will be required if this unit does not operate for production purposes during the respective semiannual or annual testing period, whichever applies.</p> <p>(c) 40 CFR Part 60, Subpart KKKK</p> <p>(i) Emission testing shall be conducted annually to determine compliance with the applicable 40 CFR Part 60, Subpart KKKK emission standard for NO_x. Testing shall be conducted once per calendar year, with no more than fourteen (14) calendar months elapsing between tests. In accordance with 40 CFR §60.4340(a):</p>	<p>ADEM Admin. Code r. 335-3-16-.05(c)</p> <p>ADEM Admin. Code r. 335-3-16-.05(c)</p> <p>ADEM Admin. Code r. 335-3-10-.02(89)</p>

Federally Enforceable Provisos	Regulations
<p>A. If the NO_x emission results from the above referenced performance test are less than or equal to 75% of the NO_x emission limit, then the frequency of subsequent performance tests may be reduced to once every two (2) years, with no more than 26 calendar months following the previous performance test.</p> <p>B. If the results of any subsequent performance test exceed 75% of the NO_x emission limit, then annual performance testing must be resumed until the unit demonstrates compliance for two (2) consecutive testing events demonstrating emissions are less than or equal to 75% of the NO_x emission limit, at which time two (2) year testing may resume.</p> <p>(ii) The permittee shall perform subsequent emission testing once per calendar year to satisfy the Title V periodic monitoring requirement for the applicable 40 CFR Part 60, Subpart KKKK emission standard for NO_x. The subsequent annual emission testing may be conducted using either an approved EPA Reference Method or with a portable analyzer. Periodic monitoring may be conducted concurrently with the annual or biennial EPA Reference Method test that is required by 40 CFR Part 60, Subpart KKKK. No periodic monitoring will be required if the unit does not operate for production purposes during the annual testing period.</p> <p>(iii) This unit is subject to the applicable monitoring requirements of 40 CFR §60.4365, which include monitoring the total sulfur content of the fuel being fired in the unit. The permittee may demonstrate compliance with the applicable SO₂ emission standard by the use of the fuel quality characteristics in a current, valid purchase contract, tariff sheet or transportation contract for the fuel which specifies that the total sulfur content is 20 grains of sulfur or less per 100 standard cubic feet.</p>	<p>ADEM Admin. Code r. 335-3-16-.05(c)</p> <p>ADEM Admin. Code r. 335-3-10-.02(89)</p>
<p>5. <u>Recordkeeping and Reporting Requirements</u></p> <p>(a) The permittee shall submit a Semiannual Monitoring Report, as required by General Permit Proviso No. 21(a), no later than 60 days after the end of each semiannual period (January 1st – June 30th and July 1st – December 31st). The report shall include a statement addressing whether only natural gas was fired in this unit and all emission monitoring was conducted as required during the reporting period. If all emission monitoring was not conducted, the report shall explain the reason(s) why it was not performed. The report shall also include a statement addressing whether this unit was operated for production purposes during each respective reporting period.</p>	<p>ADEM Admin. Code r. 335-3-16-.05(c)</p>

Federally Enforceable Provisos	Regulations
<p>(b) 40 CFR Part 60, Subpart KKKK</p> <p>(i) The permittee shall maintain records of the most current fuel tariff sheet as required by 40 CFR §60.4365, on-site in a permanent form suitable for inspection for at least five (5) years (2 years on-site and 3 years off-site) from the date of generation of each record.</p> <p>(ii) As required by 40 CFR Part 60, Subpart KKKK, the permittee shall submit a written notification of the intent to conduct a performance test to the Air Division at least 30 days prior to conducting a performance test. The notification shall include a copy of the site-specific test plan required by §60.8(d).</p> <p>(iii) As required by 40 CFR §60.4375, the permittee shall submit the results of all emission tests conducted to the Air Division within 60 days of the actual completion of the test unless the Air Division specifically approves an extension of time.</p> <p>(c) 40 CFR Part 60, Subpart OOOOb</p> <p>The permittee shall perform the required notification, recordkeeping, and reporting requirements in accordance with 40 CFR §60.5420b, which include, but may not be limited to:</p> <p>(i) Initial Annual Report as specified in 40 CFR §60.5420b(b);</p> <p>(ii) Annual reports as specified in 40 CFR §60.5420b(b); and</p> <p>(iii) Recordkeeping requirements as specified in 40 CFR §60.5420b(c)(14).</p>	<p>ADEM Admin. Code r. 335-3-16-.05(c) and ADEM Admin. Code r. 335-3-10-.02(89)</p> <p>ADEM Admin. Code r. 335-3-10-.02(89)</p> <p>ADEM Admin. Code r. 335-3-10-.02(89)</p> <p>40 CFR Part 60, Subpart OOOOb</p>

Emission Unit No. 026 (Mainline Unit No. 17)

Summary Page

Description: 23,383 hp Solar Titan 130-23502S, Natural Gas-fired Combustion Turbine equipped with a Dry Low NO_x Combustor (MLU 17)

Permitted Operating Schedule: $\frac{24 \text{ Hours}}{\text{Day}} \times \frac{365 \text{ Days}}{\text{Year}} = \frac{8760 \text{ Hours}}{\text{Year}}$

Emission Limitations:

Emission Point No.	Description	Pollutant	Emission Limit	Regulation
026	23,383 hp Solar Titan 130-23502S Natural Gas-fired Combustion Turbine	NO _x	6.10 lb/hr OR 9 ppmvd at 15% O ₂ , dry basis	ADEM Admin. Code r. 335-3-14-.04
			25 ppmvd at 15% O ₂ , dry basis OR 150 ng/J of useful output (1.2 lb/MWh)	ADEM Admin Code r. 335-3-10-.02(89) 40 CFR Part 60, Subpart KKKK (NSPS)
		CO	N/A	N/A
		VOC	N/A	N/A
		SO ₂	26 ng SO ₂ /J (0.060 lb SO ₂ /MMBtu) OR Fuel Sulfur Content < 20 grains per 100 standard cubic feet	ADEM Admin Code r. 335-3-10-.02(89) 40 CFR Part 60, Subpart KKKK (NSPS)
		PM	N/A	N/A
		HAP	N/A	N/A
		Formaldehyde (CH ₂ O)	91 ppbvd at 15% O ₂	ADEM Admin Code r. 335-3-11-.06(102) 40 CFR Part 63, Subpart YYYY (NESHAP)

Emission Unit No. 026 (Mainline Unit No. 17)

Unit Specific Provisos

Federally Enforceable Provisos	Regulations
1. <u>Applicability</u>	
(a) This unit is subject to the applicable requirements of ADEM Admin. Code r. 335-3-16-.03, “Major Source Operating Permits.”	ADEM Admin. Code r. 335-3-16-.03
(b) This unit is subject to a synthetic minor source emission limit to restrict its potential to emit below the applicability threshold established at ADEM Admin. Code r. 335-3-14-.04, Air Permits Authorizing Construction in Clean Areas [Prevention of Significant Deterioration (PSD)].	ADEM Admin. Code r. 335-3-14-.04
(c) This unit is subject to the applicable requirements of 40 CFR Part 60, Subpart KKKK, the Standards of Performance for Stationary Combustion Turbines.	ADEM Admin. Code r. 335-3-10-.02(89)
(d) This unit is subject to the applicable requirements of 40 CFR Part 60, Subpart OOOOb, the Standards of Performance for Crude Oil and Natural Gas Facilities For Which Construction, Modification, Or Reconstruction Commenced After December 6, 2022.	40 CFR Part 60, Subpart OOOOb
(e) This unit is subject to the applicable requirements of 40 CFR Part 63, Subpart YYYY, the National Emission Standards for Hazardous Air Pollutants for Stationary Combustion Turbines.	ADEM Admin. Code r. 335-3-11-.06(102)
2. <u>Emission Standards</u>	
(a) The permittee shall not discharge more than one six-minute average opacity greater than 20% in any 60-minute period from this unit. At no time shall the permittee discharge a six-minute average opacity of particulate emissions greater than 40% from this unit.	ADEM Admin. Code r. 335-3-4-.01(1)
(b) PSD – Synthetic Minor Source Requirements	
The permittee shall not cause or allow emissions of nitrogen oxides (NO _x) from this unit in excess of 6.10 lb/hr or 9 ppmvd at 15% O ₂ , dry basis.	ADEM Admin. Code r. 335-3-14-.04
(c) 40 CFR Part 60, Subpart KKKK	
(i) This unit is subject to the applicable emission standards of 40 CFR §60.4320. The permittee shall not cause or allow emissions of nitrogen oxides (NO _x) from this unit in excess of 25 ppmvd at 15% O ₂ , dry basis or 150 ng/J of useful output (1.2 lb/MWh).	ADEM Admin. Code r. 335-3-10-.02(89)

Federally Enforceable Provisos	Regulations
<p>(ii) This unit is subject to the applicable emission standards of 40 CFR §60.4330. The permittee shall not burn any fuel in this turbine which contains total potential sulfur emissions in excess of 26 ng SO₂/J (0.060 lb SO₂/MMBtu heat input) OR, as an alternative, no fuel shall be burned in the unit that contains sulfur in excess of 20 grains per 100 standard cubic feet.</p>	<p>ADEM Admin. Code r. 335-3-10-.02(89)</p>
<p>(d) 40 CFR Part 63, Subpart YYYY</p>	
<p>(i) This unit is subject to the applicable emission standards of 40 CFR §63.6100 and Table 1 to Subpart YYYY. The permittee shall not cause or allow emissions of formaldehyde (CH₂O) from this unit in excess of 91 ppbvd at 15% O₂.</p>	<p>ADEM Admin Code r. 335-3-11-.06(102)</p>
<p>(ii) This unit is subject to the applicable operational limitations of 40 CFR §63.6100 and Table 2 to Subpart YYYY. The permittee shall maintain the operating limitations approved by the Administrator, which include continuously monitoring the gas producer turbine speed (% NGP) and the inlet ambient air temperature (T₁) in order to confirm the turbine is operating in lean premixed (LPM) combustion mode.</p>	<p>ADEM Admin Code r. 335-3-11-.06(102)</p>
<p>(iii) Per 40 CFR §63.6105(a), the permittee shall comply with the applicable emission limitations and operating limitations at all times, including during startup, shutdown, and malfunction.</p>	<p>ADEM Admin Code r. 335-3-11-.06(102)</p>
<p>(iv) Per 40 CFR §63.6105(c), the permittee shall operate and maintain this unit, including air pollution control and monitoring equipment, in a manner consistent with safety and good air pollution control practices for minimizing emissions at all times, including during startup, shutdown, and malfunction.</p>	<p>ADEM Admin Code r. 335-3-11-.06(102)</p>
<p>3. <u>Compliance and Performance Test Methods and Procedures</u></p>	
<p>(a) PSD – Synthetic Minor Source Requirements</p>	
<p>Compliance with the nitrogen oxides (NO_x) emission rate applicable to this unit shall be determined by EPA Reference Methods 1, 2, 3 and 4 or 19, and EPA Reference Method 7E in Appendix A of 40 CFR Part 60.</p>	<p>ADEM Admin. Code r. 335-3-1-.05</p>
<p>(b) 40 CFR Part 60, Subpart KKKK</p>	
<p>(i) Compliance with the nitrogen oxides (NO_x) emission rate applicable to this unit shall be determined by EPA Reference Methods 1, 2, 3 and 4 or 19, and EPA Reference Method 7E in Appendix A of 40 CFR Part 60.</p>	<p>ADEM Admin. Code r. 335-3-1-.05</p>

Federally Enforceable Provisos	Regulations
<p>(ii) This unit is subject to the applicable testing and procedure requirements of 40 CFR §60.4365, which include determining the sulfur content of the fuel burned in the turbine in accordance with one of the methods described in 40 CFR §60.4365(a).</p>	<p>ADEM Admin. Code r. 335-3-10-.02(89)</p>
<p>(c) 40 CFR Part 63, Subpart YYYY</p>	
<p>(i) Compliance with the formaldehyde (CH₂O) emission rate applicable to this unit shall be determined by EPA Reference Methods 1 and 3A and EPA Reference Method 320 in Appendix A of 40 CFR Part 63.</p>	<p>ADEM Admin Code r. 335-3-11-.06(102)</p>
<p>(ii) Per 40 CFR §63.6125(b), the permittee shall continuously monitor the operating parameters specified in the approved petition to the Administrator, in order to comply with the operating limitations in Table 2 and as specified in Table 5 of Subpart YYYY. These parameters are the gas producer turbine speed (% NGP) and the inlet ambient air temperature (T_i).</p>	<p>ADEM Admin Code r. 335-3-11-.06(102)</p>
<p>(d) 40 CFR Part 60, Subpart OOOOb</p>	
<p>The permittee shall demonstrate initial and continuous compliance with the following standards that apply to fugitive equipment components affected facilities found in 40 CFR §60.5410b(k) and §60.5415b(l):</p>	<p>40 CFR Part 60, Subpart OOOOb</p>
<p>(i) The permittee shall develop a fugitive emissions monitoring plan as required by 40 CFR §60.5397b(b), (c), and (d) [40 CFR §60.5410b(k)];</p>	
<p>(ii) The permittee shall conduct an initial and subsequent periodic monitoring survey as required by 40 CFR §60.5397b(f)(3) and 40 CFR §60.5397b(g) [40 CFR §60.5410b(k) and §60.5415b(l)]; and</p>	
<p>(iii) The permittee must repair each identified source of fugitive emissions for each affected facility as required by 40 CFR §60.5397b(h) [40 CFR §60.5410b(k) and §60.5415b(l)].</p>	
<p>(e) If testing is required, opacity shall be determined by 40 CFR Part 60, Appendix A, Method 9.</p>	<p>ADEM Admin. Code r. 335-3-1-.05</p>

Federally Enforceable Provisos	Regulations
<p>4. Emission Monitoring</p> <p>(a) The permittee shall only fire natural gas in this unit.</p> <p>(b) PSD – Synthetic Minor Source Requirements</p> <p>Emission testing shall be conducted semiannually to determine compliance with the applicable PSD synthetic minor source emission standard for NO_x. Testing shall be conducted twice per calendar year at a frequency of once per semiannual period (Jan 1st - Jun 30th and Jul 1st - Dec 31st), with a minimum of three (3) calendar months elapsing between tests. The first emission testing conducted following the effective date of this permit shall be conducted in accordance with an approved EPA Reference Method for NO_x. All subsequent emission testing during the permit term may be conducted using either an approved EPA Reference Method for NO_x or utilizing a portable analyzer in accordance with a protocol/method approved in advance by the Air Division.</p> <p>(i) If emission results from the above referenced performance test are less than or equal to 75% of the emission limit, then the frequency of subsequent performance tests may be reduced from a semiannual to an annual basis.</p> <p>(ii) If the results of any subsequent performance test exceed 75% of the emission limit, then semiannual performance testing shall resume until the unit demonstrates compliance for two (2) consecutive testing events demonstrating emissions are less than or equal to 75% of the emission limit, at which time annual testing may resume.</p> <p>(iii) Periodic monitoring may be conducted concurrently with the annual or biennial EPA Reference Method test that is required by 40 CFR Part 60, Subpart KKKK.</p> <p>(iv) After the first performance test conducted following the issuance of this permit, no periodic monitoring will be required if this unit does not operate for production purposes during the respective semiannual or annual testing period, whichever applies.</p> <p>(c) 40 CFR Part 60, Subpart KKKK</p> <p>(i) Emission testing shall be conducted annually to determine compliance with the applicable 40 CFR Part 60, Subpart KKKK emission standard for NO_x. Testing shall be conducted once per calendar year, with no more than fourteen (14) calendar months elapsing between tests. In accordance with 40 CFR §60.4340(a):</p>	<p>ADEM Admin. Code r. 335-3-16-.05(c)</p> <p>ADEM Admin. Code r. 335-3-16-.05(c)</p> <p>ADEM Admin. Code r. 335-3-10-.02(89)</p>

Federally Enforceable Provisos	Regulations
<p>A. If the NO_x emission results from the above referenced performance test are less than or equal to 75% of the NO_x emission limit, then the frequency of subsequent performance tests may be reduced to once every two (2) years, with no more than 26 calendar months following the previous performance test.</p> <p>B. If the results of any subsequent performance test exceed 75% of the NO_x emission limit, then annual performance testing must be resumed until the unit demonstrates compliance for two (2) consecutive testing events demonstrating emissions are less than or equal to 75% of the NO_x emission limit, at which time two (2) year testing may resume.</p> <p>(ii) The permittee shall perform subsequent emission testing once per calendar year to satisfy the Title V periodic monitoring requirement for the applicable 40 CFR Part 60, Subpart KKKK emission standard for NO_x. The subsequent annual emission testing may be conducted using either an approved EPA Reference Method or with a portable analyzer. Periodic monitoring may be conducted concurrently with the annual or biennial EPA Reference Method test that is required by 40 CFR Part 60, Subpart KKKK. No periodic monitoring will be required if the unit does not operate for production purposes during the annual testing period.</p> <p>(iii) This unit is subject to the applicable monitoring requirements of 40 CFR §60.4365, which include monitoring the total sulfur content of the fuel being fired in the unit. The permittee may demonstrate compliance with the applicable SO₂ emission standard by the use of the fuel quality characteristics in a current, valid purchase contract, tariff sheet or transportation contract for the fuel which specifies that the total sulfur content is 20 grains of sulfur or less per 100 standard cubic feet.</p>	<p>ADEM Admin. Code r. 335-3-16-.05(c)</p> <p>ADEM Admin. Code r. 335-3-10-.02(89)</p>
<p>(d) 40 CFR Part 63, Subpart YYYY</p> <p>This unit is subject to the applicable testing requirements of 40 CFR §63.6115. Emission testing shall be conducted annually to determine compliance with the applicable 40 CFR Part 63, Subpart YYYY emission standard for formaldehyde (CH₂O). Testing shall be conducted once per calendar year, with no more than fourteen (14) calendar months elapsing between tests.</p>	<p>ADEM Admin Code r. 335-3-11-.06(102)</p>

Federally Enforceable Provisos	Regulations
<p>5. Recordkeeping and Reporting Requirements</p> <p>(a) The permittee shall submit a Semiannual Monitoring Report, as required by General Permit Proviso No. 21(a), no later than 60 days after the end of each semiannual period (January 1st – June 30th and July 1st – December 31st). The report shall include a statement addressing whether only natural gas was fired in this unit and all emission monitoring was conducted as required during the reporting period. If all emission monitoring was not conducted, the report shall explain the reason(s) why it was not performed.</p> <p>(b) 40 CFR Part 60, Subpart KKKK</p> <p>(i) The permittee shall maintain records of the most current fuel tariff sheet as required by 40 CFR §60.4365, on-site in a permanent form suitable for inspection for at least five (5) years (2 years on-site and 3 years off-site) from the date of generation of each record.</p> <p>(ii) As required by 40 CFR Part 60, Subpart KKKK, the permittee shall submit a written notification of the intent to conduct a performance test to the Air Division at least 30 days prior to conducting a performance test. The notification shall include a copy of the site-specific test plan required by §60.8(d).</p> <p>(iii) As required by 40 CFR §60.4375, the permittee shall submit the results of all emission tests conducted to the Air Division within 60 days of the actual completion of the test unless the Air Division specifically approves an extension of time.</p> <p>(c) 40 CFR Part 63, Subpart YYYY</p> <p>(i) The permittee shall maintain records as required by 40 CFR §63.6160, on-site in a permanent form suitable for inspection for at least five (5) years (2 years on-site and 3 years off-site) from the date of generation of each record.</p> <p>(ii) As required by §63.6150(f), the permittee shall submit the results of all emission tests conducted to the Air Division within 60 days of the actual completion of the test unless the Air Division specifically approves an extension of time.</p> <p>(iii) The permittee shall perform the required notifications, recordkeeping, and reporting requirements in accordance with 40 CFR §63.6145, 40 CFR §63.6150, 40 CFR §63.6155, and 40 CFR §63.6160 which include, but may not be limited to:</p>	<p>ADEM Admin. Code r. 335-3-16-.05(c)</p> <p>ADEM Admin. Code r. 335-3-16-.05(c) and ADEM Admin. Code r. 335-3-10-.02(89)</p> <p>ADEM Admin. Code r. 335-3-10-.02(89)</p> <p>ADEM Admin. Code r. 335-3-10-.02(89)</p> <p>ADEM Admin. Code r. 335-3-16-.05(c) and ADEM Admin. Code r. 335-3-11-.06(102)</p> <p>ADEM Admin Code r. 335-3-11-.06(102)</p> <p>ADEM Admin Code r. 335-3-11-.06(102)</p>

Federally Enforceable Provisos	Regulations
<p>A. The permittee shall submit a Semiannual Compliance Report (SCR) which contains the information in 40 CFR §63.6150(a)(1) through (5), as applicable. The report shall be submitted for the reporting periods of January 1 – June 30 and July 1 – December 31 by July 31 and January 31, respectively.</p> <p>B. The permittee shall submit a notification of intent to conduct a performance test at least 60 calendar days prior to the test in accordance with 40 CFR §63.6145(e) and 40 CFR §63.7(b)(1).</p> <p>C. The permittee shall submit a Notification of Compliance Status in accordance with 40 CFR §63.6145(f) and 40 CFR §63.9(h)(2)(ii) for each performance test required to demonstrate compliance with the emission limitation for formaldehyde (CH₂O), including the performance test results, before the close of business on the 60th calendar day following the completion of the performance test.</p> <p>D. Recordkeeping requirements as specified in 40 CFR §63.6155.</p> <p>E. Recordkeeping format and length requirements as specified in 40 CFR §63.6160.</p> <p>(d) 40 CFR Part 60, Subpart OOOOb</p> <p>The permittee shall perform the required notification, recordkeeping, and reporting requirements in accordance with 40 CFR §60.5420b, which include, but may not be limited to:</p> <ul style="list-style-type: none"> (i) Initial Annual Report as specified in 40 CFR §60.5420b(b); (ii) Annual reports as specified in 40 CFR §60.5420b(b); and (iii) Recordkeeping requirements as specified in 40 CFR §60.5420b(c)(14). 	<p>40 CFR Part 60, Subpart OOOOb</p>

Emission Unit No. 027 (Auxiliary Unit No. 4)

Summary Page

Description: 675 hp Dresser-Waukesha L36GL 4-Stroke, Lean Burn Natural Gas-fired Emergency Reciprocating Engine (AUX 4)

Permitted Operating Schedule: 500 Hrs/yr

Emission Limitations:

Emission Point No.	Description	Pollutant	Emission Limit	Regulation
027	675 hp Dresser-Waukesha L36GL 4-Stroke, Lean Burn Natural Gas-fired Emergency Reciprocating Engine	NO _x	2.0 g/hp-hr or 160 ppmvd at 15% O ₂	ADEM Admin. Code r. 335-3-10-.03(88) 40 CFR Part 60, Subpart JJJJ (NSPS)
		CO	4.0 g/hp-hr or 540 ppmvd at 15% O ₂	ADEM Admin. Code r. 335-3-10-.03(88) 40 CFR Part 60, Subpart JJJJ (NSPS)
		VOC	1.0 g/hp-hr or 86 ppmvd at 15% O ₂	ADEM Admin. Code r. 335-3-10-.03(88) 40 CFR Part 60, Subpart JJJJ (NSPS)
		SO ₂	N/A	N/A
		PM	N/A	N/A
		HAP	N/A	N/A

Emission Unit No. 027 (Auxiliary Unit No. 4)

Unit Specific Provisos

Federally Enforceable Provisos	Regulations
<p>1. <u>Applicability</u></p> <p>(a) This unit is subject to the applicable requirements of ADEM Admin. Code r. 335-3-16-.03, “Major Source Operating Permits.”</p> <p>(b) This unit is subject to a synthetic minor source emission limit to restrict its potential to emit below the applicability threshold established at ADEM Admin. Code r. 335-3-14-.04, Air Permits Authorizing Construction in Clean Areas [Prevention of Significant Deterioration (PSD)].</p> <p>(c) This unit is subject to the applicable requirements of 40 CFR Part 63, Subpart ZZZZ, National Emission Standards for Hazardous Air Pollutants for Stationary Reciprocating Internal Combustion Engines, and 40 CFR Part 63, Subpart A as specified in Table 8 to Subpart ZZZZ.</p> <p>(d) This unit is subject to the applicable requirements of 40 CFR Part 60, Subpart JJJJ, Standards of Performance for Stationary Spark Ignition Internal Combustion Engines, and 40 CFR Part 60, Subpart A as specified in Table 3 to Subpart JJJJ.</p>	<p>ADEM Admin. Code r. 335-3-16-.03</p> <p>ADEM Admin. Code r. 335-3-14-.04</p> <p>ADEM Admin. Code r. 335-3-11-.06(103)</p> <p>ADEM Admin. Code r. 335-3-10-.02(88)</p>
<p>2. <u>Emission Standards</u></p> <p>(a) The permittee shall not operate this unit in excess of 500 hours during any consecutive 12-month period.</p> <p>(b) The permittee shall not cause or allow emission of nitrogen oxides (NO_x) from this unit in excess of 2.0 g/hp-hr or 160 ppmvd at 15% O₂.</p> <p>(c) The permittee shall not cause or allow emissions of carbon monoxide (CO) from this unit in excess of 4.0 g/hp-hr or 540 ppmvd at 15% O₂.</p> <p>(d) The permittee shall not cause or allow emissions of volatile organic compounds (VOC) from this unit in excess of 1.0 g/hp-hr or 86 ppmvd at 15% O₂.</p> <p>(e) The permittee shall not discharge more than one six-minute average opacity greater than 20% in any 60-minute period from this unit. At no time shall the permittee discharge a six-minute average opacity of particulate emissions greater than 40% from this unit.</p>	<p>ADEM Admin. Code r. 335-3-14-.04</p> <p>ADEM Admin. Code r. 335-3-10-.02(88)</p> <p>ADEM Admin. Code r. 335-3-10-.02(88)</p> <p>ADEM Admin. Code r. 335-3-10-.02(88)</p> <p>ADEM Admin. Code r. 335-3-4-.01(1)</p>

Federally Enforceable Provisos	Regulations
<p>3. <u>Compliance and Performance Test Methods and Procedures</u></p> <p>(a) Performance tests to determine compliance with the applicable nitrogen oxides (NO_x), carbon monoxide (CO), and volatile organic compound (VOC) emission limitations for this unit shall be conducted in accordance with the procedures and methods specified in 40 CFR §60.4244 and Table 2 to Subpart JJJJ.</p> <p>(b) If testing is required, opacity shall be determined by 40 CFR Part 60, Appendix A, Method 9.</p>	<p>ADEM Admin. Code r. 335-3-10-.02(88)</p> <p>ADEM Admin. Code r. 335-3-1-.05</p>
<p>4. <u>Emission Monitoring</u></p> <p>(a) To demonstrate compliance with the applicable Subpart JJJJ NO_x, CO, and VOC standards, and to satisfy the Title V periodic monitoring requirement, the permittee shall conduct emission testing for this unit every 8,760 hours of operation or every three years, whichever comes first using the appropriate EPA Reference Method,.</p> <p>(b) The permittee shall maintain a maintenance plan on file, records of all maintenance conducted on this engine, and to the extent practicable, maintain and operate this engine in a manner consistent with good air pollution control practices for minimizing emissions.</p> <p>(c) The permittee shall not operate this engine except as provided in §60.4243(d), which includes but may not be limited to:</p> <p>(i) Emergency situations;</p> <p>(ii) A total of 100 hours per year or less for the purposes allowed by 40 CFR §60.4243(d), which include maintenance checks and readiness testing, emergency demand response, and periods where deviation of voltage or frequency of 5 percent or greater below standard voltage or frequency; and</p> <p>(iii) A total of 50 hours per year or less for the non-emergency situations allowed by 40 CFR §60.4243(d); however, those 50 hours are counted towards the 100 hours per year allowed for maintenance checks and readiness testing, emergency demand response, and voltage or frequency deviations of 5 percent or greater.</p> <p>(d) This unit is limited to the use of natural gas only as a fuel to fire the engine. However, the permittee may operate the engine using propane for a maximum of 100 hours per year and an alternate fuel solely during emergency operations, but must keep records of such use.</p> <p>(e) The permittee shall only fire natural gas in this unit.</p>	<p>ADEM Admin. Code r. 335-3-10-.02(88) and ADEM Admin Code r. 335-3-16-.05(c)</p> <p>ADEM Admin. Code r. 335-3-10-.02(88)</p> <p>ADEM Admin. Code r. 335-3-10-.02(88)</p> <p>ADEM Admin. Code r. 335-3-16-.05(c) and ADEM Admin. Code r. 335-3-10-.02(88)</p> <p>ADEM Admin. Code r. 335-3-16-.05(c)</p>

Federally Enforceable Provisos	Regulations
<p>(f) Within 15 days of the end of each calendar month, the permittee shall calculate the number of hours of operation of this unit for the previous month and the previous 12-month period.</p>	<p>ADEM Admin. Code r. 335-3-14-.04</p>
<p>5. <u>Recordkeeping and Reporting Requirements</u></p>	
<p>(a) The permittee shall maintain records of hours of operation on a monthly and 12-month rolling total basis.</p>	<p>ADEM Admin. Code r. 335-3-14-.04</p>
<p>(b) The permittee shall keep each required record for 5 years following the date of each occurrence, measurement, maintenance, corrective action, report, or record. The permittee shall keep each record readily accessible in hard copy or electronic form on site for at least 2 years after the date of each occurrence, measurement, maintenance, corrective action, report, or record. The permittee may keep the records off site for the remaining 3 years.</p>	<p>ADEM Admin. Code r. 335-3-16-.05(c)</p>
<p>(c) The permittee shall keep the following records for this engine in accordance with 40 CFR §60.4245. At a minimum, these records shall include:</p>	<p>ADEM Admin. Code r. 335-3-16-.05(c) and ADEM Admin. Code r. 335-3-10-.02(88)</p>
<p>(i) A copy of all notifications submitted to comply with 40 CFR Part 60, Subpart JJJJ and all documentation supporting any notification;</p>	
<p>(ii) For each period of operation, the permittee shall record the date and length of operation and the reason the engine was in operation during that time. For periods of operation designated as “emergency operation,” the records shall reflect what classified the operation as emergency. The permittee shall subtotal the total number of hours the engine was operated during a calendar year by the reason the engine was in operation;</p>	
<p>(iii) The dates and nature of maintenance performed.</p>	
<p>(d) As required by 40 CFR Part 60, Subpart JJJJ, the permittee shall submit a written notification of the intent to conduct a performance test to the Air Division at least 30 days prior to conducting a performance test. The notification shall include a copy of the site-specific test plan required by §60.8(d).</p>	<p>ADEM Admin. Code r. 335-3-10-.02(88)</p>
<p>(e) As required by 40 CFR §60.4245, the permittee shall submit the results of all emission tests conducted to the Air Division within 60 days of the actual completion of the test unless the Air Division specifically approves an extension of time.</p>	<p>ADEM Admin. Code r. 335-3-10-.02(88)</p>

Federally Enforceable Provisos	Regulations
<p>(f) The permittee shall submit a Semiannual Monitoring Report, as required by General Permit Proviso No. 21(a), no later than 60 days after the end of each semiannual period (January 1st – June 30th and July 1st – December 31st). The report shall include a statement addressing whether only natural gas was fired in this unit and all emission monitoring was conducted as required during the reporting period. If all emission monitoring was not conducted, the report shall explain the reason(s) why it was not performed.</p>	<p>ADEM Admin. Code r. 335-3-16-.05(c)</p>